


# Turkey Point 4

## 3Q/2009 Performance Indicators

Licensee's General Comments: none

### Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

### Notes

Unplanned Scrams per 7000 Critical Hrs	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09
Unplanned scrams	0	2.0	0	0	0	0	0	0
Critical hours	2209.0	2098.6	1255.6	2019.8	2144.4	2159.0	2184.0	2208.0
Indicator value	0	1.6	1.8	1.8	1.9	0	0	0

Licensee Comments: none

## Unplanned Power Changes per 7000 Critical Hrs



Thresholds: White > 6.0

### Notes

Unplanned Power Changes per 7000 Critical Hrs	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09
Unplanned power changes	0	0	0	0	0	1.0	0	0
Critical hours	2209.0	2098.6	1255.6	2019.8	2144.4	2159.0	2184.0	2208.0
Indicator value	0.8	0.8	0.9	0	0	0.9	0.8	0.8

Licensee Comments: none

## Unplanned Scrams with Complications



Thresholds: White > 1.0


### Notes

Unplanned Scrams with Complications	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

---

## Safety System Functional Failures (PWR)




Thresholds: White > 5.0

### Notes

Safety System Functional Failures (PWR)	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09
Safety System Functional Failures	0	0	0	1	1	0	0	0
Indicator value	0	0	0	1	2	2	2	1

Licensee Comments: none

# Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, Emergency AC Power System	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09
UAI ( $\Delta$ CDF)	1.70E-09	1.70E-09	1.60E-09	2.00E-09	1.80E-09	4.50E-09	4.60E-09	4.90E-09
URI ( $\Delta$ CDF)	-7.10E-09	-7.20E-09	-7.60E-09	-7.70E-09	-1.40E-08	-1.40E-08	-1.40E-08	-6.50E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-5.40E-09	-5.50E-09	-6.00E-09	-5.70E-09	-1.22E-08	-9.50E-09	-9.40E-09	-1.60E-09

Licensee Comments: none

# Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, High Pressure Injection System	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09
UAI ( $\Delta$ CDF)	7.60E-11	6.90E-11	1.10E-10	3.50E-10	5.60E-10	5.40E-10	4.80E-10	5.50E-10
URI ( $\Delta$ CDF)	1.40E-09	1.40E-09	1.40E-09	1.40E-09	1.40E-09	-1.10E-09	-1.10E-09	-1.10E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	1.48E-09	1.47E-09	1.51E-09	1.75E-09	1.96E-09	-5.60E-10	-6.20E-10	-5.50E-10

Licensee Comments: none

# Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, Heat Removal System	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09
UAI ( $\Delta$ CDF)	5.60E-09	8.60E-10	4.50E-10	3.30E-10	-2.50E-11	3.60E-09	4.60E-09	7.90E-09
URI ( $\Delta$ CDF)	3.80E-08	3.80E-08	3.80E-08	3.80E-08	-9.80E-08	-1.00E-07	-1.00E-07	-1.00E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	4.36E-08	3.89E-08	3.85E-08	3.83E-08	-9.80E-08	-9.64E-08	-9.54E-08	-9.21E-08

Licensee Comments: none

# Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


## Notes

Mitigating Systems Performance Index, Residual Heat Removal System	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09
UAI ( $\Delta$ CDF)	9.50E-10	-3.50E-11	-4.70E-10	-4.70E-10	-4.70E-10	-4.70E-10	-4.70E-10	-2.30E-10
URI ( $\Delta$ CDF)	2.90E-09	2.70E-09	-1.80E-09	-1.80E-09	-1.80E-09	-1.90E-09	-1.90E-09	-2.00E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	3.85E-09	2.67E-09	-2.27E-09	-2.27E-09	-2.27E-09	-2.37E-09	-2.37E-09	-2.23E-09

Licensee Comments: none



# Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, Cooling Water Systems	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09
UAI ( $\Delta$ CDF)	6.00E-10	8.00E-10	9.90E-10	9.60E-10	1.30E-09	1.50E-09	1.60E-09	1.50E-09
URI ( $\Delta$ CDF)	8.70E-11	3.70E-10	6.00E-11	6.10E-11	6.20E-11	6.10E-11	6.00E-11	5.90E-11
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	6.87E-10	1.17E-09	1.05E-09	1.02E-09	1.36E-09	1.56E-09	1.66E-09	1.56E-09

Licensee Comments: none

# Reactor Coolant System Activity




Thresholds: White > 50.0 Yellow > 100.0

## Notes

Reactor Coolant System Activity	10/07	11/07	12/07	1/08	2/08	3/08	4/08	5/08	6/08	7/08	8/08	9/08
Maximum activity	0.000641	0.000580	0.000549	0.000710	0.000605	0.000657	0.000005	0.000286	0.000280	0.000308	0.000308	0.000319
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0.1	0.1	0.1	0.1	0.1	0.1	0	0	0	0	0	0
Reactor Coolant System Activity	10/08	11/08	12/08	1/09	2/09	3/09	4/09	5/09	6/09	7/09	8/09	9/09
Maximum activity	0.000320	0.000369	0.000377	0.000402	0.000391	0.000489	0.000424	0.000459	0.000461	0.000457	0.000469	0.000505
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0.1

Licensee Comments: none

## Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

### Notes

Reactor Coolant System Leakage	10/07	11/07	12/07	1/08	2/08	3/08	4/08	5/08	6/08	7/08	8/08	9/08
Maximum leakage	0.040	0.050	0.080	0.080	0.060	0.060	N/A	0.090	0.050	0.160	0.220	0.140
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.4	0.5	0.8	0.8	0.6	0.6	N/A	0.9	0.5	1.6	2.2	1.4
Reactor Coolant System Leakage	10/08	11/08	12/08	1/09	2/09	3/09	4/09	5/09	6/09	7/09	8/09	9/09
Maximum leakage	0.140	0.120	0.050	0.030	0.040	0.060	0.020	0.040	0.020	0.100	0.070	0.040
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	1.4	1.2	0.5	0.3	0.4	0.6	0.2	0.4	0.2	1.0	0.7	0.4

Licensee Comments: none

## Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

### Notes

Drill/Exercise Performance	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09
Successful opportunities	36.0	37.0	40.0	20.0	38.0	68.0	44.0	29.0
Total opportunities	38.0	45.0	42.0	20.0	41.0	72.0	44.0	31.0
Indicator value	96.2%	93.5%	93.9%	93.6%	93.0%	93.8%	94.3%	93.7%

Licensee Comments: none

## ERO Drill Participation



Thresholds: White < 80.0% Yellow < 60.0%


### Notes

ERO Drill Participation	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09
Participating Key personnel	82.0	80.0	85.0	92.0	85.0	81.0	80.0	116.0
Total Key personnel	82.0	80.0	85.0	92.0	85.0	81.0	84.0	119.0
Indicator value	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	95.2%	97.5%

Licensee Comments: none

---

# Alert & Notification System



Thresholds: White < 94.0% Yellow < 90.0%

## Notes

Alert & Notification System	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09
Successful siren-tests	376	375	329	372	326	376	328	370
Total sirens-tests	376	376	329	376	329	376	329	376
Indicator value	99.8%	99.8%	99.9%	99.7%	99.4%	99.5%	99.4%	99.3%

Licensee Comments: none

# Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0

## Notes

Occupational Exposure Control Effectiveness	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

Licensee Comments: none

---

# RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

## Notes

RETS/ODCM Radiological Effluent	4Q/07	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

[Security](#) information not publicly available.