


Crystal River 3

4Q/2009 Performance Indicators

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
Unplanned scrams	0	0	1.0	0	1.0	0	1.0	0
Critical hours	1717.7	2184.0	2122.6	2209.0	2106.0	2184.0	2056.7	0
Indicator value	0	0	0.9	0.9	1.6	1.6	1.6	2.2

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs



Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
Unplanned power changes	1.0	1.0	1.0	0	0	0	0	0
Critical hours	1717.7	2184.0	2122.6	2209.0	2106.0	2184.0	2056.7	0
Indicator value	1.9	2.8	3.8	2.6	1.6	0.8	0	0

Licensee Comments: none

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

Safety System Functional Failures (PWR)




Thresholds: White > 5.0

Notes

Safety System Functional Failures (PWR)	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
Safety System Functional Failures	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
UAI (Δ CDF)	-4.10E-09	8.10E-09	3.10E-09	-3.10E-09	-5.10E-09	-3.90E-09	-3.90E-09	-3.50E-09
URI (Δ CDF)	4.80E-08	4.80E-08	4.80E-08	4.90E-08	4.90E-08	4.90E-08	5.00E-08	-1.30E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	4.39E-08	5.61E-08	5.11E-08	4.59E-08	4.39E-08	4.51E-08	4.61E-08	4.80E-09

Licensee Comments: none

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
UAI (Δ CDF)	-4.90E-09	-4.90E-09	-4.90E-09	-4.90E-09	-4.90E-09	-4.90E-09	3.30E-09	5.60E-09
URI (Δ CDF)	-9.60E-09	-9.70E-09	-9.80E-09	-9.80E-09	-9.90E-09	-9.90E-09	-1.00E-08	-1.00E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.45E-08	-1.46E-08	-1.47E-08	-1.47E-08	-1.48E-08	-1.48E-08	-6.70E-09	-4.40E-09

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
UAI (Δ CDF)	2.40E-08	2.40E-08	2.00E-08	2.40E-08	2.50E-08	1.70E-08	1.10E-08	-3.80E-09
URI (Δ CDF)	-5.00E-08	-5.00E-08	-5.00E-08	-4.90E-08	-4.90E-08	-4.90E-08	-4.90E-08	-4.90E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-2.60E-08	-2.60E-08	-3.00E-08	-2.50E-08	-2.40E-08	-3.20E-08	-3.80E-08	-5.28E-08

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
UAI (Δ CDF)	-1.20E-08	-1.40E-08	-6.50E-09	-1.20E-08	-1.20E-08	-7.30E-09	1.20E-09	2.60E-08
URI (Δ CDF)	-2.70E-08	-2.70E-08	-2.70E-08	-2.80E-08	-2.80E-08	-2.90E-08	-2.90E-08	-3.00E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-3.90E-08	-4.10E-08	-3.35E-08	-4.00E-08	-4.00E-08	-3.63E-08	-2.78E-08	-4.00E-09

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


Notes

Mitigating Systems Performance Index, Cooling Water Systems	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
UAI (Δ CDF)	1.40E-07	1.10E-07	1.30E-07	7.90E-08	1.40E-07	1.10E-07	2.00E-07	1.90E-07
URI (Δ CDF)	-1.40E-07	-1.40E-07	-1.40E-07	-1.40E-07	-1.40E-07	-1.40E-07	-3.00E-08	-6.50E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	0.00E+00	-3.00E-08	-1.00E-08	-6.10E-08	0.00E+00	-3.00E-08	1.70E-07	1.25E-07

Licensee Comments:

4Q/09: Changed PRA Parameter(s). The UABLP for RWP-1 was revised to include 1646.51 overhaul hours incurred 07/06/09 - 09/11/09. The UABLP for SWP-1C was revised to include 1627.96 overhaul hours incurred 06/29/09 - 09/04/09. The Operational Demands (estimated) and Total Start Demands (estimated) for DCP-1A, DCP-1B, SWP-1A, SWP-1B and SWP-1C were revised because the estimated number of demands were more than 25% less than the baseline value assumed in the MSPI Basis Document.

Reactor Coolant System Activity




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Activity	1/08	2/08	3/08	4/08	5/08	6/08	7/08	8/08	9/08	10/08	11/08	12/08
Maximum activity	0.001060	0.001144	0.000926	0.001342	0.001835	0.001571	0.001635	0.001660	0.001675	0.001920	0.001690	0.001510
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Reactor Coolant System Activity	1/09	2/09	3/09	4/09	5/09	6/09	7/09	8/09	9/09	10/09	11/09	12/09
Maximum activity	0.001720	0.000982	0.001030	0.000745	0.001050	0.001530	0.001630	0.001540	0.002510	N/A	N/A	N/A
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0.2	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.3	N/A	N/A	N/A

Licensee Comments: none

Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	1/08	2/08	3/08	4/08	5/08	6/08	7/08	8/08	9/08	10/08	11/08	12/08
Maximum leakage	0.700	1.170	0.080	0.100	0.100	0.120	0.120	0.210	0.160	0.160	0.200	0.220
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	7.0	11.7	0.8	1.0	1.0	1.2	1.2	2.1	1.6	1.6	2.0	2.2
Reactor Coolant System Leakage	1/09	2/09	3/09	4/09	5/09	6/09	7/09	8/09	9/09	10/09	11/09	12/09
Maximum leakage	0.240	0.200	0.260	0.290	0.340	0.390	0.340	0.450	0.320	N/A	N/A	N/A
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	2.4	2.0	2.6	2.9	3.4	3.9	3.4	4.5	3.2	N/A	N/A	N/A

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
Successful opportunities	50.0	52.0	30.0	15.0	33.0	19.0	20.0	0
Total opportunities	52.0	59.0	30.0	15.0	34.0	19.0	21.0	0
Indicator value	97.6%	95.8%	96.0%	96.2%	95.6%	95.7%	95.2%	95.2%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
Participating Key personnel	76.0	75.0	78.0	82.0	73.0	76.0	82.0	80.0
Total Key personnel	80.0	82.0	83.0	82.0	74.0	77.0	82.0	80.0
Indicator value	95.0%	91.5%	94.0%	100.0%	98.6%	98.7%	100.0%	100.0%

Licensee Comments: none

Alert & Notification System



Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
Successful siren-tests	1035	1038	1036	1079	1000	1038	1078	998
Total sirens-tests	1038	1040	1040	1080	1000	1040	1080	1000
Indicator value	99.2%	99.5%	99.6%	99.8%	99.8%	99.8%	99.9%	99.9%

Licensee Comments: none

Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

[Security](#) information not publicly available.