


# Dresden 3

## 4Q/2009 Performance Indicators

Licensee's General Comments: none

### Unplanned Scrams per 7000 Critical Hrs



Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0


### Notes

Unplanned Scrams per 7000 Critical Hrs	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
Unplanned scrams	0	0	0	0	0	0	0	1.0
Critical hours	1983.8	2184.0	2208.0	1804.0	2159.0	2145.0	2208.0	2145.7
Indicator value	0	0	0	0	0	0	0	0.8

Licensee Comments: none

---

## Unplanned Power Changes per 7000 Critical Hrs



Thresholds: White > 6.0

### Notes

Unplanned Power Changes per 7000 Critical Hrs	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
Unplanned power changes	0	0	1.0	0	0	0	1.0	1.0
Critical hours	1983.8	2184.0	2208.0	1804.0	2159.0	2145.0	2208.0	2145.7
Indicator value	0	0	0.8	0.9	0.8	0.8	0.8	1.6

Licensee Comments: none

## Unplanned Scrams with Complications



Thresholds: White > 1.0


### Notes

Unplanned Scrams with Complications	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

---

## Safety System Functional Failures (BWR)




Thresholds: White > 6.0

### Notes

Safety System Functional Failures (BWR)	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
Safety System Functional Failures	0	1	0	1	0	1	1	0
Indicator value	1	1	1	2	2	2	3	2

Licensee Comments: none

# Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, Emergency AC Power System	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
UAI ( $\Delta$ CDF)	-4.60E-09	-4.00E-09	-4.00E-09	-4.00E-09	-4.00E-09	-2.40E-09	-2.10E-09	5.10E-10
URI ( $\Delta$ CDF)	-3.70E-08	6.40E-08	6.40E-08	6.50E-08	6.10E-08	1.70E-07	1.60E-07	2.70E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-4.16E-08	6.00E-08	6.00E-08	6.10E-08	5.70E-08	1.68E-07	1.58E-07	2.75E-08

Licensee Comments: none

# Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, High Pressure Injection System	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
UAI ( $\Delta$ CDF)	-1.20E-09	-1.40E-09	-1.40E-09	1.10E-08	1.20E-08	1.70E-09	1.70E-09	2.50E-08
URI ( $\Delta$ CDF)	-9.90E-09	-9.90E-09	-9.90E-09	-9.90E-09	-1.00E-08	-1.00E-08	-1.00E-08	-1.10E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.11E-08	-1.13E-08	-1.13E-08	1.10E-09	2.00E-09	-8.30E-09	-8.30E-09	1.40E-08

Licensee Comments: none

# Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, Heat Removal System	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
UAI ( $\Delta$ CDF)	-4.30E-09	-4.30E-09	-4.30E-09	-4.30E-09	-4.30E-09	-4.30E-09	-4.30E-09	-4.30E-09
URI ( $\Delta$ CDF)	-6.00E-11	-6.00E-11	-6.00E-11	-6.00E-11	-6.00E-11	-6.00E-11	-6.00E-11	-6.80E-11
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-4.36E-09	-4.36E-09	-4.36E-09	-4.36E-09	-4.36E-09	-4.36E-09	-4.36E-09	-4.37E-09

Licensee Comments: none

# Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


## Notes

Mitigating Systems Performance Index, Residual Heat Removal System	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
UAI ( $\Delta$ CDF)	-1.30E-09	-1.30E-09	-1.30E-09	-1.30E-09	-1.20E-09	-1.30E-09	-1.30E-09	-1.30E-09
URI ( $\Delta$ CDF)	-1.60E-09	-1.60E-09	-1.60E-09	-1.70E-09	-1.80E-09	-1.70E-09	-1.70E-09	-1.70E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-2.90E-09	-2.90E-09	-2.90E-09	-3.00E-09	-3.00E-09	-3.00E-09	-3.00E-09	-3.00E-09

Licensee Comments: none



# Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, Cooling Water Systems	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
UAI ( $\Delta$ CDF)	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.10E-11	1.10E-11
URI ( $\Delta$ CDF)	-1.90E-11	-2.00E-11	-1.90E-11	-2.00E-11	-2.10E-11	-2.10E-11	-2.10E-11	-2.10E-11
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.90E-11	-2.00E-11	-1.90E-11	-2.00E-11	-2.10E-11	-2.10E-11	-1.00E-11	-1.00E-11

Licensee Comments: none

# Reactor Coolant System Activity




Thresholds: White > 50.0 Yellow > 100.0

## Notes

Reactor Coolant System Activity	1/08	2/08	3/08	4/08	5/08	6/08	7/08	8/08	9/08	10/08	11/08	12/08
Maximum activity	0.000020	0.000004	0.000019	0.000032	0.000033	0.000016	0.000028	0.000028	0.000034	0.000013	0.000015	0.000014
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0
Reactor Coolant System Activity	1/09	2/09	3/09	4/09	5/09	6/09	7/09	8/09	9/09	10/09	11/09	12/09
Maximum activity	0.000023	0.000016	0.000011	0.000016	0.000015	0.000015	0.000014	0.000012	0.000013	0.000012	0.000020	0.000011
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Licensee Comments: none

## Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

### Notes

Reactor Coolant System Leakage	1/08	2/08	3/08	4/08	5/08	6/08	7/08	8/08	9/08	10/08	11/08	12/08
Maximum leakage	2.490	2.018	1.933	1.918	2.018	1.937	1.942	1.922	1.935	1.950	2.012	1.833
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	10.0	8.1	7.7	7.7	8.1	7.7	7.8	7.7	7.7	7.8	8.0	7.3
Reactor Coolant System Leakage	1/09	2/09	3/09	4/09	5/09	6/09	7/09	8/09	9/09	10/09	11/09	12/09
Maximum leakage	1.837	1.820	1.823	1.855	1.868	1.882	1.855	1.835	1.838	2.102	2.007	1.973
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	7.3	7.3	7.3	7.4	7.5	7.5	7.4	7.3	7.4	8.4	8.0	7.9

Licensee Comments: none

## Drill/Exercise Performance



Thresholds: White < 90.0% Yellow < 70.0%


### Notes

Drill/Exercise Performance	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
Successful opportunities	24.0	16.0	40.0	24.0	46.0	33.0	36.0	34.0
Total opportunities	24.0	16.0	40.0	24.0	46.0	34.0	36.0	34.0
Indicator value	97.1%	96.8%	99.2%	99.2%	100.0%	99.6%	99.5%	99.6%

Licensee Comments:

2Q/09: Numerical corrections made to "Successful drill, exer & event opportunities" and "Total drill, exer & event opportunities" for May 2009.

## ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

### Notes

ERO Drill Participation	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
Participating Key personnel	63.0	67.0	64.0	64.0	63.0	65.0	65.0	71.0
Total Key personnel	64.0	68.0	64.0	64.0	64.0	65.0	65.0	71.0
Indicator value	98.4%	98.5%	100.0%	100.0%	98.4%	100.0%	100.0%	100.0%

Licensee Comments: none

# Alert & Notification System



**Thresholds:** White < 94.0% Yellow < 90.0%

## Notes

Alert & Notification System	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
Successful siren-tests	4970	4972	5037	4963	4900	4978	5064	4983
Total sirens-tests	4992	4992	5070	4992	4914	4992	5070	4992
Indicator value	99.6%	99.6%	99.6%	99.5%	99.5%	99.5%	99.7%	99.8%

Licensee Comments: none

# Occupational Exposure Control Effectiveness



**Thresholds: White > 2.0 Yellow > 5.0**

## Notes

Occupational Exposure Control Effectiveness	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

Licensee Comments: none

---

# RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

## Notes

RETS/ODCM Radiological Effluent	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

[Security](#) information not publicly available.