


Millstone 3

4Q/2009 Performance Indicators

Licensee's General Comments: The Emergency Response Organization Drill Participation indicator data for September was revised due to a personal qualification error. The change did not result in the indicator crossing a threshold.

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
Unplanned scrams	0	0	0	1.0	0	0	0	1.0
Critical hours	2183.0	2184.0	2208.0	1194.9	2159.0	2184.0	2208.0	1919.9
Indicator value	0	0	0	0.9	0.9	0.9	0.9	0.8

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs



Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
Unplanned power changes	0	0	0	0	0	0	0	0
Critical hours	2183.0	2184.0	2208.0	1194.9	2159.0	2184.0	2208.0	1919.9
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

Safety System Functional Failures (PWR)




Thresholds: White > 5.0

Notes

Safety System Functional Failures (PWR)	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
Safety System Functional Failures	0	0	0	1	0	0	0	0
Indicator value	0	0	0	1	1	1	1	0

Licensee Comments: none

Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
UAI (Δ CDF)	4.00E-07	1.30E-07	7.50E-08	9.40E-08	1.00E-07	1.00E-07	5.70E-08	1.10E-07
URI (Δ CDF)	-6.10E-07	-5.70E-07	-5.80E-07	-5.80E-07	-5.30E-07	-5.40E-07	-9.00E-08	-9.80E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-2.10E-07	-4.40E-07	-5.05E-07	-4.86E-07	-4.30E-07	-4.40E-07	-3.30E-08	1.20E-08

Licensee Comments: none

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
UAI (Δ CDF)	3.00E-08	1.70E-08	2.90E-08	2.90E-08	1.40E-08	1.10E-08	-5.10E-09	-9.60E-09
URI (Δ CDF)	1.10E-07	1.20E-07	1.30E-07	1.40E-07	-1.70E-07	-1.70E-07	1.10E-07	1.10E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	1.40E-07	1.37E-07	1.59E-07	1.69E-07	-1.56E-07	-1.59E-07	1.05E-07	1.00E-07

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
UAI (Δ CDF)	1.40E-07	1.20E-07	1.40E-07	1.40E-07	3.70E-08	-4.90E-10	3.30E-09	-4.10E-08
URI (Δ CDF)	8.10E-07	3.60E-07	3.60E-07	3.80E-07	-1.10E-07	-1.10E-07	-9.00E-08	-9.30E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	9.50E-07	4.80E-07	5.00E-07	5.20E-07	-7.30E-08	-1.10E-07	-8.67E-08	-1.34E-07

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
UAI (Δ CDF)	-9.80E-09	-9.80E-09	-9.80E-09	-9.80E-09	-9.80E-09	-9.80E-09	-1.70E-08	-1.70E-08
URI (Δ CDF)	-2.60E-08	-2.50E-08	-2.50E-08	-2.60E-08	-2.60E-08	-2.60E-08	-4.40E-08	-4.50E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-3.58E-08	-3.48E-08	-3.48E-08	-3.58E-08	-3.58E-08	-3.58E-08	-6.10E-08	-6.20E-08

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
UAI (Δ CDF)	2.50E-08	3.60E-08	3.50E-08	3.90E-08	1.10E-08	-1.00E-07	-3.50E-08	-3.50E-08
URI (Δ CDF)	-2.50E-08	-2.50E-08	-2.50E-08	-2.50E-08	-2.50E-08	-2.50E-08	-4.30E-08	-4.30E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	0.00E+00	1.10E-08	1.00E-08	1.40E-08	-1.40E-08	-1.25E-07	-7.80E-08	-7.80E-08

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	1/08	2/08	3/08	4/08	5/08	6/08	7/08	8/08	9/08	10/08	11/08	12/08
Maximum activity	0.000426	0.000408	0.000391	0.000343	0.000348	0.000345	0.000402	0.000398	0.000299	0.000299	0	0.000248
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Reactor Coolant System Activity	1/09	2/09	3/09	4/09	5/09	6/09	7/09	8/09	9/09	10/09	11/09	12/09
Maximum activity	0.000251	0.000442	0.000326	0.000320	0.000339	0.000429	0.000436	0.000500	0.001033	0.000591	0.000583	0.000714
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0	0	0	0	0	0.1	0.1	0.1	0.1	0.1

Licensee Comments: none

Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	1/08	2/08	3/08	4/08	5/08	6/08	7/08	8/08	9/08	10/08	11/08	12/08
Maximum leakage	0.051	0.144	0.068	0.147	0.111	0.078	0.077	0.063	0.144	0.058	0.083	0.096
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.5	1.4	0.7	1.5	1.1	0.8	0.8	0.6	1.4	0.6	0.8	1.0
Reactor Coolant System Leakage	1/09	2/09	3/09	4/09	5/09	6/09	7/09	8/09	9/09	10/09	11/09	12/09
Maximum leakage	0.102	0.087	0.093	0.082	0.087	0.091	0.087	0.085	0.076	0.077	0.084	0.086
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	1.0	0.9	0.9	0.8	0.9	0.9	0.9	0.9	0.8	0.8	0.8	0.9

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
Successful opportunities	35.0	38.0	57.0	0	23.0	48.0	50.0	36.0
Total opportunities	37.0	41.0	59.0	0	26.0	49.0	51.0	37.0
Indicator value	92.9%	92.4%	93.6%	93.6%	93.5%	94.3%	94.7%	95.7%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
Participating Key personnel	141.0	144.0	147.0	145.0	142.0	140.0	136.0	145.0
Total Key personnel	147.0	146.0	147.0	145.0	143.0	143.0	146.0	145.0
Indicator value	95.9%	98.6%	100.0%	100.0%	99.3%	97.9%	93.2%	100.0%

Licensee Comments: none

Alert & Notification System



Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
Successful siren-tests	316	304	450	304	316	310	459	314
Total sirens-tests	318	318	477	318	318	318	477	318
Indicator value	97.2%	96.5%	96.3%	96.0%	96.0%	96.4%	97.1%	97.8%

Licensee Comments: none

Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

[Security](#) information not publicly available.