


Palo Verde 3

4Q/2009 Performance Indicators

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
Unplanned scrams	0	0	2.0	0	0	0	0	1.0
Critical hours	1838.3	2184.0	2091.2	2208.0	2160.0	919.4	2208.0	2155.7
Indicator value	0	0	2.3	1.7	1.6	1.9	0	0.9

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs



Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
Unplanned power changes	0	0	1.0	0	0	0	0	0
Critical hours	1838.3	2184.0	2091.2	2208.0	2160.0	919.4	2208.0	2155.7
Indicator value	2.4	0	1.1	0.8	0.8	0.9	0	0

Licensee Comments: none

Unplanned Scrams with Complications



Thresholds: White > 1.0


Notes

Unplanned Scrams with Complications	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments:

4Q/09: A plant specific FAQ per NEI 99-02 Appendix D is being prepared regarding the Unit 3 scram that occurred on December 3, 2009.

Safety System Functional Failures (PWR)




Thresholds: White > 5.0

Notes

Safety System Functional Failures (PWR)	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
Safety System Functional Failures	0	0	0	0	0	1	0	0
Indicator value	0	0	0	0	0	1	1	1

Licensee Comments: none

Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
UAI (ΔCDF)	9.70E-08	1.80E-07	1.60E-07	1.70E-07	4.90E-08	4.30E-08	3.60E-08	2.90E-08
URI (ΔCDF)	-6.70E-08	-6.70E-08	-6.70E-08	-6.70E-08	9.30E-08	1.80E-07	7.90E-09	3.40E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	3.00E-08	1.13E-07	9.30E-08	1.03E-07	1.42E-07	2.23E-07	4.39E-08	3.24E-08

Licensee Comments: none

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
UAI (Δ CDF)	6.10E-09	5.60E-09	5.60E-09	3.10E-09	1.90E-09	1.90E-09	1.90E-09	1.90E-09
URI (Δ CDF)	-1.50E-08	-1.50E-08	-1.50E-08	-1.50E-08	-2.30E-08	-2.30E-08	-2.20E-08	-2.20E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-8.90E-09	-9.40E-09	-9.40E-09	-1.19E-08	-2.11E-08	-2.11E-08	-2.01E-08	-2.01E-08

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
UAI (Δ CDF)	-3.20E-08	-7.70E-08	-1.50E-07	-1.70E-07	-6.70E-08	-6.00E-08	-6.30E-08	-6.30E-08
URI (Δ CDF)	-2.30E-07	-2.30E-07	-2.30E-07	-2.30E-07	-9.80E-08	-9.80E-08	-9.80E-08	-1.00E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-2.62E-07	-3.07E-07	-3.80E-07	-4.00E-07	-1.65E-07	-1.58E-07	-1.61E-07	-1.63E-07

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
UAI (Δ CDF)	4.50E-09	9.30E-09	8.50E-09	6.80E-09	2.20E-09	1.40E-09	2.60E-09	1.90E-09
URI (Δ CDF)	-9.00E-09	-9.00E-09	-9.00E-09	-9.00E-09	-2.30E-08	6.80E-08	6.90E-08	7.00E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-4.50E-09	3.00E-10	-5.00E-10	-2.20E-09	-2.08E-08	6.94E-08	7.16E-08	7.19E-08

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
UAI (Δ CDF)	9.10E-09	8.80E-09	2.30E-08	2.30E-08	1.10E-08	1.10E-08	9.30E-09	9.30E-09
URI (Δ CDF)	-1.60E-07	-1.60E-07	-1.60E-07	-1.60E-07	-1.90E-07	-1.90E-07	-1.90E-07	-1.90E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.51E-07	-1.51E-07	-1.37E-07	-1.37E-07	-1.79E-07	-1.79E-07	-1.81E-07	-1.81E-07

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	1/08	2/08	3/08	4/08	5/08	6/08	7/08	8/08	9/08	10/08	11/08	12/08
Maximum activity	0.000146	0.000152	0.000162	0.000172	0.000175	0.000179	0.000178	0.000181	0.000181	0.000190	0.000188	0.000194
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0
Reactor Coolant System Activity	1/09	2/09	3/09	4/09	5/09	6/09	7/09	8/09	9/09	10/09	11/09	12/09
Maximum activity	0.000191	0.000200	0.000198	0.000185	N/A	0.000157	0.000165	0.000163	0.000177	0.000179	0.000190	0.000252
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0	0	N/A	0	0	0	0	0	0	0

Licensee Comments:

6/09: The station was unable to perform Unit 3 I-131 analysis during the refueling outage in May 2009 .

Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	1/08	2/08	3/08	4/08	5/08	6/08	7/08	8/08	9/08	10/08	11/08	12/08
Maximum leakage	0.051	0.023	0.047	0.029	0.014	0.041	0.033	0.053	0.032	0.050	0.027	0.029
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.5	0.2	0.5	0.3	0.1	0.4	0.3	0.5	0.3	0.5	0.3	0.3
Reactor Coolant System Leakage	1/09	2/09	3/09	4/09	5/09	6/09	7/09	8/09	9/09	10/09	11/09	12/09
Maximum leakage	0.037	0.031	0.050	0.018	0.017	0.053	0.033	0.034	0.023	0.041	0.027	0.067
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.4	0.3	0.5	0.2	0.2	0.5	0.3	0.3	0.2	0.4	0.3	0.7

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
Successful opportunities	129.0	35.0	43.0	35.0	75.0	109.0	49.0	13.0
Total opportunities	132.0	39.0	43.0	39.0	79.0	112.0	50.0	14.0
Indicator value	94.4%	94.0%	95.0%	94.6%	94.6%	95.4%	96.2%	96.1%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
Participating Key personnel	188.0	191.0	183.0	72.0	78.0	87.0	95.0	92.0
Total Key personnel	190.0	191.0	183.0	85.0	78.0	87.0	95.0	92.0
Indicator value	98.9%	100.0%	100.0%	84.7%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
Successful siren-tests	296	296	296	331	296	296	296	333
Total sirens-tests	296	296	296	333	296	296	296	333
Indicator value	100.0%	100.0%	100.0%	99.8%	99.8%	99.8%	99.8%	100.0%

Licensee Comments: none

Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	1Q/08	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

[Security](#) information not publicly available.