


Prairie Island 2

1Q/2010 Performance Indicators

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10
Unplanned scrams	0	0	1.0	0	0	0	0	0
Critical hours	2184.0	1942.7	1477.8	2159.0	2184.0	2208.0	2209.0	2159.0
Indicator value	0	0	0.9	0.9	0.9	0.9	0	0

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10
Unplanned power changes	0	0	0	0	0	0	0	0
Critical hours	2184.0	1942.7	1477.8	2159.0	2184.0	2208.0	2209.0	2159.0
Indicator value	0.8	0.8	0.9	0	0	0	0	0

Licensee Comments: none

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

Safety System Functional Failures (PWR)




Thresholds: White > 5.0

Notes

Safety System Functional Failures (PWR)	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10
Safety System Functional Failures	0	1	0	0	1	0	1	0
Indicator value	0	1	1	1	2	1	2	2

Licensee Comments: none

Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10
UAI (Δ CDF)	9.60E-08	9.80E-08	1.00E-07	1.00E-07	1.50E-07	1.50E-07	1.40E-07	1.44E-07
URI (Δ CDF)	-2.30E-08	-2.20E-08	-2.10E-08	-2.10E-08	-2.10E-08	-2.10E-08	-2.10E-08	7.17E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	7.30E-08	7.60E-08	7.90E-08	7.90E-08	1.29E-07	1.29E-07	1.19E-07	2.20E-07

Licensee Comments: none

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10
UAI (ΔCDF)	-3.80E-09	-3.60E-09	-1.50E-09	-1.80E-09	-1.80E-09	4.70E-09	1.20E-08	6.60E-09
URI (ΔCDF)	-1.70E-08	-1.70E-08	-1.70E-08	-1.70E-08	-1.70E-08	-1.70E-08	-1.70E-08	-1.69E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-2.08E-08	-2.06E-08	-1.85E-08	-1.88E-08	-1.88E-08	-1.23E-08	-5.00E-09	-1.00E-08

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10
UAI (Δ CDF)	-2.80E-08	-3.70E-08	-3.00E-08	-3.20E-08	-9.00E-09	-9.00E-09	-1.30E-08	-1.35E-08
URI (Δ CDF)	-1.30E-07	-1.30E-07	-1.30E-07	-1.30E-07	-1.30E-07	-1.30E-07	-1.30E-07	-1.29E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.58E-07	-1.67E-07	-1.60E-07	-1.62E-07	-1.39E-07	-1.39E-07	-1.43E-07	-1.40E-07

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10
UAI (Δ CDF)	-2.20E-08	-2.20E-08	-2.20E-08	8.90E-09	8.90E-09	8.90E-09	8.10E-09	7.87E-09
URI (Δ CDF)	-1.20E-07	-1.30E-07	-1.50E-07	-1.40E-07	-1.40E-07	-1.40E-07	-1.20E-07	-1.07E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.42E-07	-1.52E-07	-1.72E-07	-1.31E-07	-1.31E-07	-1.31E-07	-1.12E-07	-9.90E-08

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10
UAI (Δ CDF)	2.20E-07	1.80E-07	1.30E-07	4.10E-07	6.70E-07	8.60E-07	7.40E-07	1.03E-06
URI (Δ CDF)	-1.00E-07	-5.00E-07	-5.10E-07	-5.10E-07	-4.70E-07	-4.70E-07	-4.80E-07	-4.78E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	1.20E-07	-3.20E-07	-3.80E-07	-1.00E-07	2.00E-07	3.90E-07	2.60E-07	5.50E-07

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	4/08	5/08	6/08	7/08	8/08	9/08	10/08	11/08	12/08	1/09	2/09	3/09
Maximum activity	0.000220	0.000230	0.000230	0.000280	0.000240	0.000240	N/A	0.000120	0.000130	0.000140	0.000015	0.000160
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0	0	0	0	N/A	0	0	0	0	0

Reactor Coolant System Activity	4/09	5/09	6/09	7/09	8/09	9/09	10/09	11/09	12/09	1/10	2/10	3/10
Maximum activity	0.000160	0.000160	0.000180	0.000170	0.000180	0.000180	0.000180	0.000190	0.000230	0.000200	0.000200	0.000239
Technical specification limit	1.0	1.0	1.0	1.0	1.0	0.5	0.5	0.5	0.5	0.5	0.5	0.5
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Licensee Comments: none

Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	4/08	5/08	6/08	7/08	8/08	9/08	10/08	11/08	12/08	1/09	2/09	3/09
Maximum leakage	0	0	0	0.501	0.736	0.206	0	0	0.201	0.042	0.238	0.264
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0	0	0	5.0	7.4	2.1	0	0	2.0	0.4	2.4	2.6
Reactor Coolant System Leakage	4/09	5/09	6/09	7/09	8/09	9/09	10/09	11/09	12/09	1/10	2/10	3/10
Maximum leakage	0.025	0	0	0.063	0	0.008	0.008	0	0	0.024	0.021	0.025
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.3	0	0	0.6	0	0.1	0.1	0	0	0.2	0.2	0.3

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10
Successful opportunities	51.0	41.0	16.0	99.0	43.0	9.0	20.0	48.0
Total opportunities	52.0	44.0	18.0	99.0	44.0	9.0	20.0	50.0
Indicator value	96.1%	95.7%	95.3%	95.8%	95.9%	96.5%	96.7%	97.3%

Licensee Comments: none

ERO Drill Participation



Thresholds: White < 80.0% Yellow < 60.0%


Notes

ERO Drill Participation	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10
Participating Key personnel	154.0	160.0	158.0	160.0	175.0	162.0	159.0	144.0
Total Key personnel	158.0	163.0	159.0	160.0	175.0	164.0	165.0	148.0
Indicator value	97.5%	98.2%	99.4%	100.0%	100.0%	98.8%	96.4%	97.3%

Licensee Comments:

4Q/09: Total Key Personnel count was revised due to two individuals not being added to participation index when they were added to the roster.

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10
Successful siren-tests	1466	1515	1517	1401	1520	1636	1517	1510
Total sirens-tests	1521	1521	1521	1404	1521	1638	1521	1521
Indicator value	98.8%	98.8%	98.8%	98.9%	99.8%	99.8%	99.8%	99.7%

Licensee Comments: none

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	1
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	1

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	2Q/08	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

[Security](#) information not publicly available.