


Fort Calhoun

2Q/2010 Performance Indicators

Licensee's General Comments: The error in normalization factors was discovered during an audit. The change does not result in the station crossing any thresholds.

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10
Unplanned scrams	0	0	0	0	0	0	0	0
Critical hours	2208.0	2209.0	2159.0	2184.0	2208.0	1071.8	2159.0	2105.6
Indicator value	1.0	1.0	0	0	0	0	0	0

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10
Unplanned power changes	1.0	0	0	0	0	1.0	0	1.0
Critical hours	2208.0	2209.0	2159.0	2184.0	2208.0	1071.8	2159.0	2105.6
Indicator value	2.9	2.9	1.9	0.8	0	0.9	0.9	1.9

Licensee Comments: none

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	1.0	1.0	0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

Safety System Functional Failures (PWR)




Thresholds: White > 5.0

Notes

Safety System Functional Failures (PWR)	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10
Safety System Functional Failures	0	0	1	0	0	0	0	0
Indicator value	0	0	1	1	1	1	0	0

Licensee Comments: none

Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10
UAI (ΔCDF)	7.40E-07	4.40E-07	4.80E-07	2.30E-07	3.50E-07	4.90E-07	3.69E-07	5.46E-07
URI (ΔCDF)	-8.00E-08	-5.10E-08	-3.80E-08	-6.40E-08	-1.00E-07	-1.10E-07	-1.05E-06	-1.18E-06
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	6.60E-07	3.89E-07	4.42E-07	1.66E-07	2.50E-07	3.80E-07	6.80E-07	6.30E-07

Licensee Comments: none

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10
UAI (Δ CDF)	8.00E-08	1.70E-08	-2.70E-08	-5.20E-08	-7.10E-08	-6.50E-08	-6.19E-08	-8.98E-08
URI (Δ CDF)	-7.10E-08	-5.10E-08	-5.30E-08	-5.30E-08	-5.30E-08	-7.10E-08	-7.23E-08	-8.21E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	9.00E-09	-3.40E-08	-8.00E-08	-1.05E-07	-1.24E-07	-1.36E-07	-1.30E-07	-1.70E-07

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10
UAI (Δ CDF)	-3.10E-08	-4.20E-08	-1.90E-08	3.30E-09	-8.40E-09	-1.90E-08	1.04E-08	4.54E-09
URI (Δ CDF)	-3.30E-07	-2.40E-07	2.60E-08	3.00E-07	3.00E-07	3.00E-07	5.62E-07	6.54E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-3.61E-07	-2.82E-07	7.00E-09	3.03E-07	2.92E-07	2.81E-07	5.70E-07	6.60E-07

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10
UAI (Δ CDF)	-1.60E-08	-6.40E-08	-5.10E-08	-6.80E-08	-7.70E-08	-7.80E-08	-7.77E-08	-8.67E-08
URI (Δ CDF)	4.20E-07	4.80E-07	4.80E-07	4.80E-07	4.90E-07	-5.00E-08	-5.08E-08	-6.53E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	4.04E-07	4.16E-07	4.29E-07	4.12E-07	4.13E-07	-1.28E-07	-1.30E-07	-1.50E-07

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10
UAI (Δ CDF)	5.60E-08	-2.40E-07	-2.30E-07	-2.40E-07	-2.60E-07	-2.40E-07	-2.84E-07	-3.22E-07
URI (Δ CDF)	1.20E-07	8.70E-08	8.70E-08	8.70E-08	7.20E-08	5.10E-08	4.07E-09	4.58E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	1.76E-07	-1.53E-07	-1.43E-07	-1.53E-07	-1.88E-07	-1.89E-07	-2.80E-07	-3.20E-07

Licensee Comments: none

Reactor Coolant System Activity




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Activity	7/08	8/08	9/08	10/08	11/08	12/08	1/09	2/09	3/09	4/09	5/09	6/09
Maximum activity	0.003640	0.003600	0.003600	0.003820	0.004060	0.004260	0.004360	0.004170	0.004110	0.004320	0.004500	0.004350
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.5	0.4
Reactor Coolant System Activity	7/09	8/09	9/09	10/09	11/09	12/09	1/10	2/10	3/10	4/10	5/10	6/10
Maximum activity	0.004590	0.004620	0.004470	0.004690	0.000973	0.001130	0.001530	0.001590	0.001640	0.001710	0.001760	0.002170
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0.5	0.5	0.4	0.5	0.1	0.1	0.2	0.2	0.2	0.2	0.2	0.2

Licensee Comments: none

Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	7/08	8/08	9/08	10/08	11/08	12/08	1/09	2/09	3/09	4/09	5/09	6/09
Maximum leakage	0.104	0.169	0.122	0.105	0.092	0.183	0.096	0.073	0.088	0.105	0.100	0.119
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	1.0	1.7	1.2	1.1	0.9	1.8	1.0	0.7	0.9	1.1	1.0	1.2
Reactor Coolant System Leakage	7/09	8/09	9/09	10/09	11/09	12/09	1/10	2/10	3/10	4/10	5/10	6/10
Maximum leakage	0.126	0.112	0.123	0.307	0.307	0.496	0.380	0.224	0.207	0.231	0.269	0.273
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	1.3	1.1	1.2	3.1	3.1	5.0	3.8	2.2	2.1	2.3	2.7	2.7

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10
Successful opportunities	68.0	56.0	58.0	42.0	39.0	4.0	23.0	57.0
Total opportunities	70.0	56.0	58.0	42.0	41.0	4.0	25.0	60.0
Indicator value	96.6%	97.2%	97.7%	98.6%	98.5%	98.7%	98.1%	97.5%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10
Participating Key personnel	104.0	108.0	110.0	110.0	116.0	117.0	116.0	116.0
Total Key personnel	106.0	108.0	110.0	111.0	117.0	118.0	118.0	117.0
Indicator value	98.1%	100.0%	100.0%	99.1%	99.1%	99.2%	98.3%	99.1%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10
Successful siren-tests	804	804	705	807	805	808	703	803
Total sirens-tests	808	808	707	808	808	808	707	808
Indicator value	99.6%	99.6%	99.6%	99.6%	99.7%	99.8%	99.7%	99.6%

Licensee Comments: none

Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10
High radiation area occurrences	0	0	0	0	0	1	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	1	1	1

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	3Q/08	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

[Security](#) information not publicly available.