


La Salle 1

3Q/2010 Performance Indicators

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10
Unplanned scrams	0	0	1.0	0	0	0	0	0
Critical hours	2198.5	2159.0	2142.3	2146.0	2209.0	1550.2	2184.0	2208.0
Indicator value	0	0	0.8	0.8	0.8	0.9	0	0

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs



Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10
Unplanned power changes	0	0	0	0	0	0	0	1.0
Critical hours	2198.5	2159.0	2142.3	2146.0	2209.0	1550.2	2184.0	2208.0
Indicator value	0	0	0	0	0	0	0	0.9

Licensee Comments:

3Q/10: An internal review identified that LaSalle inadvertently reported a Unit 1 downpower that occurred in January 2010 as an unplanned power change per 7000 critical hours. More than 72 hours elapsed between the time of discovery of the condition and a change in power. This discrepancy has been entered into the corrective action program, and the number of unplanned power changes per 7000 critical hours on Unit 1 for January 2010 has been changed from 1 to 0. The indicator color was not impacted, and remains GREEN.

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

Safety System Functional Failures (BWR)




Thresholds: White > 6.0

Notes

Safety System Functional Failures (BWR)	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10
Safety System Functional Failures	0	0	0	1	0	0	0	0
Indicator value	0	0	0	1	1	1	1	0

Licensee Comments: none

Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10
UAI (Δ CDF)	-3.10E-09	-3.20E-09	-3.00E-09	-3.00E-09	-3.00E-09	-2.18E-09	-2.18E-09	-3.99E-09
URI (Δ CDF)	1.00E-07	1.00E-07	1.20E-07	1.20E-07	2.90E-08	2.90E-08	2.89E-08	-4.81E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	9.69E-08	9.68E-08	1.17E-07	1.17E-07	2.60E-08	2.70E-08	2.70E-08	-8.80E-09

Licensee Comments: none

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10
UAI (Δ CDF)	-6.40E-10	-7.00E-10	-6.90E-10	-6.90E-10	-6.90E-10	2.01E-09	2.01E-09	2.01E-09
URI (Δ CDF)	-3.90E-09	-2.20E-09	-2.80E-09	-3.30E-09	-3.40E-09	8.12E-08	8.12E-08	8.12E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-4.54E-09	-2.90E-09	-3.49E-09	-3.99E-09	-4.09E-09	8.30E-08	8.30E-08	8.30E-08

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10
UAI (Δ CDF)	-5.40E-09	-5.40E-09	-5.40E-09	-4.50E-09	-4.50E-09	-2.39E-09	-2.39E-09	-1.40E-09
URI (Δ CDF)	-7.70E-09	-6.60E-09	-6.60E-09	-5.60E-11	-1.30E-10	-1.95E-10	-2.00E-10	-2.03E-10
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.31E-08	-1.20E-08	-1.20E-08	-4.56E-09	-4.63E-09	-2.60E-09	-2.60E-09	-1.60E-09

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10
UAI (Δ CDF)	-5.80E-08	-5.80E-08	-5.80E-08	-5.80E-08	-5.80E-08	-4.99E-08	-4.99E-08	-4.99E-08
URI (Δ CDF)	-8.60E-08	-7.90E-08	-8.00E-08	-8.20E-08	-8.30E-08	-8.44E-08	-8.44E-08	-8.44E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.44E-07	-1.37E-07	-1.38E-07	-1.40E-07	-1.41E-07	-1.30E-07	-1.30E-07	-1.30E-07

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10
UAI (Δ CDF)	6.20E-08	6.40E-08	4.60E-08	4.70E-08	4.70E-08	3.40E-08	5.71E-08	5.50E-08
URI (Δ CDF)	-1.10E-07	-1.10E-07	-1.10E-07	-1.10E-07	-1.10E-07	-1.04E-07	-1.04E-07	-1.04E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-4.80E-08	-4.60E-08	-6.40E-08	-6.30E-08	-6.30E-08	-7.00E-08	-4.70E-08	-4.90E-08

Licensee Comments: none

Reactor Coolant System Activity




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Activity	10/08	11/08	12/08	1/09	2/09	3/09	4/09	5/09	6/09	7/09	8/09	9/09
Maximum activity	0.000214	0.000219	0.000231	0.000218	0.000259	0.000213	0.000199	0.000200	0.001510	0.000446	0.000257	0.000426
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.8	0.2	0.1	0.2
Reactor Coolant System Activity	10/09	11/09	12/09	1/10	2/10	3/10	4/10	5/10	6/10	7/10	8/10	9/10
Maximum activity	0.000451	0.000584	0.000669	0.000934	0.000745	0.000236	0.000244	0.000253	0.000276	0.000279	0.000279	0.000275
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0.2	0.3	0.3	0.5	0.4	0.1	0.1	0.1	0.1	0.1	0.1	0.1

Licensee Comments: none

Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	10/08	11/08	12/08	1/09	2/09	3/09	4/09	5/09	6/09	7/09	8/09	9/09
Maximum leakage	3.700	3.100	2.900	2.900	3.000	2.900	3.000	3.200	4.500	6.400	2.800	2.900
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	14.8	12.4	11.6	11.6	12.0	11.6	12.0	12.8	18.0	25.6	11.2	11.6
Reactor Coolant System Leakage	10/09	11/09	12/09	1/10	2/10	3/10	4/10	5/10	6/10	7/10	8/10	9/10
Maximum leakage	2.900	3.000	2.900	3.000	2.900	3.300	3.300	3.200	3.800	3.600	3.300	3.400
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	11.6	12.0	11.6	12.0	11.6	13.2	13.2	12.8	15.2	14.4	13.2	13.6

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10
Successful opportunities	50.0	20.0	44.0	48.0	44.0	20.0	55.0	16.0
Total opportunities	50.0	20.0	44.0	48.0	46.0	20.0	56.0	16.0
Indicator value	98.1%	98.1%	98.1%	98.7%	98.0%	98.4%	99.1%	99.0%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10
Participating Key personnel	68.0	65.0	66.0	68.0	68.0	70.0	77.0	72.0
Total Key personnel	68.0	65.0	66.0	68.0	68.0	70.0	77.0	74.0
Indicator value	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	97.3%

Licensee Comments: none

Alert & Notification System



Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10
Successful siren-tests	3169	3144	3199	3246	3198	2139	2167	2205
Total sirens-tests	3200	3150	3200	3250	3200	2142	2176	2210
Indicator value	99.6%	99.6%	99.6%	99.7%	99.9%	99.9%	99.8%	99.8%

Licensee Comments: none

Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

[Security](#) information not publicly available.