


Vogle 1

3Q/2010 Performance Indicators

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10
Unplanned scrams	0	0	0	0	2.0	0	0	0
Critical hours	2209.0	2159.0	2184.0	1950.0	1736.2	2159.0	2184.0	2208.0
Indicator value	0	0	0	0	1.7	1.7	1.7	1.7

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs



Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10
Unplanned power changes	0	0	0	0	0	0	0	0
Critical hours	2209.0	2159.0	2184.0	1950.0	1736.2	2159.0	2184.0	2208.0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

Safety System Functional Failures (PWR)




Thresholds: White > 5.0

Notes

Safety System Functional Failures (PWR)	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10
Safety System Functional Failures	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


Notes

Mitigating Systems Performance Index, Emergency AC Power System	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10
UAI (Δ CDF)	8.80E-08	2.30E-08	-1.60E-08	-2.40E-08	-1.22E-07	-1.75E-07	-1.75E-07	-1.73E-07
URI (Δ CDF)	2.50E-07	1.50E-07	1.50E-07	1.60E-07	2.55E-07	-2.64E-07	-2.48E-07	-2.54E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	3.38E-07	1.73E-07	1.34E-07	1.36E-07	1.30E-07	-4.40E-07	-4.20E-07	-4.30E-07

Licensee Comments:

3Q/10: Risk Cap Invoked.

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10
UAI (Δ CDF)	3.10E-09	3.00E-09	-1.30E-09	-9.10E-10	-2.20E-09	-1.65E-09	-1.83E-09	-3.40E-09
URI (Δ CDF)	-9.00E-09	-9.10E-09	-9.20E-09	-9.30E-09	-9.30E-09	-9.41E-09	-9.54E-09	-9.66E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-5.90E-09	-6.10E-09	-1.05E-08	-1.02E-08	-1.15E-08	-1.10E-08	-1.10E-08	-1.30E-08

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


Notes

Mitigating Systems Performance Index, Heat Removal System	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10
UAI (Δ CDF)	-1.50E-08	-1.60E-07	-5.90E-08	-5.50E-08	-4.90E-08	2.41E-08	-3.46E-09	-6.57E-09
URI (Δ CDF)	1.50E-07	-7.70E-07	1.60E-07	1.60E-07	1.40E-07	-2.77E-07	-2.77E-07	-2.77E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	1.35E-07	-9.30E-07	1.01E-07	1.05E-07	9.10E-08	-2.50E-07	-2.80E-07	-2.80E-07

Licensee Comments:

3Q/10: Risk Cap Invoked.

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10
UAI (Δ CDF)	-5.90E-09	-6.00E-09	-6.70E-09	-9.90E-09	-9.60E-09	-9.57E-09	-9.57E-09	-9.57E-09
URI (Δ CDF)	-3.30E-08	-3.30E-08	-3.20E-08	-3.20E-08	-3.10E-08	-3.07E-08	-3.07E-08	-3.07E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-3.89E-08	-3.90E-08	-3.87E-08	-4.19E-08	-4.06E-08	-4.00E-08	-4.00E-08	-4.00E-08

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes


Mitigating Systems Performance Index, Cooling Water Systems	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10
UAI (ΔCDF)	3.70E-08	3.70E-08	3.70E-08	3.70E-08	3.60E-08	2.78E-08	2.78E-08	2.78E-08
URI (ΔCDF)	5.60E-07	5.60E-07	5.40E-07	5.40E-07	4.70E-07	-1.25E-07	-1.25E-07	-1.25E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	5.97E-07	5.97E-07	5.77E-07	5.77E-07	5.06E-07	-9.70E-08	-9.70E-08	-9.70E-08

Licensee Comments:

2Q/10: In July 2010 a thermal analysis was performed for the motor thrust bearing for a Nuclear Service Cooling Water pump by the Kingsbury Corporation. This analysis was necessary due to the motor cooler discharge line freezing on January 7th and 11th 2010. The purpose of this analysis was to determine whether or not the pump motor would meet its Mission Time with no motor cooling water. The conclusion was that the thrust and upper guide bearings would be able to continually function without cooling water under the conditions noted during the initial event and therefore are not MSPI failures.

1Q/10: In July 2010 a thermal analysis was performed for the motor thrust bearing for a Nuclear Service Cooling Water pump by the Kingsbury Corporation. This analysis was necessary due to the motor cooler discharge line freezing on January 7th and 11th 2010. The purpose of this analysis was to determine whether or not the pump motor would meet its Mission Time with no motor cooling water. The conclusion was that the thrust and upper guide bearings would be able to continually function without cooling water under the conditions noted during the initial event and therefore are not MSPI failures.

Reactor Coolant System Activity




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Activity	10/08	11/08	12/08	1/09	2/09	3/09	4/09	5/09	6/09	7/09	8/09	9/09
Maximum activity	0.000100	0.000183	0.000175	0.000200	0.002520	0.000948	0.001279	0.000539	0.000204	0.000202	0.000165	0.000195
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0	0	0.3	0.1	0.1	0.1	0	0	0	0
Reactor Coolant System Activity	10/09	11/09	12/09	1/10	2/10	3/10	4/10	5/10	6/10	7/10	8/10	9/10
Maximum activity	0.000066	0.000086	0.000080	0.000090	0.000090	0.000099	0.000101	0.000115	0.000110	0.000110	0.000111	0.000117
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Licensee Comments: none

Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	10/08	11/08	12/08	1/09	2/09	3/09	4/09	5/09	6/09	7/09	8/09	9/09
Maximum leakage	0.132	0.147	0.156	0.142	0.131	0.144	0.143	0.135	0.126	0.123	0.165	0.135
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	1.3	1.5	1.6	1.4	1.3	1.4	1.4	1.4	1.3	1.2	1.7	1.4
Reactor Coolant System Leakage	10/09	11/09	12/09	1/10	2/10	3/10	4/10	5/10	6/10	7/10	8/10	9/10
Maximum leakage	0.104	0.072	0.101	0.105	0.094	0.131	0.101	0.094	0.073	0.137	0.149	0.125
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	1.0	0.7	1.0	1.1	0.9	1.3	1.0	0.9	0.7	1.4	1.5	1.3

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10
Successful opportunities	28.0	64.0	91.0	81.0	51.0	53.0	51.0	35.0
Total opportunities	36.0	66.0	94.0	83.0	54.0	54.0	53.0	35.0
Indicator value	92.0%	93.8%	94.0%	94.4%	94.2%	94.7%	95.5%	95.6%

License Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10
Participating Key personnel	123.0	127.0	137.0	139.0	135.0	128.0	128.0	126.0
Total Key personnel	142.0	133.0	137.0	139.0	136.0	129.0	128.0	130.0
Indicator value	86.6%	95.5%	100.0%	100.0%	99.3%	99.2%	100.0%	96.9%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10
Successful siren-tests	610	611	611	607	611	611	610	608
Total sirens-tests	611	611	611	611	611	611	611	611
Indicator value	99.9%	99.9%	99.9%	99.8%	99.8%	99.8%	99.8%	99.8%

Licensee Comments: none

Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	1	1	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	4Q/08	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

[Security](#) information not publicly available.