


Calvert Cliffs 2

4Q/2010 Performance Indicators

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
Unplanned scrams	0	0	0	0	1.0	0	0	0
Critical hours	1657.0	2184.0	2208.0	2209.0	1941.7	2184.0	2208.0	2209.0
Indicator value	0	0	0	0	0.8	0.8	0.8	0.8

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
Unplanned power changes	0	0	0	0	0	1.0	0	0
Critical hours	1657.0	2184.0	2208.0	2209.0	1941.7	2184.0	2208.0	2209.0
Indicator value	0	0	0	0	0	0.8	0.8	0.8

Licensee Comments: none

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
Scrams with complications	0	0	0	0	1.0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	1.0	1.0	1.0	1.0

Licensee Comments: none

Safety System Functional Failures (PWR)




Thresholds: White > 5.0

Notes

Safety System Functional Failures (PWR)	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
Safety System Functional Failures	0	0	0	0	0	1	0	0
Indicator value	0	0	0	0	0	1	1	1

Licensee Comments: none

Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
UAI (Δ CDF)	2.20E-08	5.50E-08	5.60E-08	7.00E-08	1.00E-07	9.77E-08	1.11E-07	9.08E-08
URI (Δ CDF)	-1.20E-07	-7.40E-08	-7.40E-08	-7.40E-08	-1.46E-08	-1.40E-08	-1.45E-08	-1.29E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-9.80E-08	-1.90E-08	-1.80E-08	-4.00E-09	8.60E-08	8.40E-08	9.60E-08	7.80E-08

Licensee Comments: none

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
UAI (Δ CDF)	6.00E-08	4.60E-08	4.20E-08	4.10E-08	6.40E-08	6.19E-08	8.72E-08	8.65E-08
URI (Δ CDF)	-9.40E-08	-7.50E-08	-7.40E-08	-7.10E-08	-6.40E-08	-6.31E-08	-6.18E-08	-6.16E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-3.40E-08	-2.90E-08	-3.20E-08	-3.00E-08	5.00E-12	-1.30E-09	2.50E-08	2.50E-08

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
UAI (Δ CDF)	4.70E-08	4.90E-09	3.50E-09	3.10E-09	1.31E-08	1.24E-08	-6.25E-09	-6.61E-09
URI (Δ CDF)	8.40E-07	1.60E-07	1.60E-07	1.60E-07	2.47E-08	2.99E-08	3.35E-08	3.56E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	8.87E-07	1.65E-07	1.64E-07	1.63E-07	3.80E-08	4.20E-08	2.70E-08	2.90E-08

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
UAI (ΔCDF)	1.20E-07	2.40E-07	2.40E-07	2.30E-07	2.25E-07	2.23E-07	-1.86E-08	2.06E-08
URI (ΔCDF)	8.30E-09	1.20E-08	1.20E-08	1.20E-08	1.34E-08	1.39E-08	4.19E-09	4.10E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	1.28E-07	2.52E-07	2.52E-07	2.42E-07	2.40E-07	2.40E-07	-1.40E-08	2.50E-08

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
UAI (Δ CDF)	3.10E-08	4.20E-08	4.20E-08	5.40E-08	5.72E-08	5.85E-08	6.57E-08	9.21E-08
URI (Δ CDF)	-3.40E-08	-1.80E-08	-1.80E-08	-1.80E-08	-1.80E-08	-1.80E-08	-1.79E-08	-1.77E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-3.00E-09	2.40E-08	2.40E-08	3.60E-08	3.90E-08	4.00E-08	4.80E-08	7.40E-08

Licensee Comments: none

Reactor Coolant System Activity




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Activity	1/09	2/09	3/09	4/09	5/09	6/09	7/09	8/09	9/09	10/09	11/09	12/09
Maximum activity	0.012200	0.010200	0.001360	0.002030	0.002060	0.002060	0.002430	0.002440	0.002560	0.002540	0.002950	0.003020
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	1.2	1.0	0.1	0.2	0.2	0.2	0.2	0.2	0.3	0.3	0.3	0.3
Reactor Coolant System Activity	1/10	2/10	3/10	4/10	5/10	6/10	7/10	8/10	9/10	10/10	11/10	12/10
Maximum activity	0.002880	0.003080	0.002190	0.003500	0.003240	0.003420	0.003610	0.003970	0.004170	0.003950	0.003620	0.003710
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0.3	0.3	0.2	0.4	0.3	0.3	0.4	0.4	0.4	0.4	0.4	0.4

License Comments: none

Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	1/09	2/09	3/09	4/09	5/09	6/09	7/09	8/09	9/09	10/09	11/09	12/09
Maximum leakage	0.160	0.100	0.060	0.070	0.080	0.090	0.070	0.130	0.090	0.100	0.100	0.080
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	1.6	1.0	0.6	0.7	0.8	0.9	0.7	1.3	0.9	1.0	1.0	0.8
Reactor Coolant System Leakage	1/10	2/10	3/10	4/10	5/10	6/10	7/10	8/10	9/10	10/10	11/10	12/10
Maximum leakage	0.110	0.080	0.110	0.134	0.190	0.270	0.210	0.130	0.130	0.110	0.110	0.130
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	1.1	0.8	1.1	1.3	1.9	2.7	2.1	1.3	1.3	1.1	1.1	1.3

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
Successful opportunities	10.0	30.0	43.0	63.0	13.0	23.0	76.0	53.0
Total opportunities	10.0	32.0	46.0	64.0	13.0	23.0	78.0	54.0
Indicator value	95.6%	95.4%	94.5%	94.7%	95.2%	95.5%	95.4%	97.2%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
Participating Key personnel	88.0	98.0	101.0	95.0	98.0	87.0	86.0	88.0
Total Key personnel	88.0	98.0	101.0	95.0	98.0	87.0	86.0	88.0
Indicator value	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
Successful siren-tests	932	948	947	942	948	948	948	940
Total sirens-tests	949	949	949	949	949	949	949	949
Indicator value	98.5%	98.6%	98.6%	99.3%	99.7%	99.7%	99.7%	99.7%

Licensee Comments: none

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

[Security](#) information not publicly available.