


# Diablo Canyon 2

## 4Q/2010 Performance Indicators

Licensee's General Comments: none

### Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

### Notes

Unplanned Scrams per 7000 Critical Hrs	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
Unplanned scrams	0	1.0	0	0	0	0	0	0
Critical hours	2159.0	2175.9	1956.3	1317.5	2159.0	2184.0	2208.0	2209.0
Indicator value	1.8	2.6	1.7	0.9	0.9	0	0	0

Licensee Comments: none

## Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

### Notes

Unplanned Power Changes per 7000 Critical Hrs	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
Unplanned power changes	0	1.0	1.0	0	0	0	0	0
Critical hours	2159.0	2175.9	1956.3	1317.5	2159.0	2184.0	2208.0	2209.0
Indicator value	0	0.9	1.7	1.8	1.8	0.9	0	0

Licensee Comments: none

## Unplanned Scrams with Complications



Thresholds: White > 1.0


### Notes

Unplanned Scrams with Complications	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

---

## Safety System Functional Failures (PWR)




Thresholds: White > 5.0

### Notes

Safety System Functional Failures (PWR)	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
Safety System Functional Failures	0	0	0	1	1	0	2	0
Indicator value	1	1	0	1	2	2	4	3

Licensee Comments: none

# Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, Emergency AC Power System	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
UAI ( $\Delta$ CDF)	-3.60E-09	-6.20E-09	-3.00E-09	-2.20E-10	-3.74E-09	-7.01E-09	-5.16E-09	-7.01E-09
URI ( $\Delta$ CDF)	2.20E-08	2.20E-08	2.20E-08	2.20E-08	2.20E-08	-3.06E-07	-3.06E-07	-4.71E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	1.84E-08	1.58E-08	1.90E-08	2.18E-08	1.80E-08	-3.10E-07	-3.10E-07	-4.80E-07

Licensee Comments: none

# Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, High Pressure Injection System	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
UAI ( $\Delta$ CDF)	-3.40E-09	-3.40E-09	-3.40E-09	-3.40E-09	-3.36E-09	-3.36E-09	-3.20E-09	-3.36E-09
URI ( $\Delta$ CDF)	-1.40E-09	-1.40E-09	-1.40E-09	3.40E-08	3.35E-08	3.35E-08	3.35E-08	3.35E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-4.80E-09	-4.80E-09	-4.80E-09	3.06E-08	3.00E-08	3.00E-08	3.00E-08	3.00E-08

Licensee Comments: none

# Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, Heat Removal System	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
UAI ( $\Delta$ CDF)	6.70E-09	3.70E-09	1.40E-08	2.80E-09	-7.35E-10	-7.35E-10	-7.35E-10	-7.35E-10
URI ( $\Delta$ CDF)	-8.90E-08	-8.90E-08	-8.90E-08	-8.90E-08	-8.86E-08	-8.86E-08	-8.86E-08	-8.86E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-8.23E-08	-8.53E-08	-7.50E-08	-8.62E-08	-8.90E-08	-8.90E-08	-8.90E-08	-8.90E-08

Licensee Comments: none

# Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, Residual Heat Removal System	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
UAI ( $\Delta$ CDF)	-5.90E-09	-5.90E-09	-5.90E-09	-5.90E-09	5.48E-10	6.33E-10	-6.71E-10	1.63E-09
URI ( $\Delta$ CDF)	-2.50E-08	-2.50E-08	-2.50E-08	-2.50E-08	-2.53E-08	-2.53E-08	-2.53E-08	-2.53E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-3.09E-08	-3.09E-08	-3.09E-08	-3.09E-08	-2.50E-08	-2.50E-08	-2.60E-08	-2.40E-08

Licensee Comments: none



# Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, Cooling Water Systems	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
UAI ( $\Delta$ CDF)	-1.60E-08	-1.70E-08	-2.80E-08	-1.90E-08	-2.65E-08	-2.12E-08	-1.55E-08	-1.75E-08
URI ( $\Delta$ CDF)	-2.00E-08	-2.00E-08	-2.00E-08	-2.00E-08	-1.98E-08	-1.98E-08	-1.98E-08	-1.98E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-3.60E-08	-3.70E-08	-4.80E-08	-3.90E-08	-4.60E-08	-4.10E-08	-3.50E-08	-3.70E-08

Licensee Comments: none

# Reactor Coolant System Activity




Thresholds: White > 50.0 Yellow > 100.0

## Notes

Reactor Coolant System Activity	1/09	2/09	3/09	4/09	5/09	6/09	7/09	8/09	9/09	10/09	11/09	12/09
Maximum activity	0.001650	0.001570	0.001460	0.001630	0.001430	0.001480	0.001650	0.001330	0.001230	0.001130	0.000309	0.000461
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0.2	0.2	0.1	0.2	0.1	0.1	0.2	0.1	0.1	0.1	0	0
Reactor Coolant System Activity	1/10	2/10	3/10	4/10	5/10	6/10	7/10	8/10	9/10	10/10	11/10	12/10
Maximum activity	0.000401	0.000480	0.000517	0.000469	0.000585	0.000535	0.000610	0.000545	0.000614	0.000558	0.000442	0.000514
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0.1	0	0.1	0.1	0.1	0.1	0.1	0.1	0	0.1

Licensee Comments: none

## Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

### Notes

<b>Reactor Coolant System Leakage</b>	<b>1/09</b>	<b>2/09</b>	<b>3/09</b>	<b>4/09</b>	<b>5/09</b>	<b>6/09</b>	<b>7/09</b>	<b>8/09</b>	<b>9/09</b>	<b>10/09</b>	<b>11/09</b>	<b>12/09</b>
Maximum leakage	0.044	0.033	0.076	0.046	0.047	0.047	0.059	0.090	0.037	0.014	0.099	0.065
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.4	0.3	0.8	0.5	0.5	0.5	0.6	0.9	0.4	0.1	1.0	0.7
<b>Reactor Coolant System Leakage</b>	<b>1/10</b>	<b>2/10</b>	<b>3/10</b>	<b>4/10</b>	<b>5/10</b>	<b>6/10</b>	<b>7/10</b>	<b>8/10</b>	<b>9/10</b>	<b>10/10</b>	<b>11/10</b>	<b>12/10</b>
Maximum leakage	0.044	0.091	0.041	0.065	0.090	0.088	0.096	0.145	0.056	0.050	0.083	0.557
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.4	0.9	0.4	0.7	0.9	0.9	1.0	1.5	0.6	0.5	0.8	5.6

Licensee Comments: none

## Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

### Notes

Drill/Exercise Performance	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
Successful opportunities	13.0	53.0	61.0	40.0	35.0	59.0	24.0	16.0
Total opportunities	14.0	55.0	62.0	41.0	37.0	60.0	24.0	17.0
Indicator value	94.3%	94.1%	95.5%	94.6%	94.7%	95.2%	96.2%	97.1%

Licensee Comments: none

## ERO Drill Participation



Thresholds: White < 80.0% Yellow < 60.0%


### Notes

ERO Drill Participation	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
Participating Key personnel	70.0	83.0	92.0	98.0	97.0	102.0	101.0	104.0
Total Key personnel	70.0	89.0	93.0	102.0	101.0	103.0	103.0	107.0
Indicator value	100.0%	93.3%	98.9%	96.1%	96.0%	99.0%	98.1%	97.2%

Licensee Comments:

3Q/10: On 11/17/10, changes were made to the September Participating Key Personnel and the Total Key Personnel values. Per DCPD notification 50361749, the change was made following identification of a brief lapse in the qualifications of three personnel. This change did not affect the color of the indicator.

# Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

## Notes

Alert & Notification System	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
Successful siren-tests	1047	916	1310	916	1048	917	1310	917
Total sirens-tests	1048	917	1310	916	1048	917	1310	917
Indicator value	99.9%	99.9%	99.9%	100.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

# Occupational Exposure Control Effectiveness



**Thresholds: White > 2.0 Yellow > 5.0**


## Notes

Occupational Exposure Control Effectiveness	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

Licensee Comments: none

---

# RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

## Notes

RETS/ODCM Radiological Effluent	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

[Security](#) information not publicly available.