


# Point Beach 2

## 4Q/2010 Performance Indicators

Licensee's General Comments: none

### Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

### Notes

Unplanned Scrams per 7000 Critical Hrs	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
Unplanned scrams	0	0	0	0	0	1.0	1.0	0
Critical hours	2159.0	2184.0	2208.0	971.4	2159.0	2153.8	2182.9	2026.7
Indicator value	0	0	0	0	0	0.9	1.9	1.6

Licensee Comments: none

## Unplanned Power Changes per 7000 Critical Hrs



Thresholds: White > 6.0

### Notes

Unplanned Power Changes per 7000 Critical Hrs	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
Unplanned power changes	0	0	0	0	0	0	0	0
Critical hours	2159.0	2184.0	2208.0	971.4	2159.0	2153.8	2182.9	2026.7
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

## Unplanned Scrams with Complications




Thresholds: White > 1.0

### Notes

Unplanned Scrams with Complications	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

## Safety System Functional Failures (PWR)




Thresholds: White > 5.0

### Notes

Safety System Functional Failures (PWR)	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
Safety System Functional Failures	0	0	0	0	0	0	0	1
Indicator value	0	0	0	0	0	0	0	1

Licensee Comments: none

# Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, Emergency AC Power System	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
UAI ( $\Delta$ CDF)	2.20E-07	1.50E-07	1.10E-07	4.20E-08	3.44E-08	-1.33E-08	7.74E-08	5.16E-08
URI ( $\Delta$ CDF)	-1.70E-07	-1.70E-07	-1.70E-07	-2.30E-07	-2.31E-07	-2.31E-07	-2.31E-07	-2.31E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	5.00E-08	-2.00E-08	-6.00E-08	-1.88E-07	-2.00E-07	-2.40E-07	-1.50E-07	-1.80E-07

Licensee Comments: none

# Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, High Pressure Injection System	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
UAI ( $\Delta$ CDF)	-1.10E-09	4.50E-09	3.80E-10	-1.40E-09	1.34E-09	2.40E-08	-2.06E-09	-1.08E-09
URI ( $\Delta$ CDF)	-1.40E-08	-1.40E-08	-1.40E-08	-1.40E-08	-1.42E-08	-1.42E-08	-1.42E-08	-1.42E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.51E-08	-9.50E-09	-1.36E-08	-1.54E-08	-1.30E-08	9.70E-09	-1.60E-08	-1.50E-08

Licensee Comments: none

# Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, Heat Removal System	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
UAI ( $\Delta$ CDF)	2.20E-07	8.40E-08	4.50E-08	7.80E-08	6.17E-08	2.30E-07	4.41E-08	-1.41E-07
URI ( $\Delta$ CDF)	-1.10E-06	-7.70E-07	-7.70E-07	-7.70E-07	-7.67E-07	-7.67E-07	-7.67E-07	-7.67E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-8.80E-07	-6.86E-07	-7.25E-07	-6.92E-07	-7.10E-07	-5.40E-07	-7.20E-07	-9.10E-07

Licensee Comments: none

# Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


## Notes

Mitigating Systems Performance Index, Residual Heat Removal System	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
UAI ( $\Delta$ CDF)	5.40E-08	4.90E-08	4.70E-08	5.50E-08	5.79E-08	6.31E-08	3.08E-08	1.12E-08
URI ( $\Delta$ CDF)	-2.90E-08	-2.90E-08	-2.90E-08	-2.90E-08	-2.90E-08	-2.90E-08	-2.90E-08	-2.90E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	2.50E-08	2.00E-08	1.80E-08	2.60E-08	2.90E-08	3.40E-08	1.80E-09	-1.80E-08

Licensee Comments: none



# Mitigating Systems Performance Index, Cooling Water Systems



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


## Notes

Mitigating Systems Performance Index, Cooling Water Systems	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
UAI ( $\Delta$ CDF)	-2.20E-07	-2.20E-07	5.80E-09	2.60E-07	3.93E-07	8.37E-07	1.23E-06	1.13E-06
URI ( $\Delta$ CDF)	-2.70E-06	-2.70E-06	-8.30E-07	-8.30E-07	-2.25E-06	-2.25E-06	-2.25E-06	-2.25E-06
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-2.92E-06	-2.92E-06	-8.24E-07	-5.70E-07	-1.90E-06	-1.40E-06	-1.00E-06	-1.10E-06

Licensee Comments:

4Q/10: Risk Cap Invoked.

# Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0

## Notes


Reactor Coolant System Activity	1/09	2/09	3/09	4/09	5/09	6/09	7/09	8/09	9/09	10/09	11/09	12/09
Maximum activity	0.000244	0.000316	0.000268	0.000276	0.000281	0.000303	0.000299	0.000308	0.000317	0.000318	N/A	0.000178
Technical specification limit	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8
Indicator value	0	0	0	0	0	0	0	0	0	0	N/A	0

Reactor Coolant System Activity	1/10	2/10	3/10	4/10	5/10	6/10	7/10	8/10	9/10	10/10	11/10	12/10
Maximum activity	0.000191	0.000193	0.000197	0.000209	0.000220	0.000213	0.000226	0.000241	0.000259	0.000252	0.000258	0.000298
Technical specification limit	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Licensee Comments: none

# Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

## Notes

Reactor Coolant System Leakage	1/09	2/09	3/09	4/09	5/09	6/09	7/09	8/09	9/09	10/09	11/09	12/09
Maximum leakage	0.020	0.040	0.040	0.030	0.030	0.050	0.030	0.030	0.040	0.090	0	0.100
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.2	0.4	0.4	0.3	0.3	0.5	0.3	0.3	0.4	0.9	0	1.0
Reactor Coolant System Leakage	1/10	2/10	3/10	4/10	5/10	6/10	7/10	8/10	9/10	10/10	11/10	12/10
Maximum leakage	0.020	0.060	0.070	0.040	0.060	0.020	0.010	0.010	0.010	0.070	0.110	0.040
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.2	0.6	0.7	0.4	0.6	0.2	0.1	0.1	0.1	0.7	1.1	0.4

Licensee Comments: none

## Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

### Notes

Drill/Exercise Performance	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
Successful opportunities	10.0	50.0	36.0	2.0	31.0	30.0	30.0	11.0
Total opportunities	11.0	51.0	36.0	2.0	31.0	30.0	30.0	12.0
Indicator value	94.8%	95.1%	96.7%	96.7%	97.4%	97.4%	98.5%	98.5%

Licensee Comments: none

# ERO Drill Participation



Thresholds: White < 80.0% Yellow < 60.0%


## Notes

ERO Drill Participation	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
Participating Key personnel	57.0	61.0	64.0	61.0	59.0	61.0	62.0	61.0
Total Key personnel	57.0	61.0	64.0	61.0	59.0	61.0	62.0	61.0
Indicator value	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

---

# Alert & Notification System



Thresholds: White < 94.0% Yellow < 90.0%

## Notes

Alert & Notification System	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
Successful siren-tests	83	84	84	84	78	84	84	83
Total sirens-tests	84	84	84	84	84	84	84	84
Indicator value	99.7%	99.7%	99.7%	99.7%	98.2%	98.2%	98.2%	97.9%

Licensee Comments: none

# Occupational Exposure Control Effectiveness



**Thresholds: White > 2.0 Yellow > 5.0**

## Notes

Occupational Exposure Control Effectiveness	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

Licensee Comments: none

---

# RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

## Notes

RETS/ODCM Radiological Effluent	1Q/09	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

[Security](#) information not publicly available.