

# Farley 1

## 1Q/2011 Performance Indicators

Licensee's General Comments: none

### Unplanned Scrams per 7000 Critical Hrs



Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0


### Notes

Unplanned Scrams per 7000 Critical Hrs	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11
Unplanned scrams	0	0	0	0	0	0	0	0
Critical hours	1373.0	2208.0	2209.0	2159.0	2184.0	2208.0	1284.8	2159.0
Indicator value	0.9	0.9	0	0	0	0	0	0

Licensee Comments: none

---

## Unplanned Power Changes per 7000 Critical Hrs



Thresholds: White > 6.0

### Notes

Unplanned Power Changes per 7000 Critical Hrs	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11
Unplanned power changes	1.0	0	1.0	0	0	2.0	0	0
Critical hours	1373.0	2208.0	2209.0	2159.0	2184.0	2208.0	1284.8	2159.0
Indicator value	1.8	0.9	1.8	1.8	0.8	2.4	1.8	1.8

Licensee Comments: none

## Unplanned Scrams with Complications



Thresholds: White > 1.0


### Notes

Unplanned Scrams with Complications	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

---

## Safety System Functional Failures (PWR)




Thresholds: White > 5.0

### Notes

Safety System Functional Failures (PWR)	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11
Safety System Functional Failures	1	0	0	0	1	0	0	0
Indicator value	2	1	1	1	1	1	1	1

Licensee Comments: none

# Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, Emergency AC Power System	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11
UAI ( $\Delta$ CDF)	8.40E-07	8.50E-07	6.50E-07	3.55E-07	3.69E-07	3.32E-07	3.27E-07	1.60E-07
URI ( $\Delta$ CDF)	2.00E-06	2.00E-06	2.00E-06	1.98E-06	1.64E-06	1.64E-06	1.64E-06	-9.40E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	2.84E-06	2.85E-06	2.65E-06	2.30E-06	2.00E-06	2.00E-06	2.00E-06	-7.80E-07

Licensee Comments: none

# Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, High Pressure Injection System	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11
UAI ( $\Delta$ CDF)	-3.80E-09	1.40E-09	5.80E-09	-7.53E-08	-5.88E-08	-4.65E-08	-3.24E-08	-4.05E-08
URI ( $\Delta$ CDF)	5.90E-08	5.90E-08	5.90E-08	5.91E-08	5.92E-08	5.93E-08	-5.17E-08	-5.17E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	5.52E-08	6.04E-08	6.48E-08	-1.60E-08	3.60E-10	1.30E-08	-8.40E-08	-9.20E-08

Licensee Comments: none

# Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, Heat Removal System	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11
UAI ( $\Delta$ CDF)	-9.10E-08	-4.20E-08	7.70E-08	-1.43E-07	-1.01E-07	-4.99E-08	-5.14E-08	-1.52E-07
URI ( $\Delta$ CDF)	-5.00E-07	-5.00E-07	-5.00E-07	-5.04E-07	-5.04E-07	-5.04E-07	-5.04E-07	-5.04E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-5.91E-07	-5.42E-07	-4.23E-07	-6.50E-07	-6.10E-07	-5.50E-07	-5.60E-07	-6.60E-07

Licensee Comments: none

# Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes


Mitigating Systems Performance Index, Residual Heat Removal System	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11
UAI ( $\Delta$ CDF)	-3.20E-08	1.10E-08	5.60E-08	-1.18E-08	-1.18E-08	-1.19E-08	-1.22E-08	-1.22E-08
URI ( $\Delta$ CDF)	4.10E-07	4.10E-07	9.10E-07	9.14E-07	9.14E-07	9.14E-07	3.11E-07	3.11E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	3.78E-07	4.21E-07	9.66E-07	9.00E-07	9.00E-07	9.00E-07	3.00E-07	3.00E-07

Licensee Comments:

1Q/11: Risk Cap Invoked.



# Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, Cooling Water Systems	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11
UAI ( $\Delta$ CDF)	2.20E-08	2.50E-08	2.50E-08	1.96E-08	3.44E-08	1.03E-07	1.03E-07	8.86E-08
URI ( $\Delta$ CDF)	6.00E-07	4.50E-07	4.50E-07	4.52E-07	4.54E-07	-8.89E-08	-9.05E-08	-9.19E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	6.22E-07	4.75E-07	4.75E-07	4.70E-07	4.90E-07	1.40E-08	1.30E-08	-3.30E-09

Licensee Comments: none

# Reactor Coolant System Activity




Thresholds: White > 50.0 Yellow > 100.0

## Notes

Reactor Coolant System Activity	4/09	5/09	6/09	7/09	8/09	9/09	10/09	11/09	12/09	1/10	2/10	3/10
Maximum activity	0.000366	0.000692	0.000856	0.000876	0.000909	0.000975	0.000971	0.001050	0.001140	0.001050	0.001060	0.001070
Technical specification limit	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
Indicator value	0.1	0.1	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Reactor Coolant System Activity	4/10	5/10	6/10	7/10	8/10	9/10	10/10	11/10	12/10	1/11	2/11	3/11
Maximum activity	0.001150	0.001190	0.001290	0.001260	0.001300	0.001400	0.001110	0.000516	0.000664	0.000721	0.000749	0.000782
Technical specification limit	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
Indicator value	0.2	0.2	0.3	0.3	0.3	0.3	0.2	0.1	0.1	0.1	0.1	0.2

Licensee Comments: none

## Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

### Notes

Reactor Coolant System Leakage	4/09	5/09	6/09	7/09	8/09	9/09	10/09	11/09	12/09	1/10	2/10	3/10
Maximum leakage	0.007	0.185	0.020	0.016	0.020	0.038	0.013	0.016	0.039	0.019	0.017	0.088
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.1	1.9	0.2	0.2	0.2	0.4	0.1	0.2	0.4	0.2	0.2	0.9
Reactor Coolant System Leakage	4/10	5/10	6/10	7/10	8/10	9/10	10/10	11/10	12/10	1/11	2/11	3/11
Maximum leakage	0.017	0.015	0.019	0.017	0.030	0.015	0.010	0.093	0.049	0.054	0.051	0.076
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.2	0.2	0.2	0.2	0.3	0.2	0.1	0.9	0.5	0.5	0.5	0.8

Licensee Comments: none

## Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

### Notes

Drill/Exercise Performance	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11
Successful opportunities	18.0	15.0	30.0	21.0	20.0	14.0	11.0	43.0
Total opportunities	18.0	15.0	31.0	22.0	23.0	15.0	11.0	46.0
Indicator value	94.4%	94.5%	94.4%	95.5%	94.4%	94.0%	93.9%	95.0%

Licensee Comments: none

## ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

### Notes

ERO Drill Participation	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11
Participating Key personnel	110.0	111.0	110.0	102.0	105.0	113.0	114.0	124.0
Total Key personnel	112.0	113.0	110.0	104.0	105.0	113.0	114.0	124.0
Indicator value	98.2%	98.2%	100.0%	98.1%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

# Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

## Notes

Alert & Notification System	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11
Successful siren-tests	43	45	40	42	38	42	42	39
Total sirens-tests	45	45	42	42	39	42	42	39
Indicator value	96.1%	96.7%	96.6%	97.7%	98.2%	98.2%	99.4%	99.4%

Licensee Comments: none

# Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0

## Notes

Occupational Exposure Control Effectiveness	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

Licensee Comments: none

# RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

## Notes

RETS/ODCM Radiological Effluent	2Q/09	3Q/09	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

[Security](#) information not publicly available.