

# Dresden 2

## 3Q/2011 Performance Indicators

Licensee's General Comments: none

### Unplanned Scrams per 7000 Critical Hrs



Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0


### Notes

Unplanned Scrams per 7000 Critical Hrs	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11
Unplanned scrams	0	0	0	0	0	0	0	0
Critical hours	1508.4	2159.0	2184.0	2208.0	2209.0	2159.0	2184.0	2208.0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

---

## Unplanned Power Changes per 7000 Critical Hrs



Thresholds: White > 6.0

### Notes

Unplanned Power Changes per 7000 Critical Hrs	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11
Unplanned power changes	0	0	0	0	0	0	0	0
Critical hours	1508.4	2159.0	2184.0	2208.0	2209.0	2159.0	2184.0	2208.0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

# Unplanned Scrams with Complications




Thresholds: White > 1.0

## Notes

Unplanned Scrams with Complications	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

## Safety System Functional Failures (BWR)



Thresholds: White > 6.0

### Notes


Safety System Functional Failures (BWR)	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11
Safety System Functional Failures	1	2	0	0	0	0	0	1
Indicator value	4	6	4	3	2	0	0	1

Licensee Comments:

3Q/11: LER 237/2011-001-00, Loss of CCSW System due to Stop Log Installation, dated 7/18/2011

---

# Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, Emergency AC Power System	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11
UAI ( $\Delta$ CDF)	1.40E-08	8.87E-10	4.83E-10	5.52E-10	1.54E-10	5.88E-10	8.60E-10	1.46E-09
URI ( $\Delta$ CDF)	2.20E-09	5.99E-10	7.94E-10	7.88E-10	7.98E-10	7.30E-10	5.38E-10	2.24E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	1.62E-08	1.50E-09	1.30E-09	1.30E-09	9.50E-10	1.30E-09	1.40E-09	3.70E-09

Licensee Comments: none

# Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, High Pressure Injection System	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11
UAI (ΔCDF)	-4.00E-08	-3.63E-08	-3.63E-08	-3.63E-08	-3.65E-08	-3.65E-08	-4.68E-08	-3.22E-09
URI (ΔCDF)	2.80E-07	2.54E-07	2.61E-07	2.61E-07	2.61E-07	2.61E-07	-7.66E-09	-7.66E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	2.40E-07	2.20E-07	2.30E-07	2.30E-07	2.20E-07	2.30E-07	-5.40E-08	-1.10E-08

Licensee Comments: none

# Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, Heat Removal System	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11
UAI ( $\Delta$ CDF)	-1.50E-09	2.40E-09	9.29E-10	3.64E-09	1.59E-09	-1.72E-09	-3.31E-09	-6.24E-09
URI ( $\Delta$ CDF)	-7.10E-11	-1.18E-10	-9.92E-11	-9.92E-11	-9.92E-11	-9.92E-11	-9.92E-11	-9.92E-11
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.57E-09	2.30E-09	8.30E-10	3.50E-09	1.50E-09	-1.80E-09	-3.40E-09	-6.30E-09

Licensee Comments: none

# Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


## Notes

Mitigating Systems Performance Index, Residual Heat Removal System	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11
UAI ( $\Delta$ CDF)	6.80E-10	-3.39E-10	-3.39E-10	-3.39E-10	-3.42E-10	7.42E-10	5.85E-10	5.71E-10
URI ( $\Delta$ CDF)	1.10E-09	1.17E-09	1.18E-09	1.19E-09	1.21E-09	1.22E-09	1.24E-09	1.31E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	1.78E-09	8.30E-10	8.40E-10	8.50E-10	8.70E-10	2.00E-09	1.80E-09	1.90E-09

Licensee Comments: none



# Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, Cooling Water Systems	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11
UAI ( $\Delta$ CDF)	3.90E-09	2.09E-09	1.90E-09	1.90E-09	1.28E-09	2.37E-09	2.44E-09	1.93E-09
URI ( $\Delta$ CDF)	-3.00E-11	-1.56E-11	-1.56E-11	-1.57E-11	-1.56E-11	-1.56E-11	-1.50E-11	-1.46E-11
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	3.87E-09	2.10E-09	1.90E-09	1.90E-09	1.30E-09	2.40E-09	2.40E-09	1.90E-09

Licensee Comments: none

# Reactor Coolant System Activity




Thresholds: White > 50.0 Yellow > 100.0

## Notes

Reactor Coolant System Activity	10/09	11/09	12/09	1/10	2/10	3/10	4/10	5/10	6/10	7/10	8/10	9/10
Maximum activity	0.000003	0.000009	0.000003	0.000003	0.000002	0.000003	0.000002	0.000003	0.000003	0.000003	0.000003	0.000003
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0
Reactor Coolant System Activity	10/10	11/10	12/10	1/11	2/11	3/11	4/11	5/11	6/11	7/11	8/11	9/11
Maximum activity	0.000004	0.000003	0.000004	0.000004	0.000004	0.000005	0.000005	0.000005	0.000005	0.000009	0.000004	0.000005
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Licensee Comments: none

# Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

## Notes

<b>Reactor Coolant System Leakage</b>	<b>10/09</b>	<b>11/09</b>	<b>12/09</b>	<b>1/10</b>	<b>2/10</b>	<b>3/10</b>	<b>4/10</b>	<b>5/10</b>	<b>6/10</b>	<b>7/10</b>	<b>8/10</b>	<b>9/10</b>
Maximum leakage	2.040	2.018	2.100	1.778	1.727	1.755	1.785	1.820	1.852	1.893	1.910	1.943
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	8.2	8.1	8.4	7.1	6.9	7.0	7.1	7.3	7.4	7.6	7.6	7.8
<b>Reactor Coolant System Leakage</b>	<b>10/10</b>	<b>11/10</b>	<b>12/10</b>	<b>1/11</b>	<b>2/11</b>	<b>3/11</b>	<b>4/11</b>	<b>5/11</b>	<b>6/11</b>	<b>7/11</b>	<b>8/11</b>	<b>9/11</b>
Maximum leakage	1.955	1.947	1.972	1.957	1.973	1.950	1.965	1.977	1.988	2.013	2.025	2.023
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	7.8	7.8	7.9	7.8	7.9	7.8	7.9	7.9	8.0	8.1	8.1	8.1

Licensee Comments: none

## Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

### Notes

Drill/Exercise Performance	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11
Successful opportunities	34.0	41.0	39.0	6.0	8.0	63.0	46.0	62.0
Total opportunities	34.0	42.0	40.0	6.0	8.0	64.0	46.0	62.0
Indicator value	99.6%	99.3%	99.0%	98.9%	98.8%	98.5%	98.9%	99.0%

Licensee Comments: none

# ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

## Notes

ERO Drill Participation	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11
Participating Key personnel	71.0	72.0	71.0	66.0	68.0	70.0	71.0	74.0
Total Key personnel	71.0	72.0	71.0	68.0	68.0	70.0	71.0	76.0
Indicator value	100.0%	100.0%	100.0%	97.1%	100.0%	100.0%	100.0%	97.4%

Licensee Comments: none

# Alert & Notification System



Thresholds: White < 94.0% Yellow < 90.0%

## Notes

Alert & Notification System	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11
Successful siren-tests	4983	2893	2929	2979	2988	2940	2936	2940
Total sirens-tests	4992	2898	2944	2990	2990	2944	2944	2944
Indicator value	99.8%	99.8%	99.8%	99.7%	99.7%	99.7%	99.8%	99.8%

Licensee Comments: none

## Occupational Exposure Control Effectiveness



**Thresholds: White > 2.0 Yellow > 5.0**


### Notes

Occupational Exposure Control Effectiveness	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

Licensee Comments: none

---

# RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

## Notes

RETS/ODCM Radiological Effluent	4Q/09	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

[Security](#) information not publicly available.