


Point Beach 2

4Q/2011 Performance Indicators

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11
Unplanned scrams	0	1.0	1.0	0	0	1.0	0	0
Critical hours	2159.0	2153.8	2182.9	2026.7	1416.6	384.9	2208.0	2209.0
Indicator value	0	0.9	1.9	1.6	1.8	2.3	1.2	1.1

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11
Unplanned power changes	0	0	0	1.0	0	0	0	0
Critical hours	2159.0	2153.8	2182.9	2026.7	1416.6	384.9	2208.0	2209.0
Indicator value	0	0	0	0.8	0.9	1.2	1.2	0

Licensee Comments: none

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

Safety System Functional Failures (PWR)



Thresholds: White > 5.0


Notes

Safety System Functional Failures (PWR)	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11
Safety System Functional Failures	0	0	0	1	2	1	0	0
Indicator value	0	0	0	1	3	4	4	3

Licensee Comments:

4Q/11: There were no LERs submitted in 4Q11.

Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


Notes

Mitigating Systems Performance Index, Emergency AC Power System	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11
UAI (Δ CDF)	3.44E-08	-1.33E-08	7.74E-08	5.16E-08	5.76E-08	8.61E-08	1.12E-07	1.22E-07
URI (Δ CDF)	-2.31E-07	-2.31E-07	-2.31E-07	-2.31E-07	-2.23E-07	-2.76E-07	-2.89E-07	-2.90E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-2.00E-07	-2.40E-07	-1.50E-07	-1.80E-07	-1.70E-07	-1.90E-07	-1.80E-07	-1.70E-07

Licensee Comments:

4Q/11: MSPI Basis Document updated for account for change in first hour of run time per FAQ 480.

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11
UAI (Δ CDF)	1.34E-09	2.40E-08	-2.06E-09	-1.08E-09	1.81E-09	2.21E-09	8.76E-09	1.39E-08
URI (Δ CDF)	-1.42E-08	-1.42E-08	-1.42E-08	-1.42E-08	-1.42E-08	-1.42E-08	-4.56E-08	-4.56E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.30E-08	9.70E-09	-1.60E-08	-1.50E-08	-1.20E-08	-1.20E-08	-3.70E-08	-3.20E-08

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11
UAI (Δ CDF)	2.24E-07	4.15E-07	2.41E-07	7.43E-08	8.13E-08	-4.01E-05	9.55E-09	1.09E-08
URI (Δ CDF)	-6.89E-07	-6.89E-07	-6.89E-07	-6.89E-07	-6.89E-07	-6.84E-07	-9.64E-09	-9.77E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-4.60E-07	-2.70E-07	-4.50E-07	-6.10E-07	-6.10E-07	-4.10E-05	-9.50E-11	1.10E-09

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11
UAI (Δ CDF)	5.79E-08	6.31E-08	3.08E-08	1.12E-08	5.11E-08	5.19E-08	3.53E-08	3.73E-08
URI (Δ CDF)	-2.90E-08	-2.90E-08	-2.90E-08	-2.90E-08	-2.90E-08	-2.90E-08	-2.24E-08	-2.24E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	2.90E-08	3.40E-08	1.80E-09	-1.80E-08	2.20E-08	2.30E-08	1.30E-08	1.50E-08

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11
UAI (Δ CDF)	3.93E-07	8.37E-07	1.23E-06	1.13E-06	9.89E-07	9.33E-07	1.26E-07	5.45E-08
URI (Δ CDF)	-2.25E-06	-2.25E-06	-2.25E-06	-2.25E-06	-2.25E-06	-2.25E-06	-2.80E-08	-2.80E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.90E-06	-1.40E-06	-1.00E-06	-1.10E-06	-1.30E-06	-1.30E-06	9.80E-08	2.70E-08

Licensee Comments: none

Reactor Coolant System Activity




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Activity	1/10	2/10	3/10	4/10	5/10	6/10	7/10	8/10	9/10	10/10	11/10	12/10
Maximum activity	0.000191	0.000193	0.000197	0.000209	0.000220	0.000213	0.000226	0.000241	0.000259	0.000252	0.000258	0.000298
Technical specification limit	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0
Reactor Coolant System Activity	1/11	2/11	3/11	4/11	5/11	6/11	7/11	8/11	9/11	10/11	11/11	12/11
Maximum activity	0.000264	0.000282	N/A	N/A	N/A	0.000135	0.000169	0.000167	0.000172	0.000189	0.000188	0.000204
Technical specification limit	0.8	0.8	0.8	0.8	0.8	0.5	0.5	0.5	0.5	0.5	0.5	0.5
Indicator value	0	0	N/A	N/A	N/A	0	0	0	0	0	0	0

Licensee Comments: none

Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	1/10	2/10	3/10	4/10	5/10	6/10	7/10	8/10	9/10	10/10	11/10	12/10
Maximum leakage	0.020	0.060	0.070	0.040	0.060	0.020	0.010	0.010	0.010	0.070	0.110	0.040
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.2	0.6	0.7	0.4	0.6	0.2	0.1	0.1	0.1	0.7	1.1	0.4
Reactor Coolant System Leakage	1/11	2/11	3/11	4/11	5/11	6/11	7/11	8/11	9/11	10/11	11/11	12/11
Maximum leakage	0.070	0.040	0.010	0	0	0.060	0.090	0.020	0.020	0.020	0.180	0.170
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.7	0.4	0.1	0	0	0.6	0.9	0.2	0.2	0.2	1.8	1.7

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11
Successful opportunities	31.0	30.0	30.0	11.0	10.0	10.0	33.0	2.0
Total opportunities	31.0	30.0	30.0	12.0	10.0	11.0	34.0	2.0
Indicator value	97.4%	97.4%	98.5%	98.5%	99.0%	98.8%	98.1%	98.1%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11
Participating Key personnel	59.0	61.0	62.0	61.0	58.0	57.0	62.0	59.0
Total Key personnel	59.0	61.0	62.0	61.0	58.0	57.0	62.0	60.0
Indicator value	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	98.3%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11
Successful siren-tests	78	84	84	83	83	83	98	98
Total sirens-tests	84	84	84	84	84	84	98	98
Indicator value	98.2%	98.2%	98.2%	97.9%	99.4%	99.1%	99.1%	99.5%

Licensee Comments: none

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

[Security](#) information not publicly available.