


# River Bend 1

## 4Q/2011 Performance Indicators

Licensee's General Comments: none

### Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

### Notes

Unplanned Scrams per 7000 Critical Hrs	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11
Unplanned scrams	0	0	0	0	0	0	0	1.0
Critical hours	2159.0	2184.0	2111.5	2209.0	1508.6	2184.0	2208.0	2154.0
Indicator value	0.9	0.9	0	0	0	0	0	0.9

Licensee Comments: none

## Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

### Notes

Unplanned Power Changes per 7000 Critical Hrs	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11
Unplanned power changes	1.0	0	0	1.0	0	1.0	0	0
Critical hours	2159.0	2184.0	2111.5	2209.0	1508.6	2184.0	2208.0	2154.0
Indicator value	0.9	0.9	0.8	1.6	0.9	1.7	1.7	0.9

Licensee Comments: none

## Unplanned Scrams with Complications



Thresholds: White > 1.0


### Notes

Unplanned Scrams with Complications	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11
Scrams with complications	0	0	0	0	0	0	0	1.0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0

Licensee Comments: none

---

## Safety System Functional Failures (BWR)




Thresholds: White > 6.0

### Notes

Safety System Functional Failures (BWR)	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11
Safety System Functional Failures	0	0	1	0	1	0	0	0
Indicator value	0	0	1	1	2	2	1	1

Licensee Comments: none

# Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


## Notes

Mitigating Systems Performance Index, Emergency AC Power System	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11
UAI ( $\Delta$ CDF)	1.12E-08	1.10E-08	8.95E-09	2.43E-08	2.31E-08	1.85E-08	1.59E-08	1.53E-08
URI ( $\Delta$ CDF)	1.57E-07	1.57E-07	1.22E-07	6.74E-08	6.63E-08	6.71E-08	6.78E-08	3.07E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	1.70E-07	1.70E-07	1.30E-07	9.20E-08	8.90E-08	8.60E-08	8.40E-08	3.20E-07

Licensee Comments:

4Q/11: Changed PRA Parameter(s).

# Mitigating Systems Performance Index, High Pressure Injection System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


## Notes

Mitigating Systems Performance Index, High Pressure Injection System	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11
UAI ( $\Delta$ CDF)	2.40E-09	2.28E-09	2.28E-09	1.01E-08	9.64E-09	9.64E-09	9.37E-09	4.20E-09
URI ( $\Delta$ CDF)	-2.95E-08	-2.96E-08	-2.94E-08	2.47E-08	2.41E-08	2.82E-08	2.77E-08	1.10E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-2.70E-08	-2.70E-08	-2.70E-08	3.50E-08	3.40E-08	3.80E-08	3.70E-08	5.30E-09

Licensee Comments:

4Q/11: Changed PRA Parameter(s).

# Mitigating Systems Performance Index, Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


## Notes

Mitigating Systems Performance Index, Heat Removal System	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11
UAI ( $\Delta$ CDF)	-2.15E-08	-2.16E-08	-2.16E-08	-1.35E-08	-1.39E-08	-1.32E-08	-1.09E-08	-4.23E-09
URI ( $\Delta$ CDF)	-6.30E-08	-6.73E-08	-6.69E-08	1.07E-07	9.53E-08	9.17E-08	8.81E-08	2.78E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-8.40E-08	-8.90E-08	-8.90E-08	9.40E-08	8.10E-08	7.80E-08	7.70E-08	2.40E-08

Licensee Comments:

4Q/11: Changed PRA Parameter(s).

# Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes


Mitigating Systems Performance Index, Residual Heat Removal System	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11
UAI ( $\Delta$ CDF)	-2.22E-08	-2.25E-08	-2.25E-08	-3.47E-08	-3.47E-08	-3.47E-08	-3.47E-08	-5.07E-08
URI ( $\Delta$ CDF)	-7.99E-08	-7.84E-08	-7.74E-08	-7.69E-08	-7.57E-08	-7.50E-08	-7.37E-08	-1.25E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.00E-07	-1.00E-07	-1.00E-07	-1.10E-07	-1.10E-07	-1.10E-07	-1.10E-07	-1.80E-07

Licensee Comments:

4Q/11: Changed PRA Parameter(s).



# Mitigating Systems Performance Index, Cooling Water Systems



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes


Mitigating Systems Performance Index, Cooling Water Systems	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11
UAI ( $\Delta$ CDF)	-2.64E-09	-2.64E-09	-2.64E-09	-2.64E-09	-2.64E-09	-2.64E-09	-2.64E-09	-1.56E-09
URI ( $\Delta$ CDF)	-2.43E-08	-2.43E-08	-2.43E-08	-2.26E-08	3.41E-07	3.41E-07	3.41E-07	4.60E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-2.70E-08	-2.70E-08	-2.70E-08	-2.50E-08	3.40E-07	3.40E-07	3.40E-07	4.60E-07

Licensee Comments:

4Q/11: Risk Cap Invoked.

4Q/11: Changed PRA Parameter(s).

# Reactor Coolant System Activity




Thresholds: White > 50.0 Yellow > 100.0

## Notes

Reactor Coolant System Activity	1/10	2/10	3/10	4/10	5/10	6/10	7/10	8/10	9/10	10/10	11/10	12/10
Maximum activity	0.000696	0.001080	0.000994	0.000866	0.001880	0.001670	0.001640	0.001670	0.001540	0.001380	0.001520	0.001530
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0.3	0.5	0.5	0.4	0.9	0.8	0.8	0.8	0.8	0.7	0.8	0.8
Reactor Coolant System Activity	1/11	2/11	3/11	4/11	5/11	6/11	7/11	8/11	9/11	10/11	11/11	12/11
Maximum activity	0.001400	0.000626	0.000658	0.000583	0.000604	0.000572	0.000659	0.000491	0.000497	0.000500	0.000516	0.000658
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0.7	0.3	0.3	0.3	0.3	0.3	0.3	0.2	0.2	0.3	0.3	0.3

Licensee Comments: none

## Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

### Notes

<b>Reactor Coolant System Leakage</b>	<b>1/10</b>	<b>2/10</b>	<b>3/10</b>	<b>4/10</b>	<b>5/10</b>	<b>6/10</b>	<b>7/10</b>	<b>8/10</b>	<b>9/10</b>	<b>10/10</b>	<b>11/10</b>	<b>12/10</b>
Maximum leakage	2.260	2.270	2.320	2.290	2.330	2.590	2.510	2.920	2.360	2.270	2.540	2.330
Technical specification limit	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0
Indicator value	7.5	7.6	7.7	7.6	7.8	8.6	8.4	9.7	7.9	7.6	8.5	7.8
<b>Reactor Coolant System Leakage</b>	<b>1/11</b>	<b>2/11</b>	<b>3/11</b>	<b>4/11</b>	<b>5/11</b>	<b>6/11</b>	<b>7/11</b>	<b>8/11</b>	<b>9/11</b>	<b>10/11</b>	<b>11/11</b>	<b>12/11</b>
Maximum leakage	2.370	2.250	2.210	2.100	2.290	2.080	2.080	2.080	2.110	2.940	2.090	2.340
Technical specification limit	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0
Indicator value	7.9	7.5	7.4	7.0	7.6	6.9	6.9	6.9	7.0	9.8	7.0	7.8

Licensee Comments: none

## Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

### Notes

Drill/Exercise Performance	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11
Successful opportunities	28.0	54.0	43.0	10.0	24.0	33.0	98.0	30.0
Total opportunities	30.0	56.0	43.0	10.0	24.0	34.0	101.0	30.0
Indicator value	97.3%	97.9%	98.0%	97.8%	97.7%	97.3%	97.3%	97.6%

Licensee Comments: none

# ERO Drill Participation



Thresholds: White < 80.0% Yellow < 60.0%


## Notes

ERO Drill Participation	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11
Participating Key personnel	126.0	128.0	132.0	95.0	96.0	95.0	97.0	91.0
Total Key personnel	127.0	128.0	132.0	95.0	96.0	95.0	97.0	91.0
Indicator value	99.2%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

---

# Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

## Notes

Alert & Notification System	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11
Successful siren-tests	1100	1184	1201	1209	1207	1207	1207	1116
Total sirens-tests	1116	1209	1209	1209	1209	1209	1209	1116
Indicator value	99.0%	98.6%	98.7%	99.0%	99.3%	99.8%	99.9%	99.9%

Licensee Comments: none

# Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0

## Notes

Occupational Exposure Control Effectiveness	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11
High radiation area occurrences	0	0	0	0	1	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>1</b>

Licensee Comments: none

# RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

## Notes

RETS/ODCM Radiological Effluent	1Q/10	2Q/10	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

[Security](#) information not publicly available.