


Ginna

2Q/2012 Performance Indicators

Licensee's General Comments: Identified a miscalculation of the number of IDS compensatory hours for the months of May, June, and August 2011 that were previously submitted. The color of the indicator remains green during those months.

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
Unplanned scrams	0	0	0	0	0	1.0	0	0
Critical hours	2208.0	2209.0	2159.0	1075.4	2208.0	2125.2	2183.0	2184.0
Indicator value	0.8	0	0	0	0	0.9	0.9	0.8

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
Unplanned power changes	0	0	0	0	0	0	0	0
Critical hours	2208.0	2209.0	2159.0	1075.4	2208.0	2125.2	2183.0	2184.0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

Safety System Functional Failures (PWR)




Thresholds: White > 5.0

Notes

Safety System Functional Failures (PWR)	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
Safety System Functional Failures	0	0	0	0	0	0	0	0
Indicator value	1	0	0	0	0	0	0	0

Licensee Comments: none

Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
UAI (Δ CDF)	-2.54E-08	5.11E-09	2.45E-08	1.65E-08	8.01E-09	-1.41E-08	-1.21E-07	-1.21E-07
URI (Δ CDF)	-5.68E-07	-5.91E-07	-5.94E-07	-6.17E-07	-6.12E-07	-6.23E-07	-6.16E-07	-6.14E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-5.90E-07	-5.90E-07	-5.70E-07	-6.00E-07	-6.00E-07	-6.40E-07	-7.40E-07	-7.40E-07

Licensee Comments: none

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
UAI (Δ CDF)	6.15E-08	6.13E-08	-1.94E-09	-1.93E-09	-1.93E-09	4.53E-10	4.51E-10	7.94E-10
URI (Δ CDF)	-4.47E-09	-4.47E-09	-4.47E-09	-4.47E-09	-4.47E-09	-4.47E-09	-4.47E-09	-4.47E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	5.70E-08	5.70E-08	-6.40E-09	-6.40E-09	-6.40E-09	-4.00E-09	-4.00E-09	-3.70E-09

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


Notes

Mitigating Systems Performance Index, Heat Removal System	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
UAI (Δ CDF)	3.73E-07	4.00E-07	3.88E-07	3.91E-07	3.92E-07	3.98E-07	3.91E-07	3.04E-07
URI (Δ CDF)	8.08E-07	7.90E-07	7.81E-07	7.70E-07	7.69E-07	4.77E-07	4.89E-07	2.30E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	1.20E-06	1.20E-06	1.20E-06	1.20E-06	1.20E-06	8.80E-07	8.80E-07	5.30E-07

Licensee Comments:

1Q/11: Changed PRA Parameter(s).

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
UAI (Δ CDF)	2.37E-08	2.15E-08	4.24E-08	4.12E-08	3.93E-08	2.08E-08	1.73E-08	1.35E-08
URI (Δ CDF)	-2.16E-08	-2.16E-08	-2.16E-08	-2.16E-08	-2.16E-08	-2.16E-08	-2.16E-08	-2.16E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	2.10E-09	7.60E-11	2.10E-08	2.00E-08	1.80E-08	8.00E-10	4.30E-09	8.10E-09

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
UAI (Δ CDF)	8.88E-08	2.86E-08	2.86E-08	1.66E-08	1.94E-08	2.00E-08	4.50E-08	1.49E-07
URI (Δ CDF)	-2.71E-08	-2.71E-08	-2.71E-08	2.97E-07	2.97E-07	2.97E-07	2.97E-07	2.97E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	6.20E-08	1.50E-09	1.50E-09	3.10E-07	3.20E-07	3.20E-07	3.40E-07	4.50E-07

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	7/10	8/10	9/10	10/10	11/10	12/10	1/11	2/11	3/11	4/11	5/11	6/11
Maximum activity	0.002120	0.002220	0.002190	0.002300	0.002290	0.002510	0.002260	0.002290	0.001880	0.001920		0.001400
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0.2	0.2	0.2	0.2	0.2	0.3	0.2	0.2	0.2	0.2		0.1

Reactor Coolant System Activity	7/11	8/11	9/11	10/11	11/11	12/11	1/12	2/12	3/12	4/12	5/12	6/12
Maximum activity	0.001590	0.001570	0.001760	0.001740	0.001840	0.001840	0.001940	0.001980	0.002300	0.002180	0.002350	0.002480
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2

Licensee Comments: none

Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	7/10	8/10	9/10	10/10	11/10	12/10	1/11	2/11	3/11	4/11	5/11	6/11
Maximum leakage	0.041	0.026	0.028	0.124	0.119	0.050	0.026	0.017	0.028	0.029		0.029
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.4	0.3	0.3	1.2	1.2	0.5	0.3	0.2	0.3	0.3		0.3
Reactor Coolant System Leakage	7/11	8/11	9/11	10/11	11/11	12/11	1/12	2/12	3/12	4/12	5/12	6/12
Maximum leakage	0.038	0.050	0.066	0.069	0.101	0.120	0.020	0.017	0.011	0.020	0.031	0.077
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.4	0.5	0.7	0.7	1.0	1.2	0.2	0.2	0.1	0.2	0.3	0.8

Licensee Comments: none

Drill/Exercise Performance



Thresholds: White < 90.0% Yellow < 70.0%


Notes

Drill/Exercise Performance	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
Successful opportunities	33.0	103.0	16.0	6.0	30.0	69.0	32.0	31.0
Total opportunities	34.0	103.0	16.0	6.0	30.0	71.0	33.0	32.0
Indicator value	97.1%	97.8%	97.5%	97.8%	98.0%	98.6%	98.7%	98.5%

Licensee Comments:

4Q/11: Upon review of previously submitted data for the month of December 2011, it was determined that 2 additional opportunities and 2 additional successes existed.

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
Participating Key personnel	55.0	63.0	63.0	55.0	58.0	60.0	60.0	62.0
Total Key personnel	55.0	63.0	63.0	55.0	58.0	60.0	60.0	62.0
Indicator value	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
Successful siren-tests	1234	1239	1245	1226	1242	1246	1247	1339
Total sirens-tests	1248	1248	1248	1248	1248	1246	1248	1344
Indicator value	99.6%	99.4%	99.4%	99.0%	99.2%	99.4%	99.4%	99.8%

Licensee Comments: none

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.
