


# Indian Point 3

## 2Q/2012 Performance Indicators

Licensee's General Comments: The main steam valve stroke test of turbine driven auxiliary feedwater pump steam supply valve PCV-1139 was inadvertently omitted as a demand in the August and December 2011 quarterly reports.

### Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

### Notes

Unplanned Scrams per 7000 Critical Hrs	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
Unplanned scrams	1.0	0	0	0	0	0	0	0
Critical hours	2166.2	2209.0	1555.7	2018.2	2208.0	2209.0	2183.0	2170.2
Indicator value	0.8	0.8	0.9	0.9	0	0	0	0

Licensee Comments: none

## Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

### Notes

Unplanned Power Changes per 7000 Critical Hrs	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
Unplanned power changes	0	0	1.0	0	0	0	1.0	0
Critical hours	2166.2	2209.0	1555.7	2018.2	2208.0	2209.0	2183.0	2170.2
Indicator value	0	0	0.9	0.9	0.9	0.9	0.8	0.8

Licensee Comments: none

## Unplanned Scrams with Complications




Thresholds: White > 1.0

### Notes

Unplanned Scrams with Complications	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

## Safety System Functional Failures (PWR)



Thresholds: White > 5.0


### Notes

Safety System Functional Failures (PWR)	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
Safety System Functional Failures	0	0	0	1	0	0	0	0
Indicator value	2	1	1	1	1	1	1	0

Licensee Comments:

2Q/11: LER-2011-003 reported on April 25, 2011, a TS required shutdown and a Safety System Functional Failure for a leak on the SW conventional essential header that caused flooding in the SW valve pit thereby preventing access to valves for accident mitigation.

# Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, Emergency AC Power System	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
UAI ( $\Delta$ CDF)	1.41E-07	1.51E-07	1.62E-07	1.49E-07	1.76E-07	1.35E-07	1.44E-07	1.01E-07
URI ( $\Delta$ CDF)	-2.98E-07	-2.05E-07	-2.20E-07	-2.25E-07	-1.35E-07	-1.29E-07	-1.02E-07	-8.28E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.60E-07	-5.40E-08	-5.90E-08	-7.60E-08	4.20E-08	6.40E-09	4.20E-08	1.90E-08

Licensee Comments: none

# Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, High Pressure Injection System	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
UAI ( $\Delta$ CDF)	-1.55E-10	-1.56E-10	-3.00E-10	3.19E-11	2.29E-10	1.97E-10	-7.07E-11	-9.48E-11
URI ( $\Delta$ CDF)	3.33E-09	3.40E-09	-7.34E-10	-7.05E-10	-7.11E-10	-7.11E-10	-6.42E-10	-5.90E-10
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	3.20E-09	3.20E-09	-1.00E-09	-6.70E-10	-4.80E-10	-5.10E-10	-7.10E-10	-6.90E-10

Licensee Comments: none

# Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, Heat Removal System	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
UAI ( $\Delta$ CDF)	-8.85E-09	1.17E-08	9.22E-08	1.15E-07	1.26E-07	1.18E-07	5.44E-08	1.75E-08
URI ( $\Delta$ CDF)	-6.17E-08	-6.17E-08	-7.50E-08	-9.41E-08	-1.03E-07	-9.91E-08	-2.32E-07	-2.05E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-7.10E-08	-5.00E-08	1.70E-08	2.10E-08	2.30E-08	1.90E-08	-1.80E-07	-1.90E-07

Licensee Comments: none

# Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


## Notes

Mitigating Systems Performance Index, Residual Heat Removal System	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
UAI ( $\Delta$ CDF)	-1.02E-08	-1.20E-08	-1.20E-08	-1.15E-08	-1.11E-08	-1.09E-08	-1.10E-08	-1.10E-08
URI ( $\Delta$ CDF)	-3.18E-09	-3.22E-09	-4.30E-09	-4.51E-09	-4.51E-09	-4.51E-09	-3.60E-09	-2.94E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.30E-08	-1.50E-08	-1.60E-08	-1.60E-08	-1.60E-08	-1.50E-08	-1.50E-08	-1.40E-08

Licensee Comments: none



## Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

### Notes

Mitigating Systems Performance Index, Cooling Water Systems	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
UAI ( $\Delta$ CDF)	5.75E-08	3.65E-08	5.68E-08	5.67E-08	1.59E-07	1.75E-07	1.79E-07	1.81E-07
URI ( $\Delta$ CDF)	2.45E-08	-1.35E-08	-1.39E-08	-1.44E-08	-7.75E-09	-8.01E-09	-7.73E-09	-7.37E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	8.20E-08	2.30E-08	4.30E-08	4.20E-08	1.50E-07	1.70E-07	1.70E-07	1.70E-07

Licensee Comments: none

## Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0

### Notes


Reactor Coolant System Activity	7/10	8/10	9/10	10/10	11/10	12/10	1/11	2/11	3/11	4/11	5/11	6/11
Maximum activity	0.000257	0.000301	0.000301	0.000313	0.000294	0.000303	0.000292	0.000324	0.000253	0.000125	0.000135	0.000137
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Reactor Coolant System Activity	7/11	8/11	9/11	10/11	11/11	12/11	1/12	2/12	3/12	4/12	5/12	6/12
Maximum activity	0.000142	0.000158	0.000153	0.000171	0.000164	0.000174	0.000186	0.000292	0.000206	0.000190	0.000203	0.000226
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Licensee Comments: none

## Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

### Notes

<b>Reactor Coolant System Leakage</b>	<b>7/10</b>	<b>8/10</b>	<b>9/10</b>	<b>10/10</b>	<b>11/10</b>	<b>12/10</b>	<b>1/11</b>	<b>2/11</b>	<b>3/11</b>	<b>4/11</b>	<b>5/11</b>	<b>6/11</b>
Maximum leakage	0.010	0.020	1.810	0.010	0.010	0	0.010	0.010	0.010	0.030	0.140	0.020
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.1	0.2	18.1	0.1	0.1	0	0.1	0.1	0.1	0.3	1.4	0.2
<b>Reactor Coolant System Leakage</b>	<b>7/11</b>	<b>8/11</b>	<b>9/11</b>	<b>10/11</b>	<b>11/11</b>	<b>12/11</b>	<b>1/12</b>	<b>2/12</b>	<b>3/12</b>	<b>4/12</b>	<b>5/12</b>	<b>6/12</b>
Maximum leakage	0.030	0.030	0.030	0.030	0.020	0.030	0.050	0.040	0.040	0.040	0.040	0.040
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.3	0.3	0.3	0.3	0.2	0.3	0.5	0.4	0.4	0.4	0.4	0.4

Licensee Comments: none

## Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

### Notes

Drill/Exercise Performance	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
Successful opportunities	97.0	55.0	19.0	66.0	143.0	14.0	131.0	289.0
Total opportunities	108.0	56.0	21.0	66.0	151.0	16.0	131.0	293.0
Indicator value	95.6%	95.6%	95.5%	95.8%	94.9%	94.4%	95.6%	96.7%

Licensee Comments: none

## ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

### Notes

ERO Drill Participation	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
Participating Key personnel	107.0	104.0	102.0	102.0	105.0	104.0	106.0	105.0
Total Key personnel	107.0	104.0	102.0	102.0	105.0	104.0	106.0	105.0
Indicator value	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

# Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

## Notes

Alert & Notification System	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
Successful siren-tests	1065	956	1012	1176	1201	993	956	787
Total sirens-tests	1067	957	1013	1179	1204	996	957	789
Indicator value	98.8%	99.7%	99.8%	99.8%	99.8%	99.8%	99.8%	99.8%

Licensee Comments: none

## Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0

### Notes

Occupational Exposure Control Effectiveness	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
High radiation area occurrences	0	0	1	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	1	1	1	1	0	0

Licensee Comments: none

## RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

### Notes

RETS/ODCM Radiological Effluent	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

---

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.

---