


Pilgrim 1

2Q/2012 Performance Indicators

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
Unplanned scrams	0	0	0	1.0	0	0	0	1.0
Critical hours	2208.0	2209.0	2091.2	1529.1	2208.0	1971.2	2183.0	2127.9
Indicator value	0	0	0	0.9	0.9	0.9	0.9	0.8

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
Unplanned power changes	0	0	1.0	0	0	2.0	0	1.0
Critical hours	2208.0	2209.0	2091.2	1529.1	2208.0	1971.2	2183.0	2127.9
Indicator value	0.8	0.8	1.6	0.9	0.9	2.7	1.8	2.5

Licensee Comments: none

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

Safety System Functional Failures (BWR)




Thresholds: White > 6.0

Notes

Safety System Functional Failures (BWR)	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
Safety System Functional Failures	0	0	0	0	0	0	1	0
Indicator value	2	2	1	0	0	0	1	1

Licensee Comments: none

Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes


Mitigating Systems Performance Index, Emergency AC Power System	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
UAI (Δ CDF)	9.56E-09	3.35E-09	6.15E-09	-6.00E-09	-6.02E-09	1.51E-08	3.14E-08	3.05E-08
URI (Δ CDF)	-1.13E-07	-1.12E-07	-5.38E-08	-4.83E-08	-4.84E-08	2.35E-08	1.28E-07	1.42E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.00E-07	-1.10E-07	-4.80E-08	-5.40E-08	-5.40E-08	3.90E-08	1.60E-07	1.70E-07

Licensee Comments:

2Q/12: Changed PRA Parameter(s).

1Q/12: Changed PRA Parameter(s).

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
UAI (Δ CDF)	-2.10E-08	-2.31E-08	-1.36E-08	-1.64E-08	-2.28E-08	9.47E-10	3.85E-10	3.35E-08
URI (Δ CDF)	2.04E-07	2.10E-07	2.10E-07	1.81E-07	1.76E-07	3.18E-07	3.34E-07	3.35E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	1.80E-07	1.90E-07	2.00E-07	1.60E-07	1.50E-07	3.20E-07	3.30E-07	3.70E-07

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
UAI (Δ CDF)	-1.06E-08	-1.07E-08	-1.30E-08	-1.29E-08	-1.29E-08	-1.58E-08	-1.57E-08	-8.67E-09
URI (Δ CDF)	8.82E-08	8.50E-08	8.83E-08	7.30E-08	7.30E-08	-4.89E-08	-4.65E-08	-4.50E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	7.80E-08	7.40E-08	7.50E-08	6.00E-08	6.00E-08	-6.50E-08	-6.20E-08	-5.40E-08

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
UAI (Δ CDF)	-2.09E-08	-1.05E-08	-8.67E-09	-7.22E-09	-1.08E-08	-2.68E-08	-2.68E-08	-2.68E-08
URI (Δ CDF)	-4.35E-08	-4.37E-08	-4.48E-08	-4.65E-08	-4.67E-08	-4.75E-08	-4.76E-08	-4.57E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-6.40E-08	-5.40E-08	-5.30E-08	-5.40E-08	-5.80E-08	-7.40E-08	-7.40E-08	-7.30E-08

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
UAI (Δ CDF)	7.50E-09	7.60E-09	8.64E-09	8.93E-09	1.35E-08	1.36E-08	1.33E-08	1.28E-08
URI (Δ CDF)	3.77E-10	2.93E-10	2.89E-10	3.08E-10	2.65E-10	2.74E-10	1.97E-10	1.02E-10
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	7.90E-09	7.90E-09	8.90E-09	9.20E-09	1.40E-08	1.40E-08	1.30E-08	1.30E-08

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0

Notes


Reactor Coolant System Activity	7/10	8/10	9/10	10/10	11/10	12/10	1/11	2/11	3/11	4/11	5/11	6/11
Maximum activity	0.000681	0.000799	0.000529	0.000730	0.000950	0.000878	0.000466	0.000700	0.000914	0.004420	0.002130	0.000221
Technical specification limit	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Reactor Coolant System Activity	7/11	8/11	9/11	10/11	11/11	12/11	1/12	2/12	3/12	4/12	5/12	6/12
Maximum activity	0.000254	0.000183	0.000211	0.000275	0.001730	0.002550	0.000559	0.000341	0.000250	0.000342	0.000575	0.000291
Technical specification limit	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Licensee Comments:

9/10: Indicates reactor coolant activity, expressed as a percentage of the Technical Specifications limit for Iodine. Technical Specifications do not specify a limit for Iodine-131.

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Leakage	7/10	8/10	9/10	10/10	11/10	12/10	1/11	2/11	3/11	4/11	5/11	6/11
Maximum leakage	1.780	1.800	1.880	1.880	1.890	1.920	1.920	1.940	1.980	2.000	2.820	1.910
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	7.1	7.2	7.5	7.5	7.6	7.7	7.7	7.8	7.9	8.0	11.3	7.6
Reactor Coolant System Leakage	7/11	8/11	9/11	10/11	11/11	12/11	1/12	2/12	3/12	4/12	5/12	6/12
Maximum leakage	1.960	1.950	1.960	1.930	1.900	1.960	2.000	1.980	2.010	2.020	2.150	2.160
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	7.8	7.8	7.8	7.7	7.6	7.8	8.0	7.9	8.0	8.1	8.6	8.6

Licensee Comments:

9/10: Reflects total leakage (identified plus un-identified), expressed as a percentage of the Technical Specifications limit. Technical Specifications specify un-identified and total leakage; it does not specify identified leakage.

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
Successful opportunities	36.0	49.0	19.0	16.0	57.0	67.0	38.0	45.0
Total opportunities	37.0	51.0	21.0	16.0	62.0	68.0	40.0	46.0
Indicator value	97.9%	97.6%	97.3%	97.9%	96.2%	96.2%	95.9%	95.9%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
Participating Key personnel	100.0	97.0	98.0	102.0	96.0	99.0	95.0	92.0
Total Key personnel	100.0	97.0	98.0	102.0	99.0	99.0	95.0	92.0
Indicator value	100.0%	100.0%	100.0%	100.0%	97.0%	100.0%	100.0%	100.0%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
Successful siren-tests	335	451	334	339	337	451	337	328
Total sirens-tests	339	452	339	339	339	452	339	337
Indicator value	98.8%	99.0%	98.8%	99.3%	99.5%	99.5%	99.7%	99.0%

Licensee Comments: none

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	3Q/10	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.
