


Farley 1

3Q/2012 Performance Indicators

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
Unplanned scrams	0	0	0	0	0	0	0	0
Critical hours	1284.8	2159.0	2184.0	2208.0	2209.0	2093.0	1606.2	2141.1
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
Unplanned power changes	0	0	1.0	0	0	0	0	0
Critical hours	1284.8	2159.0	2184.0	2208.0	2209.0	2093.0	1606.2	2141.1
Indicator value	1.8	1.8	2.7	0.9	0.8	0.8	0	0

Licensee Comments: none

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

Safety System Functional Failures (PWR)




Thresholds: White > 5.0

Notes

Safety System Functional Failures (PWR)	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
Safety System Functional Failures	0	0	0	0	0	0	0	0
Indicator value	1	1	0	0	0	0	0	0

Licensee Comments: none

Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


Notes

Mitigating Systems Performance Index, Emergency AC Power System	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
UAI (Δ CDF)	3.27E-07	1.60E-07	1.16E-07	-2.66E-08	-2.66E-08	-2.68E-08	-2.57E-08	-2.70E-08
URI (Δ CDF)	1.64E-06	-9.40E-07	-4.93E-07	-4.88E-07	-4.88E-07	-4.87E-07	-4.87E-07	-3.18E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	2.00E-06	-7.80E-07	-3.80E-07	-5.10E-07	-5.10E-07	-5.10E-07	-5.10E-07	-3.40E-07

Licensee Comments:

4Q/10: Risk Cap Invoked.

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
UAI (Δ CDF)	-3.24E-08	-3.52E-08	-8.61E-11	-4.90E-11	-3.26E-11	1.93E-11	6.68E-11	8.79E-11
URI (Δ CDF)	-5.17E-08	-5.17E-08	-1.26E-08	-1.26E-08	-1.26E-08	-1.26E-08	-1.26E-08	-1.26E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-8.40E-08	-8.70E-08	-1.30E-08	-1.30E-08	-1.30E-08	-1.30E-08	-1.20E-08	-1.20E-08

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
UAI (Δ CDF)	-5.14E-08	-1.52E-07	-1.14E-07	-1.13E-07	-1.19E-07	-9.03E-08	-8.31E-08	-8.71E-08
URI (Δ CDF)	-5.04E-07	-5.04E-07	-4.16E-07	-4.16E-07	-4.12E-07	-4.12E-07	-4.12E-07	-4.12E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-5.60E-07	-6.60E-07	-5.30E-07	-5.30E-07	-5.30E-07	-5.00E-07	-4.90E-07	-5.00E-07

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
UAI (ΔCDF)	-1.22E-08	-1.22E-08	1.86E-09	1.52E-09	1.47E-09	1.45E-08	5.76E-08	3.56E-08
URI (ΔCDF)	3.11E-07	3.11E-07	3.45E-07	3.45E-07	3.45E-07	3.45E-07	3.45E-07	3.45E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	3.00E-07	3.00E-07	3.50E-07	3.50E-07	3.50E-07	3.60E-07	4.00E-07	3.80E-07

Licensee Comments:

3Q/12: Risk Cap Invoked.

2Q/12: Risk Cap Invoked.

1Q/12: Risk Cap Invoked.

4Q/11: Risk Cap Invoked.


3Q/11: Risk Cap Invoked.

2Q/11: Risk Cap Invoked.

1Q/11: Risk Cap Invoked.

4Q/10: Risk Cap Invoked.

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
UAI (ΔCDF)	1.03E-07	8.86E-08	2.31E-08	2.08E-08	2.11E-08	2.14E-08	2.13E-08	2.11E-08
URI (ΔCDF)	-9.05E-08	-9.19E-08	7.02E-08	7.02E-08	7.02E-08	7.02E-08	7.02E-08	7.02E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	1.30E-08	-3.30E-09	9.30E-08	9.10E-08	9.10E-08	9.20E-08	9.10E-08	9.10E-08

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	10/10	11/10	12/10	1/11	2/11	3/11	4/11	5/11	6/11	7/11	8/11	9/11
Maximum activity	0.001110	0.000516	0.000664	0.000721	0.000749	0.000782	0.000847	0.000884	0.000975	0.000958	0.000981	0.001110
Technical specification limit	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
Indicator value	0.2	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.2	0.2	0.2	0.2

Reactor Coolant System Activity	10/11	11/11	12/11	1/12	2/12	3/12	4/12	5/12	6/12	7/12	8/12	9/12
Maximum activity	0.001040	0.001150	0.001180	0.001220	0.001280	0.001240	N/A	0.000614	0.000629	0.000730	0.000837	0.000819
Technical specification limit	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
Indicator value	0.2	0.2	0.2	0.2	0.3	0.2	N/A	0.1	0.1	0.1	0.2	0.2

Licensee Comments: none

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0

Notes


Reactor Coolant System Leakage	10/10	11/10	12/10	1/11	2/11	3/11	4/11	5/11	6/11	7/11	8/11	9/11
Maximum leakage	0.010	0.093	0.049	0.054	0.051	0.076	0.048	0.042	0.040	0.036	0.059	0.035
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.1	0.9	0.5	0.5	0.5	0.8	0.5	0.4	0.4	0.4	0.6	0.4

Reactor Coolant System Leakage	10/11	11/11	12/11	1/12	2/12	3/12	4/12	5/12	6/12	7/12	8/12	9/12
Maximum leakage	0.041	0.031	0.052	0.050	0.029	0.105	0.308	0.350	0.349	0.314	0.308	0.275
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.4	0.3	0.5	0.5	0.3	1.1	3.1	3.5	3.5	3.1	3.1	2.8

Licensee Comments:

6/12: April RCS Activity data not available because of U1 Outage

Drill/Exercise Performance



Thresholds: White < 90.0% Yellow < 70.0%


Notes

Drill/Exercise Performance	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
Successful opportunities	11.0	31.0	59.0	55.0	28.0	39.0	14.0	62.0
Total opportunities	11.0	34.0	61.0	56.0	28.0	40.0	15.0	64.0
Indicator value	93.9%	94.7%	94.8%	95.3%	95.6%	95.9%	96.5%	96.8%

Licensee Comments:

1Q/12: Data changed due to an entry error at the site.

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
Participating Key personnel	111.0	109.0	116.0	128.0	134.0	130.0	127.0	123.0
Total Key personnel	114.0	124.0	122.0	129.0	136.0	130.0	128.0	123.0
Indicator value	97.4%	87.9%	95.1%	99.2%	98.5%	100.0%	99.2%	100.0%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
Successful siren-tests	42	39	42	42	42	42	42	39
Total sirens-tests	42	39	42	42	42	42	42	39
Indicator value	99.4%	99.4%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.

 [Action Matrix Summary](#) | [Inspection Findings Summary](#) | [PI Summary](#) | [Reactor Oversight Process](#)

Last Modified: October 24, 2012