


Nine Mile Point 2

3Q/2012 Performance Indicators

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
Unplanned scrams	0	0	0	1.0	0	0	0	1.0
Critical hours	2209.0	2159.0	2184.0	2083.0	2081.3	2183.0	834.9	2152.3
Indicator value	0.9	0	0	0.8	0.8	0.8	1.0	1.0

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
Unplanned power changes	0	1.0	0	1.0	1.0	0	1.0	1.0
Critical hours	2209.0	2159.0	2184.0	2083.0	2081.3	2183.0	834.9	2152.3
Indicator value	0	0.9	0.8	1.6	2.5	1.6	2.9	2.9

Licensee Comments: none

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

Safety System Functional Failures (BWR)



Thresholds: White > 6.0

Notes


Safety System Functional Failures (BWR)	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
Safety System Functional Failures	0	0	0	0	1	0	0	1
Indicator value	0	0	0	0	1	1	1	2

Licensee Comments:

3Q/12: LER 2012-002

4Q/11: LER 2011-004

Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


Notes

Mitigating Systems Performance Index, Emergency AC Power System	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
UAI (Δ CDF)	-6.54E-08	-6.65E-09	-1.52E-08	-1.37E-08	-1.37E-08	-1.37E-08	-1.36E-08	-1.30E-08
URI (Δ CDF)	-1.45E-06	-1.49E-07	-1.41E-07	-9.55E-08	-9.26E-08	-9.30E-08	-9.91E-08	-9.19E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.50E-06	-1.60E-07	-1.60E-07	-1.10E-07	-1.10E-07	-1.10E-07	-1.10E-07	-1.00E-07

Licensee Comments:

1Q/11: MSPI Planned Unavailability Coefficients were updated to align with changes in maintenance strategies including newly identified work, offline work being performed online, and unavailability activities no longer being performed in parallel

Mitigating Systems Performance Index, High Pressure Injection System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


Notes

Mitigating Systems Performance Index, High Pressure Injection System	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
UAI (Δ CDF)	-1.30E-08	-4.64E-09	-3.15E-09	-3.55E-09	-6.91E-09	-1.30E-08	-9.59E-09	-7.76E-09
URI (Δ CDF)	-4.21E-08	-3.78E-08	-3.64E-08	-3.22E-08	-3.11E-08	-3.08E-08	-3.10E-08	-3.15E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-5.50E-08	-4.20E-08	-4.00E-08	-3.60E-08	-3.80E-08	-4.40E-08	-4.10E-08	-3.90E-08

Licensee Comments:

1Q/11: MSPI Planned Unavailability Coefficients were updated to align with changes in maintenance strategies including newly identified work, offline work being performed online, and unavailability activities no longer being performed in parallel

Mitigating Systems Performance Index, Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


Notes

Mitigating Systems Performance Index, Heat Removal System	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
UAI (Δ CDF)	4.05E-08	2.74E-08	1.39E-09	1.46E-09	7.09E-09	7.07E-09	8.27E-09	7.81E-09
URI (Δ CDF)	-1.46E-07	-2.88E-08	-2.62E-08	-2.68E-08	-2.68E-08	-2.68E-08	-2.88E-08	-2.75E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.10E-07	-1.40E-09	-2.50E-08	-2.50E-08	-2.00E-08	-2.00E-08	-2.00E-08	-2.00E-08

Licensee Comments:

1Q/11: MSPI Planned Unavailability Coefficients were updated to align with changes in maintenance strategies including newly identified work, offline work being performed online, and unavailability activities no longer being performed in parallel

Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


Notes

Mitigating Systems Performance Index, Residual Heat Removal System	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
UAI (Δ CDF)	-2.97E-08	-7.74E-09	-7.74E-09	-7.74E-09	-7.74E-09	-7.74E-09	-7.74E-09	-1.06E-08
URI (Δ CDF)	-5.34E-08	-1.40E-08	-1.27E-08	-1.29E-08	-1.28E-08	-1.28E-08	-1.52E-08	-2.08E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-8.30E-08	-2.20E-08	-2.00E-08	-2.10E-08	-2.00E-08	-2.10E-08	-2.30E-08	-3.10E-08

Licensee Comments:

1Q/11: MSPI Planned Unavailability Coefficients were updated to align with changes in maintenance strategies including newly identified work, offline work being performed online, and unavailability activities no longer being performed in parallel

Mitigating Systems Performance Index, Cooling Water Systems



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


Notes

Mitigating Systems Performance Index, Cooling Water Systems	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
UAI (Δ CDF)	1.24E-08	3.99E-09	3.92E-09	3.75E-09	2.76E-09	2.76E-09	2.96E-09	3.51E-09
URI (Δ CDF)	6.56E-08	2.18E-08	2.38E-08	2.41E-08	-1.14E-08	-1.15E-08	-1.22E-08	-1.23E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	7.80E-08	2.60E-08	2.80E-08	2.80E-08	-8.60E-09	-8.70E-09	-9.20E-09	-8.80E-09

Licensee Comments:

1Q/11: MSPI Planned Unavailability Coefficients were updated to align with changes in maintenance strategies including newly identified work, offline work being performed online, and unavailability activities no longer being performed in parallel

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	10/10	11/10	12/10	1/11	2/11	3/11	4/11	5/11	6/11	7/11	8/11	9/11
Maximum activity	0.000073	0.000078	0.000067	0.000076	0.000082	0.000078	0.000075	0.000078	0.000076	0.000066	0.000070	0.000067
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Reactor Coolant System Activity	10/11	11/11	12/11	1/12	2/12	3/12	4/12	5/12	6/12	7/12	8/12	9/12
Maximum activity	0.000067	0.000070	0.000070	0.000072	0.000071	0.000076	0.000073	N/A	N/A	0.000022	0.000032	0.000029
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	0	0	0	0	N/A	N/A	0	0	0

Licensee Comments: none

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Leakage	10/10	11/10	12/10	1/11	2/11	3/11	4/11	5/11	6/11	7/11	8/11	9/11
Maximum leakage	2.743	2.752	2.717	2.717	2.684	2.724	2.697	2.670	2.699	2.743	2.686	2.711
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	11.0	11.0	10.9	10.9	10.7	10.9	10.8	10.7	10.8	11.0	10.7	10.8

Reactor Coolant System Leakage	10/11	11/11	12/11	1/12	2/12	3/12	4/12	5/12	6/12	7/12	8/12	9/12
Maximum leakage	2.744	2.779	2.679	2.701	2.685	2.651	2.621	N/A	2.753	2.714	2.654	2.633
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	11.0	11.1	10.7	10.8	10.7	10.6	10.5	N/A	11.0	10.9	10.6	10.5

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
Successful opportunities	50.0	33.0	11.0	26.0	60.0	37.0	3.0	79.0
Total opportunities	51.0	33.0	11.0	26.0	61.0	38.0	3.0	85.0
Indicator value	98.3%	98.5%	98.5%	99.0%	98.9%	98.8%	98.8%	97.1%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
Participating Key personnel	96.0	100.0	102.0	97.0	90.0	88.0	83.0	86.0
Total Key personnel	96.0	100.0	102.0	97.0	90.0	88.0	83.0	86.0
Indicator value	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
Successful siren-tests	296	222	258	258	295	222	296	222
Total sirens-tests	296	222	259	259	296	222	296	222
Indicator value	99.7%	99.7%	99.6%	99.8%	99.7%	99.7%	99.8%	99.9%

Licensee Comments: none

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.

 [Action Matrix Summary](#) | [Inspection Findings Summary](#) | [PI Summary](#) | [Reactor Oversight Process](#)

Last Modified: October 24, 2012