


Peach Bottom 2

3Q/2012 Performance Indicators

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
Unplanned scrams	0	0	0	0	0	0	0	0
Critical hours	2064.2	2159.0	2184.0	2208.0	2209.0	2183.0	2184.0	1701.9
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
Unplanned power changes	0	0	0	0	0	0	0	0
Critical hours	2064.2	2159.0	2184.0	2208.0	2209.0	2183.0	2184.0	1701.9
Indicator value	0.9	0	0	0	0	0	0	0

Licensee Comments: none

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

Safety System Functional Failures (BWR)



Thresholds: White > 6.0


Notes

Safety System Functional Failures (BWR)	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
Safety System Functional Failures	0	0	1	0	0	0	0	0
Indicator value	0	0	1	1	1	1	0	0

Licensee Comments:

2Q/11: LER 2-11-01

Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
UAI (Δ CDF)	-1.72E-08	3.57E-09	1.87E-08	-1.01E-08	1.18E-08	1.08E-08	-1.31E-09	-9.34E-11
URI (Δ CDF)	3.36E-08	2.92E-08	2.96E-08	3.76E-08	3.59E-08	-1.83E-08	-2.36E-08	-1.96E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	1.60E-08	3.30E-08	4.80E-08	2.70E-08	4.80E-08	-7.50E-09	-2.50E-08	-2.00E-08


Licensee Comments:

1Q/11: Changed PRA Parameter(s). MSPI basis document revision 5 incorporates PRA updates for PBAPS U2 and U3 completed in the 3rd qtr 2010. MSPI PRA values for all impacted functions, device records and unit CDF have been revised IAW the values calculated in PB209A for U2 and PB309A for U3, respectively.

4Q/10: Changed PRA Parameter(s). PBAPS PRA MODEL UPDATE for 2010 was effective Q4 2010. Update PB209A/P309A has been incorporated into Revision 5 of the station MSPI Bases Document. All impacted Unit performance values have been updated as applicable effective 10/1/2010.

4Q/10: Changed PRA Parameter(s). PBAPS PRA MODEL UPDATE for 2010 was effective Q4 2010. Update PB209A/P309A has been incorporated into Revision 5 of the station MSPI Bases Document. All impacted Unit performance values have been updated as applicable effective 10/1/2010.

Mitigating Systems Performance Index, High Pressure Injection System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
UAI (ΔCDF)	-3.91E-08	-2.80E-08	-2.80E-08	-2.84E-08	-2.88E-08	-1.70E-08	-1.70E-08	-1.63E-08
URI (ΔCDF)	-1.25E-07	1.16E-07	1.16E-07	1.16E-07	1.16E-07	1.15E-07	1.15E-07	1.15E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.60E-07	8.80E-08	8.80E-08	8.70E-08	8.70E-08	9.80E-08	9.80E-08	9.90E-08


Licensee Comments:

1Q/11: Changed PRA Parameter(s). MSPI basis document revision 5 incorporates PRA updates for PBAPS U2 and U3 completed in the 3rd qtr 2010. MSPI PRA values for all impacted functions, device records and unit CDF have been revised IAW the values calculated in PB209A for U2 and PB309A for U3, respectively.

4Q/10: Changed PRA Parameter(s). PBAPS PRA MODEL UPDATE for 2010 was effective Q4 2010. Update PB209A/P309A has been incorporated into Revision 5 of the station MSPI Bases Document. All impacted Unit performance values have been updated as applicable effective 10/1/2010.

4Q/10: Changed PRA Parameter(s). PBAPS PRA MODEL UPDATE for 2010 was effective Q4 2010. Update PB209A/P309A has been incorporated into Revision 5 of the station MSPI Bases Document. All impacted Unit performance values have been updated as applicable effective 10/1/2010.

Mitigating Systems Performance Index, Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
UAI (Δ CDF)	-3.11E-08	-3.11E-08	-3.11E-08	-3.11E-08	-3.11E-08	-3.11E-08	-3.11E-08	-3.11E-08
URI (Δ CDF)	-9.60E-08	-9.63E-08	-9.65E-08	-9.68E-08	-9.70E-08	-9.73E-08	-9.75E-08	-9.77E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.30E-07	-1.30E-07	-1.30E-07	-1.30E-07	-1.30E-07	-1.30E-07	-1.30E-07	-1.30E-07

Licensee Comments:


1Q/11: Changed PRA Parameter(s). MSPI basis document revision 5 incorporates PRA updates for PBAPS U2 and U3 completed in the 3rd qtr 2010. MSPI PRA values for all impacted functions, device records and unit CDF have been revised IAW the values calculated in PB209A for U2 and PB309A for U3, respectively.

4Q/10: Changed PRA Parameter(s). PBAPS PRA MODEL UPDATE for 2010 was effective Q4 2010. Update PB209A/P309A has been incorporated into Revision 5 of the station MSPI Bases Document. All impacted Unit performance values have been updated as applicable effective 10/1/2010.

4Q/10: Changed PRA Parameter(s). PBAPS PRA MODEL UPDATE for 2010 was effective Q4 2010. Update PB209A/P309A has been incorporated into Revision 5 of the station MSPI Bases Document. All impacted Unit

performance values have been updated as applicable effective 10/1/2010.

Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
UAI (Δ CDF)	-2.19E-10	-2.17E-10	-2.17E-10	-3.09E-10	-3.04E-10	-3.04E-10	-1.10E-10	8.40E-11
URI (Δ CDF)	-3.21E-09	-4.19E-09	-5.09E-09	-5.94E-09	-6.72E-09	-7.46E-09	-8.14E-09	-8.79E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-3.40E-09	-4.40E-09	-5.30E-09	-6.20E-09	-7.00E-09	-7.80E-09	-8.30E-09	-8.70E-09


Licensee Comments:

1Q/11: Changed PRA Parameter(s). MSPI basis document revision 5 incorporates PRA updates for PBAPS U2 and U3 completed in the 3rd qtr 2010. MSPI PRA values for all impacted functions, device records and unit CDF have been revised IAW the values calculated in PB209A for U2 and PB309A for U3, respectively.

4Q/10: Changed PRA Parameter(s). PBAPS PRA MODEL UPDATE for 2010 was effective Q4 2010. Update PB209A/P309A has been incorporated into Revision 5 of the station MSPI Bases Document. All impacted Unit performance values have been updated as applicable effective 10/1/2010.

4Q/10: Changed PRA Parameter(s). PBAPS PRA MODEL UPDATE for 2010 was effective Q4 2010. Update PB209A/P309A has been incorporated into Revision 5 of the station MSPI Bases Document. All impacted Unit performance values have been updated as applicable effective 10/1/2010.

Mitigating Systems Performance Index, Cooling Water Systems



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
UAI (Δ CDF)	2.68E-09	2.45E-09	2.60E-09	1.46E-09	1.34E-09	2.40E-09	2.55E-09	2.93E-09
URI (Δ CDF)	-1.85E-09	-1.85E-09	-1.85E-09	-1.85E-09	-1.85E-09	-1.85E-09	-1.85E-09	-1.85E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	8.20E-10	6.00E-10	7.50E-10	-3.90E-10	-5.10E-10	5.50E-10	7.00E-10	1.10E-09


Licensee Comments:

1Q/11: Changed PRA Parameter(s). MSPI basis document revision 5 incorporates PRA updates for PBAPS U2 and U3 completed in the 3rd qtr 2010. MSPI PRA values for all impacted functions, device records and unit CDF have been revised IAW the values calculated in PB209A for U2 and PB309A for U3, respectively.

4Q/10: Changed PRA Parameter(s). PBAPS PRA MODEL UPDATE for 2010 was effective Q4 2010. Update PB209A/P309A has been incorporated into Revision 5 of the station MSPI Bases Document. All impacted Unit performance values have been updated as applicable effective 10/1/2010.

4Q/10: Changed PRA Parameter(s). PBAPS PRA MODEL UPDATE for 2010 was effective Q4 2010. Update PB209A/P309A has been incorporated into Revision 5 of the station MSPI Bases Document. All impacted Unit performance values have been updated as applicable effective 10/1/2010.

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	10/10	11/10	12/10	1/11	2/11	3/11	4/11	5/11	6/11	7/11	8/11	9/11
Maximum activity	0.000024	0.000021	0.000022	0.000022	0.000029	0.000061	0.000022	0.000023	0.000023	0.000025	0.000024	0.000022
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0
Reactor Coolant System												

Activity	10/11	11/11	12/11	1/12	2/12	3/12	4/12	5/12	6/12	7/12	8/12	9/12
Maximum activity	0.000027	0.000023	0.000022	0.000022	0.000020	0.000027	0.000020	0.000020	0.000020	0.000024	0.000021	0.000020
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Licensee Comments: none

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0

Notes


Reactor Coolant System Leakage	10/10	11/10	12/10	1/11	2/11	3/11	4/11	5/11	6/11	7/11	8/11	9/11
Maximum leakage	2.400	1.750	1.740	1.740	1.740	1.780	1.780	1.720	1.780	1.780	1.790	1.790
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	9.6	7.0	7.0	7.0	7.0	7.1	7.1	6.9	7.1	7.1	7.2	7.2

Reactor Coolant System Leakage	10/11	11/11	12/11	1/12	2/12	3/12	4/12	5/12	6/12	7/12	8/12	9/12
Maximum leakage	1.780	1.780	1.790	1.740	1.720	1.750	1.750	1.790	1.810	1.820	1.820	1.820
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0

Indicator value	7.1	7.1	7.2	7.0	6.9	7.0	7.0	7.2	7.2	7.3	7.3	7.3
-----------------	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
Successful opportunities	28.0	70.0	26.0	19.0	36.0	93.0	32.0	15.0
Total opportunities	28.0	73.0	27.0	19.0	36.0	93.0	32.0	15.0
Indicator value	98.6%	98.3%	98.2%	98.4%	98.5%	98.9%	98.8%	98.8%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
Participating Key personnel	67.0	66.0	67.0	61.0	67.0	71.0	72.0	74.0
Total Key personnel	67.0	66.0	67.0	61.0	67.0	71.0	72.0	74.0
Indicator value	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
Successful siren-tests	1259	1260	1259	1254	1257	1258	1258	1257
Total sirens-tests	1261	1261	1261	1261	1261	1261	1261	1261
Indicator value	99.8%	99.8%	99.8%	99.8%	99.7%	99.7%	99.7%	99.7%

Licensee Comments: none

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	4Q/10	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.

 [Action Matrix Summary](#) | [Inspection Findings Summary](#) | [PI Summary](#) | [Reactor Oversight Process](#)

Last Modified: October 24, 2012