


Fermi 2

4Q/2012 Performance Indicators

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
Unplanned scrams	0	0	0	0	0	1.0	1.0	1.0
Critical hours	1784.8	2184.0	2208.0	2209.0	2042.0	1282.6	1487.1	918.6
Indicator value	1.9	0.9	0.9	0	0	0.9	2.0	3.7

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
Unplanned power changes	1.0	0	0	1.0	0	0	0	0
Critical hours	1784.8	2184.0	2208.0	2209.0	2042.0	1282.6	1487.1	918.6
Indicator value	1.9	1.9	1.9	1.7	0.8	0.9	1.0	0

Licensee Comments: none

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

Safety System Functional Failures (BWR)



Thresholds: White > 6.0

Notes

Safety System Functional Failures (BWR)	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
Safety System Functional Failures	1	0	0	1	0	1	0	0
Indicator value	1	1	1	2	1	2	2	1


Licensee Comments:

2Q/12: LER 2012-001

4Q/11: LER 2011-01, Loss of the High Pressure Coolant Injection system due to an inoperable minimum flow valve.

1Q/11: February - Fermi 2 LER 2010-004

Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
UAI (Δ CDF)	-5.74E-09	-5.60E-09	1.40E-09	5.00E-10	-4.61E-09	-4.99E-09	-4.30E-09	-3.57E-09
URI (Δ CDF)	-2.97E-07	-3.00E-07	-3.01E-07	-2.95E-07	-2.99E-07	-3.57E-07	-3.61E-07	-3.58E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-3.00E-07	-3.10E-07	-3.00E-07	-2.90E-07	-3.00E-07	-3.60E-07	-3.60E-07	-3.60E-07

Licensee Comments: none

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
UAI (Δ CDF)	-1.24E-10	-1.24E-10	5.29E-09	4.06E-09	4.07E-09	4.13E-09	4.38E-09	4.49E-09
URI (Δ CDF)	-4.38E-09	-4.63E-09	2.01E-08	2.10E-08	1.96E-08	1.82E-08	1.65E-08	1.65E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-4.50E-09	-4.80E-09	2.50E-08	2.50E-08	2.40E-08	2.20E-08	2.10E-08	2.10E-08

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
UAI (Δ CDF)	-2.37E-09	-2.37E-09	-2.37E-09	-2.37E-09	-2.37E-09	-2.73E-09	-2.72E-09	-2.72E-09
URI (Δ CDF)	-2.66E-08	-2.74E-08	-2.82E-08	-2.89E-08	-2.97E-08	-3.04E-08	-3.18E-08	-3.18E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-2.90E-08	-3.00E-08	-3.10E-08	-3.10E-08	-3.20E-08	-3.30E-08	-3.50E-08	-3.50E-08

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
UAI (Δ CDF)	-6.24E-09	5.41E-09	6.79E-09	-4.23E-09	2.75E-09	3.28E-09	4.46E-09	1.13E-08
URI (Δ CDF)	-1.08E-07	-1.08E-07	-1.08E-07	-1.08E-07	-1.08E-07	-1.08E-07	-1.08E-07	-1.08E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.10E-07	-1.00E-07	-1.00E-07	-1.10E-07	-1.10E-07	-1.10E-07	-1.00E-07	-9.70E-08

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
UAI (Δ CDF)	2.88E-08	3.83E-08	3.83E-08	1.39E-08	2.12E-08	1.67E-08	1.84E-08	1.37E-08
URI (Δ CDF)	-1.28E-08	-1.28E-08	-1.29E-08	-1.29E-08	-1.29E-08	-1.28E-08	-1.29E-08	-1.29E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	1.60E-08	2.50E-08	2.50E-08	1.00E-09	8.30E-09	3.80E-09	5.60E-09	8.50E-10

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	1/11	2/11	3/11	4/11	5/11	6/11	7/11	8/11	9/11	10/11	11/11	12/11
Maximum activity	0.000025	0.000027	0.000033	0.000019	0.000017	0.000014	0.000016	0.000011	0.000006	0.000023	0.000025	0.000027
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Reactor Coolant System Activity	1/12	2/12	3/12	4/12	5/12	6/12	7/12	8/12	9/12	10/12	11/12	12/12
Maximum activity	0.000028	0.000031	0.000025	N/A	0.000028	0.000015	N/A	0.000015	0.000016	0.000018	0.000018	N/A
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	N/A	0	0	N/A	0	0	0	0	N/A

Licensee Comments: none

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Leakage	1/11	2/11	3/11	4/11	5/11	6/11	7/11	8/11	9/11	10/11	11/11	12/11
Maximum leakage	1.600	1.630	1.630	1.630	1.790	1.680	1.660	1.660	1.690	1.660	1.660	1.660
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	6.4	6.5	6.5	6.5	7.2	6.7	6.6	6.6	6.8	6.6	6.6	6.6

Reactor Coolant System Leakage	1/12	2/12	3/12	4/12	5/12	6/12	7/12	8/12	9/12	10/12	11/12	12/12
Maximum leakage	1.790	1.840	1.950	0	1.680	1.670	1.710	1.720	1.720	1.730	1.730	0.630
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	7.2	7.4	7.8	0	6.7	6.7	6.8	6.9	6.9	6.9	6.9	2.5

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
Successful opportunities	18.0	31.0	46.0	30.0	6.0	10.0	50.0	34.0
Total opportunities	19.0	31.0	46.0	31.0	6.0	10.0	53.0	35.0
Indicator value	96.2%	96.9%	97.8%	97.6%	98.5%	98.8%	97.7%	97.4%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
Participating Key personnel	120.0	120.0	121.0	119.0	118.0	116.0	115.0	116.0
Total Key personnel	120.0	120.0	121.0	119.0	119.0	117.0	115.0	117.0
Indicator value	100.0%	100.0%	100.0%	100.0%	99.2%	99.1%	100.0%	99.1%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
Successful siren-tests	186	186	186	123	186	186	186	184
Total sirens-tests	186	186	186	124	186	186	186	186
Indicator value	100.0%	100.0%	100.0%	99.9%	99.9%	99.9%	99.9%	99.7%

Licensee Comments: none

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.