


# McGuire 1

## 4Q/2012 Performance Indicators

Licensee's General Comments: none

### Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

### Notes

Unplanned Scrams per 7000 Critical Hrs	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
Unplanned scrams	1.0	0	0	0	0	0	0	0
Critical hours	2062.1	2184.0	1879.2	1881.8	2183.0	2184.0	2208.0	2209.0
<b>Indicator value</b>	<b>1.7</b>	<b>0.8</b>	<b>0.8</b>	<b>0.9</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

Licensee Comments: none

### Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

#### Notes

Unplanned Power Changes per 7000 Critical Hrs	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
Unplanned power changes	1.0	0	0	0	0	0	0	0
Critical hours	2062.1	2184.0	1879.2	1881.8	2183.0	2184.0	2208.0	2209.0
<b>Indicator value</b>	<b>1.7</b>	<b>0.8</b>	<b>0.8</b>	<b>0.9</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

Licensee Comments: none

### Unplanned Scrams with Complications




Thresholds: White > 1.0

#### Notes

Unplanned Scrams with Complications	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
Scrams with complications	0	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>

Licensee Comments: none

### Safety System Functional Failures (PWR)




Thresholds: White > 5.0

#### Notes

Safety System Functional Failures (PWR)	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
Safety System Functional Failures	1	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>2</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

Licensee Comments: none

### Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


#### Notes

Mitigating Systems Performance Index, Emergency AC Power System	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
UAI ( $\Delta$ CDF)	-4.25E-08	-2.40E-08	-2.14E-08	6.97E-09	9.26E-09	1.97E-08	4.58E-08	3.02E-08
URI ( $\Delta$ CDF)	-4.47E-07	-4.47E-07	-4.47E-07	-4.47E-07	-4.47E-07	-4.47E-07	-3.94E-07	-3.94E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-4.90E-07	-4.70E-07	-4.70E-07	-4.40E-07	-4.40E-07	-4.30E-07	-3.50E-07	-3.60E-07

Licensee Comments:

4Q/12: PRA updates for 2013

### Mitigating Systems Performance Index, High Pressure Injection System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


#### Notes

Mitigating Systems Performance Index, High Pressure Injection System	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
UAI ( $\Delta$ CDF)	8.51E-09	8.46E-09	1.13E-08	8.92E-09	1.10E-08	1.94E-08	3.58E-08	3.25E-08
URI ( $\Delta$ CDF)	-4.91E-08	-4.91E-08	-4.91E-08	-4.91E-08	-4.91E-08	-4.91E-08	-1.50E-08	-1.50E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-4.10E-08	-4.10E-08	-3.80E-08	-4.00E-08	-3.80E-08	-3.00E-08	2.10E-08	1.80E-08

Licensee Comments:

4Q/12: PRA updates for 2013

### Mitigating Systems Performance Index, Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


#### Notes

Mitigating Systems Performance Index, Heat Removal System	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
UAI ( $\Delta$ CDF)	-1.60E-08	1.45E-08	2.54E-08	3.34E-08	5.92E-08	4.76E-08	1.88E-07	1.71E-07
URI ( $\Delta$ CDF)	-1.71E-07	-1.67E-07	-1.67E-07	-1.67E-07	-1.67E-07	-1.67E-07	-1.94E-07	-1.94E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.90E-07	-1.50E-07	-1.40E-07	-1.30E-07	-1.10E-07	-1.20E-07	-6.00E-09	-2.30E-08

Licensee Comments:

4Q/12: PRA updates for 2013

### Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

#### Notes


Mitigating Systems Performance Index, Residual Heat Removal System	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
UAI ( $\Delta$ CDF)	-3.11E-08	-3.11E-08	-3.11E-08	-3.11E-08	-1.32E-08	-1.70E-08	-3.35E-08	-1.56E-08
URI ( $\Delta$ CDF)	-2.47E-07	-2.47E-07	-2.47E-07	-2.47E-07	-2.47E-07	-2.47E-07	-1.56E-07	-1.56E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-2.80E-07	-2.80E-07	-2.80E-07	-2.80E-07	-2.60E-07	-2.60E-07	-1.90E-07	-1.70E-07

Licensee Comments:

4Q/12: PRA updates for 2013



### Mitigating Systems Performance Index, Cooling Water Systems



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

#### Notes


Mitigating Systems Performance Index, Cooling Water Systems	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
UAI ( $\Delta$ CDF)	5.53E-07	5.51E-07	4.19E-07	3.94E-07	3.85E-07	3.92E-07	3.97E-07	3.97E-07
URI ( $\Delta$ CDF)	-1.09E-06	-1.09E-06	-1.09E-06	-1.09E-06	-1.09E-06	-1.09E-06	-8.54E-07	-8.54E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-5.40E-07	-5.40E-07	-6.70E-07	-7.00E-07	-7.10E-07	-7.00E-07	-4.60E-07	-4.60E-07

Licensee Comments:

4Q/12: PRA updates for 2013

1Q/11: Risk Cap Invoked.

### Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0

**Notes**


Reactor Coolant System Activity	1/11	2/11	3/11	4/11	5/11	6/11	7/11	8/11	9/11	10/11	11/11	12/11
Maximum activity	0.000498	0.000462	0.000467	0.000466	0.000588	0.001497	0.001784	0.000538	0.000556	0.000556	0.000371	0.000305
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0	0	0.1	0.1	0.2	0.1	0.1	0.1	0	0

Reactor Coolant System Activity	1/12	2/12	3/12	4/12	5/12	6/12	7/12	8/12	9/12	10/12	11/12	12/12
Maximum activity	0.000474	0.000310	0.000320	0.000376	0.001090	0.000325	0.000371	0.000379	0.000389	0.000235	0.000249	0.000260
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0	0	0.1	0	0	0	0	0	0	0

Licensee Comments: none

### Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

**Notes**

Reactor Coolant System Leakage	1/11	2/11	3/11	4/11	5/11	6/11	7/11	8/11	9/11	10/11	11/11	12/11
Maximum leakage	0.076	0.082	0.063	0.058	0.078	0.122	0.091	0.116	0.165	0.085	0.120	0.117
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
<b>Indicator value</b>	<b>0.8</b>	<b>0.8</b>	<b>0.6</b>	<b>0.6</b>	<b>0.8</b>	<b>1.2</b>	<b>0.9</b>	<b>1.2</b>	<b>1.7</b>	<b>0.9</b>	<b>1.2</b>	<b>1.2</b>
Reactor Coolant System Leakage	1/12	2/12	3/12	4/12	5/12	6/12	7/12	8/12	9/12	10/12	11/12	12/12
Maximum leakage	0.162	0.184	0.161	0.119	0.085	0.087	0.123	0.145	0.148	0.140	0.238	0.170
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
<b>Indicator value</b>	<b>1.6</b>	<b>1.8</b>	<b>1.6</b>	<b>1.2</b>	<b>0.9</b>	<b>0.9</b>	<b>1.2</b>	<b>1.5</b>	<b>1.5</b>	<b>1.4</b>	<b>2.4</b>	<b>1.7</b>

Licensee Comments: none

### Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

#### Notes

Drill/Exercise Performance	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
Successful opportunities	0	30.0	40.0	64.0	26.0	25.0	12.0	57.0
Total opportunities	0	32.0	40.0	65.0	27.0	26.0	12.0	57.0
<b>Indicator value</b>	<b>95.3%</b>	<b>94.6%</b>	<b>95.8%</b>	<b>98.2%</b>	<b>97.9%</b>	<b>97.7%</b>	<b>97.6%</b>	<b>98.1%</b>

Licensee Comments: none

### ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

#### Notes

ERO Drill Participation	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
Participating Key personnel	167.0	165.0	168.0	173.0	170.0	169.0	168.0	167.0
Total Key personnel	170.0	168.0	169.0	174.0	171.0	170.0	171.0	167.0
Indicator value	98.2%	98.2%	99.4%	99.4%	99.4%	99.4%	98.2%	100.0%

Licensee Comments: none

### Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

#### Notes

Alert & Notification System	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
Successful siren-tests	1808	1803	1808	1805	1803	1780	1807	1801
Total sirens-tests	1809	1809	1809	1809	1809	1786	1809	1809
Indicator value	99.4%	99.8%	99.9%	99.8%	99.8%	99.8%	99.8%	99.7%

Licensee Comments: none

### Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

**Notes**

Occupational Exposure Control Effectiveness	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
High radiation area occurrences	0	0	1	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	1	0
<b>Indicator value</b>	<b>0</b>	<b>0</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>1</b>

Licensee Comments: none

### RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

#### Notes

RETS/ODCM Radiological Effluent	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.