


## Nine Mile Point 2

### 4Q/2012 Performance Indicators

Licensee's General Comments: none

#### Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

#### Notes

Unplanned Scrams per 7000 Critical Hrs	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
Unplanned scrams	0	0	1.0	0	0	0	1.0	0
Critical hours	2159.0	2184.0	2083.0	2081.3	2183.0	834.9	2152.3	2091.9
Indicator value	0	0	0.8	0.8	0.8	1.0	1.0	1.0

Licensee Comments: none

### Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

#### Notes

Unplanned Power Changes per 7000 Critical Hrs	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
Unplanned power changes	1.0	0	1.0	1.0	0	1.0	1.0	0
Critical hours	2159.0	2184.0	2083.0	2081.3	2183.0	834.9	2152.3	2091.9
<b>Indicator value</b>	<b>0.9</b>	<b>0.8</b>	<b>1.6</b>	<b>2.5</b>	<b>1.6</b>	<b>2.9</b>	<b>2.9</b>	<b>1.9</b>

Licensee Comments: none

### Unplanned Scrams with Complications




Thresholds: White > 1.0

#### Notes

Unplanned Scrams with Complications	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
Scrams with complications	0	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>

Licensee Comments: none

### Safety System Functional Failures (BWR)



Thresholds: White > 6.0

#### Notes


Safety System Functional Failures (BWR)	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
Safety System Functional Failures	0	0	0	1	0	0	1	0
<b>Indicator value</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>2</b>	<b>1</b>

Licensee Comments:

3Q/12: LER 2012-002

4Q/11: LER 2011-004

### Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


#### Notes

Mitigating Systems Performance Index, Emergency AC Power System	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
UAI ( $\Delta$ CDF)	-6.65E-09	-1.52E-08	-1.37E-08	-1.37E-08	-1.37E-08	-1.36E-08	-1.30E-08	-1.30E-08
URI ( $\Delta$ CDF)	-1.49E-07	-1.41E-07	-9.55E-08	-9.26E-08	-9.30E-08	-9.91E-08	-9.19E-08	-9.33E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.60E-07	-1.60E-07	-1.10E-07	-1.10E-07	-1.10E-07	-1.10E-07	-1.00E-07	-1.10E-07

#### Licensee Comments:

1Q/11: MSPI Planned Unavailability Coefficients were updated to align with changes in maintenance strategies including newly identified work, offline work being performed online, and unavailability activities no longer being performed in parallel

### Mitigating Systems Performance Index, High Pressure Injection System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


#### Notes

Mitigating Systems Performance Index, High Pressure Injection System	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
UAI ( $\Delta$ CDF)	-4.64E-09	-3.15E-09	-3.55E-09	-6.91E-09	-1.30E-08	-9.59E-09	-7.76E-09	-1.53E-08
URI ( $\Delta$ CDF)	-3.78E-08	-3.64E-08	-3.22E-08	-3.11E-08	-3.08E-08	-3.10E-08	-3.15E-08	-2.97E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-4.20E-08	-4.00E-08	-3.60E-08	-3.80E-08	-4.40E-08	-4.10E-08	-3.90E-08	-4.50E-08

#### Licensee Comments:

1Q/11: MSPI Planned Unavailability Coefficients were updated to align with changes in maintenance strategies including newly identified work, offline work being performed online, and unavailability activities no longer being performed in parallel

### Mitigating Systems Performance Index, Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


#### Notes

Mitigating Systems Performance Index, Heat Removal System	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
UAI ( $\Delta$ CDF)	2.74E-08	1.39E-09	1.46E-09	7.09E-09	7.07E-09	8.27E-09	7.81E-09	1.02E-08
URI ( $\Delta$ CDF)	-2.88E-08	-2.62E-08	-2.68E-08	-2.68E-08	-2.68E-08	-2.88E-08	-2.75E-08	-2.81E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.40E-09	-2.50E-08	-2.50E-08	-2.00E-08	-2.00E-08	-2.00E-08	-2.00E-08	-1.80E-08

#### Licensee Comments:

1Q/11: MSPI Planned Unavailability Coefficients were updated to align with changes in maintenance strategies including newly identified work, offline work being performed online, and unavailability activities no longer being performed in parallel

### Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

#### Notes


Mitigating Systems Performance Index, Residual Heat Removal System	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
UAI ( $\Delta$ CDF)	-7.74E-09	-7.74E-09	-7.74E-09	-7.74E-09	-7.74E-09	-7.74E-09	-1.06E-08	-1.06E-08
URI ( $\Delta$ CDF)	-1.40E-08	-1.27E-08	-1.29E-08	-1.28E-08	-1.28E-08	-1.52E-08	-2.08E-08	-2.13E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-2.20E-08	-2.00E-08	-2.10E-08	-2.00E-08	-2.10E-08	-2.30E-08	-3.10E-08	-3.20E-08

#### Licensee Comments:

1Q/11: MSPI Planned Unavailability Coefficients were updated to align with changes in maintenance strategies including newly identified work, offline work being performed online, and unavailability activities no longer being performed in parallel



### Mitigating Systems Performance Index, Cooling Water Systems



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


#### Notes

Mitigating Systems Performance Index, Cooling Water Systems	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
UAI ( $\Delta$ CDF)	3.99E-09	3.92E-09	3.75E-09	2.76E-09	2.76E-09	2.96E-09	3.51E-09	3.39E-09
URI ( $\Delta$ CDF)	2.18E-08	2.38E-08	2.41E-08	-1.14E-08	-1.15E-08	-1.22E-08	-1.23E-08	-1.22E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	2.60E-08	2.80E-08	2.80E-08	-8.60E-09	-8.70E-09	-9.20E-09	-8.80E-09	-8.90E-09

#### Licensee Comments:

1Q/11: MSPI Planned Unavailability Coefficients were updated to align with changes in maintenance strategies including newly identified work, offline work being performed online, and unavailability activities no longer being performed in parallel

### Reactor Coolant System Activity




Thresholds: White > 50.0 Yellow > 100.0

#### Notes

Reactor Coolant System Activity	1/11	2/11	3/11	4/11	5/11	6/11	7/11	8/11	9/11	10/11	11/11	12/11
Maximum activity	0.000076	0.000082	0.000078	0.000075	0.000078	0.000076	0.000066	0.000070	0.000067	0.000067	0.000070	0.000070
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0
Reactor Coolant System Activity	1/12	2/12	3/12	4/12	5/12	6/12	7/12	8/12	9/12	10/12	11/12	12/12
Maximum activity	0.000072	0.000071	0.000076	0.000073	N/A	N/A	0.000022	0.000032	0.000029	0.000023	0.000022	0.000024
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	0	N/A	N/A	0	0	0	0	0	0

Licensee Comments: none

### Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0

#### Notes


Reactor Coolant System Leakage	1/11	2/11	3/11	4/11	5/11	6/11	7/11	8/11	9/11	10/11	11/11	12/11
Maximum leakage	2.717	2.684	2.724	2.697	2.670	2.699	2.743	2.686	2.711	2.744	2.779	2.679
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	10.9	10.7	10.9	10.8	10.7	10.8	11.0	10.7	10.8	11.0	11.1	10.7

Reactor Coolant System Leakage	1/12	2/12	3/12	4/12	5/12	6/12	7/12	8/12	9/12	10/12	11/12	12/12
Maximum leakage	2.701	2.685	2.651	2.621	N/A	2.753	2.714	2.654	2.633	2.631	2.628	2.632
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	10.8	10.7	10.6	10.5	N/A	11.0	10.9	10.6	10.5	10.5	10.5	10.5

Licensee Comments: none

### Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

### Notes

Drill/Exercise Performance	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
Successful opportunities	33.0	11.0	26.0	60.0	37.0	3.0	79.0	60.0
Total opportunities	33.0	11.0	26.0	61.0	38.0	3.0	85.0	61.0
Indicator value	98.5%	98.5%	99.0%	98.9%	98.8%	98.8%	97.1%	97.2%

Licensee Comments: none

### ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

#### Notes

ERO Drill Participation	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
Participating Key personnel	100.0	102.0	97.0	90.0	88.0	83.0	86.0	84.0
Total Key personnel	100.0	102.0	97.0	90.0	88.0	83.0	86.0	84.0
Indicator value	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

### Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

#### Notes

Alert & Notification System	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
Successful siren-tests	222	258	258	295	222	296	222	333
Total sirens-tests	222	259	259	296	222	296	222	333
Indicator value	99.7%	99.6%	99.8%	99.7%	99.7%	99.8%	99.9%	100.0%

Licensee Comments: none

### Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

#### Notes

Occupational Exposure Control Effectiveness	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

Licensee Comments: none

### RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

#### Notes

RETS/ODCM Radiological Effluent	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.