


Saint Lucie 1

4Q/2012 Performance Indicators

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
Unplanned scrams	0	0	1.0	1.0	1.0	1.0	0	0
Critical hours	2159.0	2184.0	2123.2	1295.7	70.9	1845.5	2080.6	2209.0
Indicator value	1.0	0	0.8	1.8	3.7	5.2	4.0	2.3

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
Unplanned power changes	0	0	0	1.0	0	0	0	0
Critical hours	2159.0	2184.0	2123.2	1295.7	70.9	1845.5	2080.6	2209.0
Indicator value	1.0	0.8	0	0.9	1.2	1.3	1.3	0

Licensee Comments: none

Unplanned Scrams with Complications



Thresholds: White > 1.0


Notes

Unplanned Scrams with Complications	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
Scrams with complications	0	0	1.0	0	1.0	0	0	0
Indicator value	0.0	0.0	1.0	1.0	2.0	2.0	1.0	1.0

Licensee Comments:

1Q/12: FPL is submitting a FAQ concerning the March USwC. This data element may be changed based on the outcome of the FAQ.

Safety System Functional Failures (PWR)



Thresholds: White > 5.0

Notes


Safety System Functional Failures (PWR)	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
Safety System Functional Failures	0	0	0	0	1	0	1	0
Indicator value	3	1	0	0	1	1	2	2

Licensee Comments:

3Q/12: August SSFF documented in LER 50-355/2012-007-00

1Q/12: Jan SSFF documented in LER 50-335/2011-003-00

Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


Notes

Mitigating Systems Performance Index, Emergency AC Power System	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
UAI (ΔCDF)	6.19E-08	6.25E-08	5.39E-08	5.40E-08	4.63E-08	5.21E-08	7.22E-08	8.54E-08
URI (ΔCDF)	2.34E-07	2.34E-07	2.34E-07	1.46E-07	9.44E-08	1.12E-07	8.54E-08	8.58E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	3.00E-07	3.00E-07	2.90E-07	2.00E-07	1.40E-07	1.60E-07	1.60E-07	1.70E-07

Licensee Comments:

3Q/12: Changed PRA Parameter(s).

Mitigating Systems Performance Index, High Pressure Injection System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


Notes

Mitigating Systems Performance Index, High Pressure Injection System	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
UAI (Δ CDF)	3.32E-08	3.09E-08	3.59E-08	-2.17E-08	-4.62E-08	-4.40E-08	-3.36E-08	-3.36E-08
URI (Δ CDF)	-1.28E-07	-1.28E-07	-1.28E-07	-1.28E-07	-1.28E-07	-1.28E-07	-1.63E-07	-1.63E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-9.50E-08	-9.70E-08	-9.20E-08	-1.50E-07	-1.70E-07	-1.70E-07	-2.00E-07	-2.00E-07

Licensee Comments:

3Q/12: Changed PRA Parameter(s).

Mitigating Systems Performance Index, Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


Notes

Mitigating Systems Performance Index, Heat Removal System	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
UAI (Δ CDF)	7.16E-09	7.16E-09	7.14E-09	7.88E-09	9.09E-09	9.31E-09	1.45E-08	1.45E-08
URI (Δ CDF)	4.12E-08	4.12E-08	4.12E-08	4.12E-08	5.42E-08	5.42E-08	2.73E-07	2.73E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	4.80E-08	4.80E-08	4.80E-08	4.90E-08	6.30E-08	6.40E-08	2.90E-07	2.90E-07

Licensee Comments:

3Q/12: Changed PRA Parameter(s). Q3 2012, Unit 1 AFW excluded MV-08-13 and MV-08-14 from scope due to low birnbaum, manual recovery action only. Unit 2 AFW excluded MV-09-13 and MV-09-14 from scope

Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


Notes

Mitigating Systems Performance Index, Residual Heat Removal System	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
UAI (Δ CDF)	1.29E-10	7.27E-11	-3.77E-11	-2.10E-10	-2.81E-10	-2.81E-10	-1.41E-10	-1.41E-10
URI (Δ CDF)	-2.25E-09	-2.25E-09	-2.25E-09	-2.25E-09	-2.25E-09	-2.25E-09	-1.96E-09	-1.96E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-2.10E-09	-2.20E-09	-2.30E-09	-2.50E-09	-2.50E-09	-2.50E-09	-2.10E-09	-2.10E-09

Licensee Comments:

3Q/12: Changed PRA Parameter(s).

Mitigating Systems Performance Index, Cooling Water Systems



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


Notes

Mitigating Systems Performance Index, Cooling Water Systems	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
UAI (ΔCDF)	3.41E-07	3.38E-07	1.16E-07	1.32E-08	-3.42E-08	-3.60E-08	2.84E-08	2.85E-08
URI (ΔCDF)	-3.55E-08	-3.55E-08	-3.55E-08	-3.55E-08	-3.55E-08	-3.55E-08	-1.20E-08	-1.20E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	3.10E-07	3.00E-07	8.10E-08	-2.20E-08	-7.00E-08	-7.20E-08	1.60E-08	1.60E-08

Licensee Comments:

3Q/12: Changed PRA Parameter(s).

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	1/11	2/11	3/11	4/11	5/11	6/11	7/11	8/11	9/11	10/11	11/11	12/11
Maximum activity	0.000590	0.000612	0.000355	0.000362	0.000395	0.000398	0.000351	0.000572	0.000376	0.000417	0.000379	N/A
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0.1	0.1	0	0	0	0	0	0.1	0	0	0	N/A

Reactor Coolant System Activity	1/12	2/12	3/12	4/12	5/12	6/12	7/12	8/12	9/12	10/12	11/12	12/12
Maximum activity	N/A	N/A	N/A	0.000031	0.000115	0.000194	0.000221	0.000293	0.000323	0.000429	0.000299	0.000304
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	N/A	N/A	N/A	0	0	0	0	0	0	0	0	0

Licensee Comments: none

Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	1/11	2/11	3/11	4/11	5/11	6/11	7/11	8/11	9/11	10/11	11/11	12/11
Maximum leakage	0.030	0.100	0.080	0.050	0.060	0.010	0.009	0.025	0.004	0.030	0.005	N/A
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.3	1.0	0.8	0.5	0.6	0.1	0.1	0.3	0	0.3	0.1	N/A
Reactor Coolant System Leakage	1/12	2/12	3/12	4/12	5/12	6/12	7/12	8/12	9/12	10/12	11/12	12/12
Maximum leakage	N/A	N/A	0.720	0.275	0.285	0.369	0.398	0.443	0.423	0.410	0.420	0.410
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	N/A	N/A	7.2	2.8	2.9	3.7	4.0	4.4	4.2	4.1	4.2	4.1

Licensee Comments: none

Drill/Exercise Performance



Thresholds: White < 90.0% Yellow < 70.0%


Notes

Drill/Exercise Performance	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
Successful opportunities	0	69.0	92.0	9.0	0	69.0	49.0	0
Total opportunities	0	69.0	94.0	10.0	0	75.0	54.0	0
Indicator value	98.4%	98.6%	98.7%	98.5%	98.4%	97.1%	96.0%	95.4%

Licensee Comments:

3Q/11: Correction made for 3Q/2011 Successful/Total Drill Exercise & Event Opportunities

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
Participating Key personnel	83.0	88.0	105.0	95.0	93.0	94.0	93.0	93.0
Total Key personnel	83.0	88.0	105.0	95.0	93.0	94.0	93.0	93.0
Indicator value	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
Successful siren-tests	630	715	629	719	628	720	630	720
Total sirens-tests	630	720	630	720	630	720	630	720
Indicator value	99.8%	99.7%	99.7%	99.7%	99.7%	99.9%	99.9%	99.9%

Licensee Comments: none

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	1Q/11	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.