


## Saint Lucie 2

### 1Q/2013 Performance Indicators

Licensee's General Comments: none

#### Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

#### Notes

Unplanned Scrams per 7000 Critical Hrs	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13
Unplanned scrams	1.0	0	0	0	1.0	0	0	0
Critical hours	1329.1	2208.0	2209.0	2183.0	2146.2	857.1	1007.1	2159.0
<b>Indicator value</b>	<b>1.2</b>	<b>1.2</b>	<b>1.2</b>	<b>0.9</b>	<b>0.8</b>	<b>0.9</b>	<b>1.1</b>	<b>1.1</b>

Licensee Comments: none

### Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

#### Notes

Unplanned Power Changes per 7000 Critical Hrs	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13
Unplanned power changes	1.0	0	0	0	0	0	1.0	0
Critical hours	1329.1	2208.0	2209.0	2183.0	2146.2	857.1	1007.1	2159.0
<b>Indicator value</b>	<b>1.2</b>	<b>1.2</b>	<b>1.2</b>	<b>0.9</b>	<b>0</b>	<b>0</b>	<b>1.1</b>	<b>1.1</b>

Licensee Comments: none

### Unplanned Scrams with Complications




Thresholds: White > 1.0

#### Notes

Unplanned Scrams with Complications	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13
Scrams with complications	0	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>

Licensee Comments: none

### Safety System Functional Failures (PWR)




Thresholds: White > 5.0

#### Notes

Safety System Functional Failures (PWR)	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13
Safety System Functional Failures	0	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

Licensee Comments: none

### Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


#### Notes

Mitigating Systems Performance Index, Emergency AC Power System	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13
UAI ( $\Delta$ CDF)	1.63E-08	1.69E-08	1.67E-08	1.62E-08	1.52E-08	5.15E-08	5.60E-08	1.81E-08
URI ( $\Delta$ CDF)	5.17E-08	5.17E-08	5.17E-08	5.26E-08	5.35E-08	9.22E-08	7.37E-08	1.03E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	6.80E-08	6.90E-08	6.80E-08	6.90E-08	6.90E-08	1.40E-07	1.30E-07	1.20E-07

Licensee Comments:

3Q/12: Changed PRA Parameter(s).

### Mitigating Systems Performance Index, High Pressure Injection System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


#### Notes

Mitigating Systems Performance Index, High Pressure Injection System	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13
UAI ( $\Delta$ CDF)	2.86E-07	2.89E-07	3.26E-07	3.11E-07	4.29E-07	6.56E-07	5.80E-07	5.33E-07
URI ( $\Delta$ CDF)	-1.72E-07	-1.72E-07	-1.72E-07	-1.72E-07	-1.72E-07	-2.84E-07	-2.84E-07	-2.84E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	1.10E-07	1.20E-07	1.50E-07	1.40E-07	2.60E-07	3.70E-07	3.00E-07	2.50E-07

Licensee Comments:

3Q/12: Changed PRA Parameter(s).

### Mitigating Systems Performance Index, Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

#### Notes


Mitigating Systems Performance Index, Heat Removal System	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13
UAI ( $\Delta$ CDF)	1.72E-08	2.49E-08	2.91E-08	2.90E-08	1.84E-08	2.04E-08	2.19E-08	2.19E-08
URI ( $\Delta$ CDF)	-1.51E-08	-1.51E-08	-1.51E-08	-1.51E-08	-3.49E-08	-2.80E-08	-2.80E-08	-2.80E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	2.10E-09	9.80E-09	1.40E-08	1.40E-08	-1.70E-08	-7.70E-09	-6.10E-09	-6.10E-09

Licensee Comments:

3Q/12: Changed PRA Parameter(s).

2Q/11: ESF non-test demands and run-hours changed to reflect the automatic AFW actuation that occurred during the June 6, 2011 reactor trip.

### Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

#### Notes


Mitigating Systems Performance Index, Residual Heat Removal System	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13
UAI ( $\Delta$ CDF)	3.94E-10	4.29E-10	5.16E-10	-2.12E-10	-1.10E-10	-2.81E-10	-2.58E-10	-2.95E-10
URI ( $\Delta$ CDF)	-2.16E-09	-2.16E-09	-2.16E-09	-2.16E-09	-2.16E-09	-3.25E-09	-3.25E-09	-3.25E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.80E-09	-1.70E-09	-1.60E-09	-2.40E-09	-2.30E-09	-3.50E-09	-3.50E-09	-3.50E-09

Licensee Comments:

3Q/12: Changed PRA Parameter(s).



### Mitigating Systems Performance Index, Cooling Water Systems



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


#### Notes

Mitigating Systems Performance Index, Cooling Water Systems	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13
UAI ( $\Delta$ CDF)	7.98E-08	7.79E-08	7.67E-08	7.44E-08	6.05E-08	-6.11E-08	-6.08E-08	-6.08E-08
URI ( $\Delta$ CDF)	-8.37E-09	-8.37E-09	-8.37E-09	-8.37E-09	-8.37E-09	-8.83E-09	-8.83E-09	-8.83E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	7.10E-08	6.90E-08	6.80E-08	6.60E-08	5.20E-08	-7.00E-08	-7.00E-08	-7.00E-08

Licensee Comments:

3Q/12: Changed PRA Parameter(s).

### Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0

#### Notes


Reactor Coolant System Activity	4/11	5/11	6/11	7/11	8/11	9/11	10/11	11/11	12/11	1/12	2/12	3/12
Maximum activity	N/A	0.000322	0.000357	0.000294	0.000274	0.000327	0.000366	0.000341	0.000408	0.000392	0.000367	0.000370
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	N/A	0	0	0	0	0	0	0	0	0	0	0

Reactor Coolant System Activity	4/12	5/12	6/12	7/12	8/12	9/12	10/12	11/12	12/12	1/13	2/13	3/13
Maximum activity	0.000420	0.000407	0.000650	0.000604	0.000836	N/A	N/A	N/A	0.000269	0.000282	0.000299	0.000304
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0.1	0.1	0.1	N/A	N/A	N/A	0	0	0	0

Licensee Comments: none

### Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

#### Notes

Reactor Coolant System Leakage	4/11	5/11	6/11	7/11	8/11	9/11	10/11	11/11	12/11	1/12	2/12	3/12
Maximum leakage	N/A	0.070	0.002	0.001	0.050	0.002	0	0.001	0.004	0	0.013	0
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
<b>Indicator value</b>	<b>N/A</b>	<b>0.7</b>	<b>0</b>	<b>0</b>	<b>0.5</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0.1</b>	<b>0</b>
Reactor Coolant System Leakage	4/12	5/12	6/12	7/12	8/12	9/12	10/12	11/12	12/12	1/13	2/13	3/13
Maximum leakage	0.002	0.001	0	0.004	0.005	N/A	N/A	N/A	0.009	0.030	0.060	0.027
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
<b>Indicator value</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0.1</b>	<b>N/A</b>	<b>N/A</b>	<b>N/A</b>	<b>0.1</b>	<b>0.3</b>	<b>0.6</b>	<b>0.3</b>

Licensee Comments: none

### Drill/Exercise Performance



Thresholds: White < 90.0% Yellow < 70.0%


#### Notes

Drill/Exercise Performance	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13
Successful opportunities	69.0	92.0	9.0	0	69.0	49.0	0	95.0
Total opportunities	69.0	94.0	10.0	0	75.0	54.0	0	99.0
Indicator value	98.6%	98.7%	98.5%	98.4%	97.1%	96.0%	95.4%	95.5%

Licensee Comments:

3Q/11: Correction made for 3Q/2011 Successful/Total Drill Exercise & Event Opportunities

### ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

#### Notes

ERO Drill Participation	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13
Participating Key personnel	88.0	105.0	95.0	93.0	94.0	93.0	93.0	106.0
Total Key personnel	88.0	105.0	95.0	93.0	94.0	93.0	93.0	106.0
Indicator value	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

### Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

#### Notes

Alert & Notification System	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13
Successful siren-tests	715	629	719	628	720	630	720	629
Total sirens-tests	720	630	720	630	720	630	720	630
Indicator value	99.7%	99.7%	99.7%	99.7%	99.9%	99.9%	99.9%	100.0%

Licensee Comments: none

### Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

#### Notes

Occupational Exposure Control Effectiveness	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

Licensee Comments: none

### RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

#### Notes

RETS/ODCM Radiological Effluent	2Q/11	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.



 [Action Matrix Summary](#) | [Inspection Findings Summary](#) | [PI Summary](#) | [Reactor Oversight Process](#)

*Last Modified: April 23, 2013*