


Fermi 2

2Q/2013 Performance Indicators

The solid trend line represents the current reporting period.

Licensee's General Comments: PRA model updated and MSPI basis document revised in 2Q2013.

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13
Unplanned scrams	0	0	0	1.0	1.0	1.0	0	0
Critical hours	2208.0	2209.0	2042.0	1282.6	1487.1	918.6	2159.0	1880.7
Indicator value	0.9	0	0	0.9	2.0	3.7	3.6	2.2

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13
Unplanned power changes	0	1.0	0	0	0	0	0	0
Critical hours	2208.0	2209.0	2042.0	1282.6	1487.1	918.6	2159.0	1880.7
Indicator value	1.9	1.7	0.8	0.9	1.0	0	0	0

Licensee Comments: none

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

Safety System Functional Failures (BWR)



Thresholds: White > 6.0

Notes

Safety System Functional Failures (BWR)	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13
Safety System Functional Failures	0	1	0	1	0	0	1	0
Indicator value	1	2	1	2	2	1	2	1


Licensee Comments:

1Q/13: LER 13-001, Loss of Secondary Containment Function

2Q/12: LER 2012-001

4Q/11: LER 2011-01, Loss of the High Pressure Coolant Injection system due to an inoperable minimum flow valve.

Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


Notes

Mitigating Systems Performance Index, Emergency AC Power System	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13
UAI (Δ CDF)	1.40E-09	5.00E-10	-4.61E-09	-4.99E-09	-4.30E-09	-3.57E-09	-4.04E-09	-1.44E-09
URI (Δ CDF)	-3.01E-07	-2.95E-07	-2.99E-07	-3.57E-07	-3.61E-07	-3.58E-07	-3.55E-07	-3.50E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-3.00E-07	-2.90E-07	-3.00E-07	-3.60E-07	-3.60E-07	-3.60E-07	-3.60E-07	-3.60E-08

Licensee Comments:

2Q/13: Changed PRA Parameter(s). PRA model updated and MSPI basis document revised.

Mitigating Systems Performance Index, High Pressure Injection System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


Notes

Mitigating Systems Performance Index, High Pressure Injection System	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13
UAI (Δ CDF)	5.29E-09	4.06E-09	4.07E-09	4.13E-09	4.38E-09	4.49E-09	4.47E-09	3.41E-08
URI (Δ CDF)	2.01E-08	2.10E-08	1.96E-08	1.82E-08	1.65E-08	1.65E-08	1.65E-08	2.78E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	2.50E-08	2.50E-08	2.40E-08	2.20E-08	2.10E-08	2.10E-08	2.10E-08	6.20E-08

Licensee Comments:

2Q/13: Changed PRA Parameter(s). PRA model updated and MSPI basis document revised.

Mitigating Systems Performance Index, Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


Notes

Mitigating Systems Performance Index, Heat Removal System	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13
UAI (Δ CDF)	-2.37E-09	-2.37E-09	-2.37E-09	-2.73E-09	-2.72E-09	-2.72E-09	-2.72E-09	-9.25E-10
URI (Δ CDF)	-2.82E-08	-2.89E-08	-2.97E-08	-3.04E-08	-3.18E-08	-3.18E-08	-3.18E-08	-2.81E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-3.10E-08	-3.10E-08	-3.20E-08	-3.30E-08	-3.50E-08	-3.50E-08	-3.50E-08	-3.70E-09

Licensee Comments:

2Q/13: Changed PRA Parameter(s). PRA model updated and MSPI basis document revised.

Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


Notes

Mitigating Systems Performance Index, Residual Heat Removal System	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13
UAI (Δ CDF)	6.79E-09	-4.23E-09	2.75E-09	3.28E-09	4.46E-09	1.13E-08	1.20E-08	2.04E-09
URI (Δ CDF)	-1.08E-07	-1.08E-07	-1.08E-07	-1.08E-07	-1.08E-07	-1.08E-07	-1.08E-07	-4.30E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.00E-07	-1.10E-07	-1.10E-07	-1.10E-07	-1.00E-07	-9.70E-08	-9.60E-08	-2.30E-09

Licensee Comments:

2Q/13: Changed PRA Parameter(s). PRA model updated and MSPI basis document revised.

Mitigating Systems Performance Index, Cooling Water Systems



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


Notes

Mitigating Systems Performance Index, Cooling Water Systems	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13
UAI (Δ CDF)	3.83E-08	1.39E-08	2.12E-08	1.67E-08	1.84E-08	1.37E-08	1.35E-08	-1.42E-10
URI (Δ CDF)	-1.29E-08	-1.29E-08	-1.29E-08	-1.28E-08	-1.29E-08	-1.29E-08	-1.29E-08	-2.59E-10
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	2.50E-08	1.00E-09	8.30E-09	3.80E-09	5.60E-09	8.50E-10	6.50E-10	-4.00E-10

Licensee Comments:

2Q/13: Changed PRA Parameter(s). PRA model updated and MSPI basis document revised.

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	7/11	8/11	9/11	10/11	11/11	12/11	1/12	2/12	3/12	4/12	5/12	6/12
Maximum activity	0.000016	0.000011	0.000006	0.000023	0.000025	0.000027	0.000028	0.000031	0.000025	N/A	0.000028	0.000015
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	0	0	0	0	0	0	N/A	0	0

Reactor Coolant System Activity	7/12	8/12	9/12	10/12	11/12	12/12	1/13	2/13	3/13	4/13	5/13	6/13
Maximum activity	N/A	0.000015	0.000016	0.000018	0.000018	N/A	0.000021	0.000020	0.000019	0.000019	0.000021	0.000022
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	N/A	0	0	0	0	N/A	0	0	0	0	0	0

Licensee Comments: none

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Leakage	7/11	8/11	9/11	10/11	11/11	12/11	1/12	2/12	3/12	4/12	5/12	6/12
Maximum leakage	1.660	1.660	1.690	1.660	1.660	1.660	1.790	1.840	1.950	0	1.680	1.670
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	6.6	6.6	6.8	6.6	6.6	6.6	7.2	7.4	7.8	0	6.7	6.7

Reactor Coolant System Leakage	7/12	8/12	9/12	10/12	11/12	12/12	1/13	2/13	3/13	4/13	5/13	6/13
Maximum leakage	1.710	1.720	1.720	1.730	1.730	0.630	1.800	1.800	1.810	1.810	1.790	1.680
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	6.8	6.9	6.9	6.9	6.9	2.5	7.2	7.2	7.2	7.2	7.2	6.7

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13
Successful opportunities	46.0	30.0	6.0	10.0	50.0	34.0	42.0	17.0
Total opportunities	46.0	31.0	6.0	10.0	53.0	35.0	43.0	17.0
Indicator value	97.8%	97.6%	98.5%	98.8%	97.7%	97.4%	97.6%	97.5%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13
Participating Key personnel	121.0	119.0	118.0	116.0	115.0	116.0	116.0	116.0
Total Key personnel	121.0	119.0	119.0	117.0	115.0	117.0	116.0	116.0
Indicator value	100.0%	100.0%	99.2%	99.1%	100.0%	99.1%	100.0%	100.0%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13
Successful siren-tests	186	123	186	186	186	184	186	186
Total sirens-tests	186	124	186	186	186	186	186	186
Indicator value	100.0%	99.9%	99.9%	99.9%	99.9%	99.7%	99.7%	99.7%

Licensee Comments: none

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	3Q/11	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.

 [Action Matrix Summary](#) | [Inspection Findings Summary](#) | [PI Summary](#) | [Reactor Oversight Process](#)

Last Modified: August 19, 2013