


## Nine Mile Point 2

### 3Q/2013 Performance Indicators

The solid trend line represents the current reporting period.

Licensee's General Comments: none

#### Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

#### Notes

Unplanned Scrams per 7000 Critical Hrs	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
Unplanned scrams	0	0	0	1.0	0	0	0	0
Critical hours	2081.3	2183.0	834.9	2152.3	2091.9	2159.0	2184.0	2208.0
Indicator value	<b>0.8</b>	<b>0.8</b>	<b>1.0</b>	<b>1.0</b>	<b>1.0</b>	<b>1.0</b>	<b>0.8</b>	<b>0</b>

Licensee Comments: none

### Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

#### Notes

Unplanned Power Changes per 7000 Critical Hrs	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
Unplanned power changes	1.0	0	1.0	1.0	0	0	1.0	0
Critical hours	2081.3	2183.0	834.9	2152.3	2091.9	2159.0	2184.0	2208.0
<b>Indicator value</b>	<b>2.5</b>	<b>1.6</b>	<b>2.9</b>	<b>2.9</b>	<b>1.9</b>	<b>1.9</b>	<b>1.6</b>	<b>0.8</b>

Licensee Comments: none

### Unplanned Scrams with Complications




Thresholds: White > 1.0

#### Notes

Unplanned Scrams with Complications	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
Scrams with complications	0	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>

Licensee Comments: none

### Safety System Functional Failures (BWR)



Thresholds: White > 6.0

#### Notes

Safety System Functional Failures (BWR)	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
Safety System Functional Failures	1	0	0	1	0	1	1	0
<b>Indicator value</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>2</b>	<b>1</b>	<b>2</b>	<b>3</b>	<b>2</b>

Licensee Comments:


2Q/13: LER 2013-002

1Q/13: LER 2013-001

3Q/12: LER 2012-002

4Q/11: LER 2011-004

### Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

#### Notes

Mitigating Systems Performance Index, Emergency AC Power System	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
UAI ( $\Delta$ CDF)	-1.37E-08	-1.37E-08	-1.36E-08	-1.30E-08	-1.30E-08	-1.30E-08	-1.30E-08	-1.30E-08
URI ( $\Delta$ CDF)	-9.26E-08	-9.30E-08	-9.91E-08	-9.19E-08	-9.33E-08	-9.08E-08	-8.16E-08	-8.08E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.10E-07	-1.10E-07	-1.10E-07	-1.00E-07	-1.10E-07	-1.00E-07	-9.50E-08	-9.40E-08

Licensee Comments: none

### Mitigating Systems Performance Index, High Pressure Injection System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

#### Notes

Mitigating Systems Performance Index, High Pressure Injection System	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
UAI ( $\Delta$ CDF)	-6.91E-09	-1.30E-08	-9.59E-09	-7.76E-09	-1.53E-08	9.71E-09	8.63E-09	6.79E-09
URI ( $\Delta$ CDF)	-3.11E-08	-3.08E-08	-3.10E-08	-3.15E-08	-2.97E-08	-3.27E-08	-3.15E-08	-2.92E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-3.80E-08	-4.40E-08	-4.10E-08	-3.90E-08	-4.50E-08	-2.30E-08	-2.30E-08	-2.20E-08

Licensee Comments: none

### Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

#### Notes

Mitigating Systems Performance Index, Heat Removal System	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
UAI ( $\Delta$ CDF)	7.09E-09	7.07E-09	8.27E-09	7.81E-09	1.02E-08	1.20E-08	2.20E-09	2.20E-09
URI ( $\Delta$ CDF)	-2.68E-08	-2.68E-08	-2.88E-08	-2.75E-08	-2.81E-08	-2.80E-08	-2.58E-08	-2.52E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-2.00E-08	-2.00E-08	-2.00E-08	-2.00E-08	-1.80E-08	-1.60E-08	-2.40E-08	-2.30E-08

Licensee Comments: none

### Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


#### Notes

Mitigating Systems Performance Index, Residual Heat Removal System	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
UAI ( $\Delta$ CDF)	-7.74E-09	-7.74E-09	-7.74E-09	-1.06E-08	-1.06E-08	-5.78E-09	-5.92E-09	-5.92E-09
URI ( $\Delta$ CDF)	-1.28E-08	-1.28E-08	-1.52E-08	-2.08E-08	-2.13E-08	-2.16E-08	-1.89E-08	-1.86E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-2.00E-08	-2.10E-08	-2.30E-08	-3.10E-08	-3.20E-08	-2.70E-08	-2.50E-08	-2.40E-08

Licensee Comments: none



### Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

#### Notes

Mitigating Systems Performance Index, Cooling Water Systems	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
UAI ( $\Delta$ CDF)	2.76E-09	2.76E-09	2.96E-09	3.51E-09	3.39E-09	3.38E-09	2.69E-09	-7.95E-10
URI ( $\Delta$ CDF)	-1.14E-08	-1.15E-08	-1.22E-08	-1.23E-08	-1.22E-08	-1.24E-08	1.66E-08	1.62E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-8.60E-09	-8.70E-09	-9.20E-09	-8.80E-09	-8.90E-09	-9.00E-09	1.90E-08	1.50E-08

Licensee Comments: none

### Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0

#### Notes


Reactor Coolant System Activity	10/11	11/11	12/11	1/12	2/12	3/12	4/12	5/12	6/12	7/12	8/12	9/12
Maximum activity	0.000067	0.000070	0.000070	0.000072	0.000071	0.000076	0.000073	N/A	N/A	0.000022	0.000032	0.000029
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	0	0	0	0	N/A	N/A	0	0	0

Reactor Coolant System Activity	10/12	11/12	12/12	1/13	2/13	3/13	4/13	5/13	6/13	7/13	8/13	9/13
Maximum activity	0.000023	0.000022	0.000024	0.000023	0.000033	0.000029	0.000028	0.000028	0.000024	0.000020	0.000017	0.000024
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Licensee Comments: none

### Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

#### Notes

Reactor Coolant System Leakage	10/11	11/11	12/11	1/12	2/12	3/12	4/12	5/12	6/12	7/12	8/12	9/12
Maximum leakage	2.744	2.779	2.679	2.701	2.685	2.651	2.621	N/A	2.753	2.714	2.654	2.633
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	11.0	11.1	10.7	10.8	10.7	10.6	10.5	N/A	11.0	10.9	10.6	10.5
Reactor Coolant System Leakage	10/12	11/12	12/12	1/13	2/13	3/13	4/13	5/13	6/13	7/13	8/13	9/13
Maximum leakage	2.631	2.628	2.632	2.611	2.610	2.712	2.660	2.597	2.610	2.667	2.653	2.757
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	10.5	10.5	10.5	10.4	10.4	10.8	10.6	10.4	10.4	10.7	10.6	11.0

Licensee Comments: none

### Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

#### Notes

Drill/Exercise Performance	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
Successful opportunities	60.0	37.0	3.0	79.0	60.0	25.0	44.0	34.0
Total opportunities	61.0	38.0	3.0	85.0	61.0	25.0	48.0	37.0
Indicator value	98.9%	98.8%	98.8%	97.1%	97.2%	97.1%	96.3%	95.5%

Licensee Comments: none

### ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

#### Notes

ERO Drill Participation	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
Participating Key personnel	90.0	88.0	83.0	86.0	84.0	87.0	85.0	82.0
Total Key personnel	90.0	88.0	83.0	86.0	84.0	87.0	85.0	82.0
Indicator value	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

### Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

#### Notes

Alert & Notification System	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
Successful siren-tests	295	222	296	222	333	222	293	221
Total sirens-tests	296	222	296	222	333	222	296	222
Indicator value	99.7%	99.7%	99.8%	99.9%	100.0%	100.0%	99.7%	99.6%

Licensee Comments: none

### Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

#### Notes

Occupational Exposure Control Effectiveness	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

Licensee Comments: none

### RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

#### Notes

RETS/ODCM Radiological Effluent	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.



 [Action Matrix Summary](#) | [Inspection Findings Summary](#) | [PI Summary](#) | [Reactor Oversight Process](#)

*Last Modified: October 22, 2013*