


Watts Bar 1

3Q/2013 Performance Indicators

The solid trend line represents the current reporting period.

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
Unplanned scrams	0	0	0	1.0	0	0	1.0	0
Critical hours	2058.5	2183.0	2184.0	1667.4	1559.8	2159.0	2144.0	2208.0
Indicator value	0.9	0.9	0	0.9	0.9	0.9	1.9	0.9

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
Unplanned power changes	0	0	0	0	1.0	0	0	0
Critical hours	2058.5	2183.0	2184.0	1667.4	1559.8	2159.0	2144.0	2208.0
Indicator value	1.9	1.9	0.8	0	0.9	0.9	0.9	0.9

Licensee Comments: none

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

Safety System Functional Failures (PWR)



Thresholds: White > 5.0


Notes

Safety System Functional Failures (PWR)	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
Safety System Functional Failures	0	0	0	1	0	0	2	0
Indicator value	0	0	0	1	1	1	3	2

Licensee Comments:

3Q/12: LER 2012-002 (B) Remove residual heat If the probable maximum flood level had occurred while raw water was required for shutdown cooling then WBNs ability to remove residual heat would have been lost; therefore, this is a reported as a safety system functional failure.

Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes


Mitigating Systems Performance Index, Emergency AC Power System	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
UAI (Δ CDF)	9.20E-07	9.10E-07	7.44E-07	7.16E-07	7.53E-07	1.05E-06	1.00E-06	1.00E-06
URI (Δ CDF)	-2.58E-06	-3.06E-06	-3.03E-06	-2.94E-06	-2.93E-06	-2.91E-06	-2.88E-06	-2.85E-06
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.70E-06	-2.10E-06	-2.30E-06	-2.20E-06	-2.20E-06	-1.90E-06	-1.90E-06	-1.80E-06

Licensee Comments:

4Q/11: Risk Cap Invoked.

4Q/11: Risk Cap Invoked.

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
UAI (Δ CDF)	-5.92E-08	-5.94E-08	-5.87E-08	-5.85E-08	-5.03E-08	-5.81E-08	-5.79E-08	-5.76E-08
URI (Δ CDF)	-1.39E-08	-1.40E-08	-1.42E-08	-1.43E-08	-1.45E-08	-1.46E-08	-1.48E-08	-1.49E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-7.30E-08	-7.30E-08	-7.30E-08	-7.30E-08	-6.50E-08	-7.30E-08	-7.30E-08	-7.20E-08

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
UAI (Δ CDF)	4.71E-07	4.68E-07	4.27E-07	4.48E-07	4.85E-07	2.31E-07	2.31E-07	2.66E-07
URI (Δ CDF)	-3.78E-07	-3.78E-07	-3.78E-07	-3.82E-07	-3.82E-07	-3.82E-07	-5.46E-07	-5.40E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	9.30E-08	9.00E-08	4.90E-08	6.60E-08	1.00E-07	-1.50E-07	-3.10E-07	-2.70E-07

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
UAI (Δ CDF)	4.06E-08	4.17E-08	3.83E-08	3.72E-08	3.20E-08	2.75E-08	2.64E-08	1.90E-08
URI (Δ CDF)	-4.20E-08	-4.24E-08	-4.28E-08	-4.32E-08	-4.36E-08	-4.40E-08	-4.44E-08	-4.48E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.40E-09	-7.80E-10	-4.50E-09	-6.00E-09	-1.20E-08	-1.60E-08	-1.80E-08	-2.60E-08

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


Notes

Mitigating Systems Performance Index, Cooling Water Systems	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
UAI (Δ CDF)	4.08E-08	3.92E-08	1.63E-07	1.65E-07	1.75E-07	1.92E-07	2.11E-07	2.10E-07
URI (Δ CDF)	-4.85E-08	-4.85E-08	-4.85E-08	-4.85E-08	-4.85E-08	-4.85E-08	6.04E-09	6.04E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-7.70E-09	-9.30E-09	1.10E-07	1.20E-07	1.30E-07	1.40E-07	2.20E-07	2.20E-07

Licensee Comments:

3Q/12: Change July 2011 MSPI value for G-B ERCW pump from planned to unplanned hours of 52.33.

Reactor Coolant System Activity




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Activity	10/11	11/11	12/11	1/12	2/12	3/12	4/12	5/12	6/12	7/12	8/12	9/12
Maximum activity	0.000358	0.000360	0.000388	0.000401	0.000405	0.000417	0.000434	0.000442	0.000450	0.000466	0.000480	0.000491
Technical specification limit	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3
Indicator value	0.1	0.1	0.1	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Reactor Coolant System Activity	10/12	11/12	12/12	1/13	2/13	3/13	4/13	5/13	6/13	7/13	8/13	9/13
Maximum activity	N/A	0.000149	0.000160	0.000169	0.000171	0.000179	0.000196	0.000217	0.000211	0.000221	0.000222	0.000212
Technical specification limit	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3
Indicator value	N/A	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1

Licensee Comments: none

Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	10/11	11/11	12/11	1/12	2/12	3/12	4/12	5/12	6/12	7/12	8/12	9/12
Maximum leakage	0.020	0.020	0.010	0.010	0.010	0.020	0.010	0.020	0.020	0.020	0.020	0.020
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.2	0.2	0.1	0.1	0.1	0.2	0.1	0.2	0.2	0.2	0.2	0.2
Reactor Coolant System Leakage	10/12	11/12	12/12	1/13	2/13	3/13	4/13	5/13	6/13	7/13	8/13	9/13
Maximum leakage	N/A	0.040	0.050	0.030	0.030	0.050	0.030	0.030	0.040	0.040	0.040	0.030
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	N/A	0.4	0.5	0.3	0.3	0.5	0.3	0.3	0.4	0.4	0.4	0.3

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
Successful opportunities	64.0	35.0	25.0	1.0	44.0	30.0	49.0	63.0
Total opportunities	67.0	35.0	26.0	2.0	44.0	30.0	50.0	64.0
Indicator value	97.0%	97.5%	98.5%	97.9%	98.1%	98.1%	98.1%	97.8%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
Participating Key personnel	70.0	69.0	71.0	69.0	72.0	75.0	73.0	72.0
Total Key personnel	70.0	69.0	71.0	69.0	72.0	75.0	73.0	72.0
Indicator value	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
Successful siren-tests	790	787	787	789	692	887	792	897
Total sirens-tests	792	792	790	792	693	890	792	899
Indicator value	99.7%	99.5%	99.6%	99.6%	99.6%	99.7%	99.8%	99.8%

Licensee Comments: none

Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	4Q/11	1Q/12	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.

 [Action Matrix Summary](#) | [Inspection Findings Summary](#) | [PI Summary](#) | [Reactor Oversight Process](#)

Last Modified: October 22, 2013