


Calvert Cliffs 2

1Q/2014 Performance Indicators

The solid trend line represents the current reporting period.

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
Unplanned scrams	0	0	0	0	2.0	0	0	1.0
Critical hours	2184.0	2208.0	2209.0	1323.2	2076.8	2104.1	2209.0	2079.5
Indicator value	0	0	0	0	1.8	1.8	1.8	2.5

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
Unplanned power changes	0	0	0	0	0	1.0	0	0
Critical hours	2184.0	2208.0	2209.0	1323.2	2076.8	2104.1	2209.0	2079.5
Indicator value	1.6	1.6	0.8	0	0	0.9	0.9	0.8

Licensee Comments: none

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
Scrams with complications	0	0	0	0	0	0	0	1.0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0

Licensee Comments: none

Safety System Functional Failures (PWR)




Thresholds: White > 5.0

Notes

Safety System Functional Failures (PWR)	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
Safety System Functional Failures	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
UAI (Δ CDF)	6.53E-08	6.38E-08	8.52E-08	3.93E-08	4.49E-08	3.19E-08	1.31E-08	2.19E-08
URI (Δ CDF)	-7.29E-08	-6.91E-08	-6.22E-08	-1.38E-07	-1.35E-07	-1.39E-07	-1.35E-07	-1.27E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-7.60E-09	-5.30E-09	2.30E-08	-9.80E-08	-9.00E-08	-1.10E-07	-1.20E-07	-1.10E-07

Licensee Comments: none

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
UAI (ΔCDF)	5.53E-08	6.19E-08	4.62E-08	5.50E-08	6.62E-08	6.30E-08	9.11E-08	2.81E-08
URI (ΔCDF)	1.11E-07	1.12E-07	1.09E-07	9.58E-08	9.47E-08	9.20E-08	8.87E-08	-4.60E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	1.70E-07	1.70E-07	1.60E-07	1.50E-07	1.60E-07	1.50E-07	1.80E-07	-1.80E-08

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
UAI (Δ CDF)	-8.59E-10	-8.25E-10	-7.43E-10	-2.88E-09	-2.44E-09	-3.08E-09	-2.04E-09	-2.70E-09
URI (Δ CDF)	-1.03E-08	-1.02E-08	-1.02E-08	-1.06E-08	-1.06E-08	-1.04E-08	-1.08E-08	-1.03E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.10E-08	-1.10E-08	-1.10E-08	-1.40E-08	-1.30E-08	-1.30E-08	-1.30E-08	-1.30E-08

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
UAI (Δ CDF)	-4.10E-08	-3.45E-08	9.07E-08	7.29E-08	1.19E-07	1.58E-07	9.51E-08	8.99E-08
URI (Δ CDF)	-4.62E-09	-4.47E-09	1.39E-09	-1.28E-10	-1.54E-10	-3.66E-10	-1.79E-10	9.79E-10
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-4.60E-08	-3.90E-08	9.20E-08	7.30E-08	1.20E-07	1.60E-07	9.50E-08	9.10E-08

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
UAI (Δ CDF)	8.44E-08	9.11E-08	9.61E-08	1.51E-07	1.77E-07	9.51E-08	5.06E-08	2.64E-08
URI (Δ CDF)	-2.38E-07	-2.38E-07	-2.38E-07	-2.38E-07	-2.38E-07	-2.38E-07	-2.38E-07	-2.38E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.50E-07	-1.50E-07	-1.40E-07	-8.70E-08	-6.10E-08	-1.40E-07	-1.90E-07	-2.10E-07

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	4/12	5/12	6/12	7/12	8/12	9/12	10/12	11/12	12/12	1/13	2/13	3/13
Maximum activity	0.001310	0.001780	0.001430	0.001370	0.001400	0.001460	0.001550	0.001540	0.001590	0.001660	0.001760	0.000316
Technical specification limit	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
Indicator value	0.3	0.4	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.4	0.1

Reactor Coolant System Activity	4/13	5/13	6/13	7/13	8/13	9/13	10/13	11/13	12/13	1/14	2/14	3/14
Maximum activity	0.000536	0.000257	0.000617	0.000583	0.000645	0.000693	0.000725	0.000610	0.000586	0.000682	0.000681	0.000758
Technical specification limit	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
Indicator value	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2

Licensee Comments: none

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0

Notes


Reactor Coolant System Leakage	4/12	5/12	6/12	7/12	8/12	9/12	10/12	11/12	12/12	1/13	2/13	3/13
Maximum leakage	0.090	0.100	0.120	0.130	0.150	0.150	0.170	0.170	0.160	0.210	0	0
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.9	1.0	1.2	1.3	1.5	1.5	1.7	1.7	1.6	2.1	0	0

Reactor Coolant System Leakage	4/13	5/13	6/13	7/13	8/13	9/13	10/13	11/13	12/13	1/14	2/14	3/14
Maximum leakage	0	0	0	0	0	0	0.060	0.050	0.060	0.060	0.060	0.070
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0	0	0	0	0	0	0.6	0.5	0.6	0.6	0.6	0.7

Licensee Comments:

6/12: CR-2012-009203. There was conflicting direction in station procedure vs. NEI and TS definitions for RCS Leakage. The corrected method to determine leakage relies exclusively on the NEI TS. 01/04/2013.

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
Successful opportunities	25.0	12.0	67.0	2.0	32.0	53.0	61.0	4.0
Total opportunities	25.0	13.0	68.0	2.0	32.0	54.0	64.0	4.0
Indicator value	98.1%	98.0%	98.1%	98.1%	98.3%	98.0%	97.7%	97.7%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
Participating Key personnel	80.0	83.0	84.0	79.0	79.0	80.0	86.0	50.0
Total Key personnel	80.0	83.0	84.0	79.0	79.0	80.0	86.0	50.0
Indicator value	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
Successful siren-tests	948	945	1016	871	948	971	947	943
Total sirens-tests	949	949	1022	876	949	972	949	949
Indicator value	98.3%	99.7%	99.7%	99.6%	99.6%	99.7%	99.8%	99.7%

Licensee Comments: none

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.

 [Action Matrix Summary](#) | [Inspection Findings Summary](#) | [PI Summary](#) | [Reactor Oversight Process](#)

Last Modified: April 23, 2014