


Nine Mile Point 2

1Q/2014 Performance Indicators

The solid trend line represents the current reporting period.

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
Unplanned scrams	0	1.0	0	0	0	0	1.0	2.0
Critical hours	834.9	2152.3	2091.9	2159.0	2184.0	2208.0	2089.7	1879.9
Indicator value	1.0	1.0	1.0	1.0	0.8	0	0.8	2.5

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
Unplanned power changes	1.0	1.0	0	0	1.0	0	1.0	0
Critical hours	834.9	2152.3	2091.9	2159.0	2184.0	2208.0	2089.7	1879.9
Indicator value	2.9	2.9	1.9	1.9	1.6	0.8	1.6	1.7

Licensee Comments: none

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

Safety System Functional Failures (BWR)



Thresholds: White > 6.0

Notes

Safety System Functional Failures (BWR)	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
Safety System Functional Failures	0	1	0	1	1	0	0	0
Indicator value	1	2	1	2	3	2	2	1


Licensee Comments:

2Q/13: LER 2013-002

1Q/13: LER 2013-001

3Q/12: LER 2012-002

Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
UAI (Δ CDF)	-1.36E-08	-1.30E-08	-1.30E-08	-1.30E-08	-1.30E-08	-1.30E-08	-1.30E-08	-1.30E-08
URI (Δ CDF)	-9.91E-08	-9.19E-08	-9.33E-08	-9.08E-08	-8.16E-08	-8.08E-08	-7.43E-08	-7.86E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.10E-07	-1.00E-07	-1.10E-07	-1.00E-07	-9.50E-08	-9.40E-08	-8.70E-08	-9.20E-08

Licensee Comments: none

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
UAI (Δ CDF)	-9.59E-09	-7.76E-09	-1.53E-08	9.71E-09	8.63E-09	6.79E-09	3.84E-08	1.80E-08
URI (Δ CDF)	-3.10E-08	-3.15E-08	-2.97E-08	-3.27E-08	-3.15E-08	-2.92E-08	-2.70E-08	-2.64E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-4.10E-08	-3.90E-08	-4.50E-08	-2.30E-08	-2.30E-08	-2.20E-08	1.10E-08	-8.30E-09

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
UAI (Δ CDF)	8.27E-09	7.81E-09	1.02E-08	1.20E-08	2.20E-09	2.20E-09	-3.46E-09	-3.34E-09
URI (Δ CDF)	-2.88E-08	-2.75E-08	-2.81E-08	-2.80E-08	-2.58E-08	-2.52E-08	-2.33E-08	-2.33E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-2.00E-08	-2.00E-08	-1.80E-08	-1.60E-08	-2.40E-08	-2.30E-08	-2.70E-08	-2.70E-08

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
UAI (Δ CDF)	-7.74E-09	-1.06E-08	-1.06E-08	-5.78E-09	-5.92E-09	-5.92E-09	-5.90E-09	-5.84E-09
URI (Δ CDF)	-1.52E-08	-2.08E-08	-2.13E-08	-2.16E-08	-1.89E-08	-1.86E-08	-1.90E-08	-2.00E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-2.30E-08	-3.10E-08	-3.20E-08	-2.70E-08	-2.50E-08	-2.40E-08	-2.50E-08	-2.60E-08

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
UAI (Δ CDF)	2.96E-09	3.51E-09	3.39E-09	3.38E-09	2.69E-09	-7.95E-10	-7.94E-10	-7.93E-10
URI (Δ CDF)	-1.22E-08	-1.23E-08	-1.22E-08	-1.24E-08	1.66E-08	1.62E-08	1.72E-08	1.69E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-9.20E-09	-8.80E-09	-8.90E-09	-9.00E-09	1.90E-08	1.50E-08	1.60E-08	1.60E-08

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0

Notes


Reactor Coolant System Activity	4/12	5/12	6/12	7/12	8/12	9/12	10/12	11/12	12/12	1/13	2/13	3/13
Maximum activity	0.000073	N/A	N/A	0.000022	0.000032	0.000029	0.000023	0.000022	0.000024	0.000023	0.000033	0.000029
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	N/A	N/A	0	0	0	0	0	0	0	0	0

Reactor Coolant System Activity	4/13	5/13	6/13	7/13	8/13	9/13	10/13	11/13	12/13	1/14	2/14	3/14
Maximum activity	0.000028	0.000028	0.000024	0.000020	0.000017	0.000024	0.000028	0.000024	0.000027	0.000025	0.000023	N/A
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	0	0	0	0	0	0	0	0	N/A

Licensee Comments:

3/14: There was no data meeting the criteria for specific activity in March 2014.

Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	4/12	5/12	6/12	7/12	8/12	9/12	10/12	11/12	12/12	1/13	2/13	3/13
Maximum leakage	2.621	N/A	2.753	2.714	2.654	2.633	2.631	2.628	2.632	2.611	2.610	2.712
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	10.5	N/A	11.0	10.9	10.6	10.5	10.5	10.5	10.5	10.4	10.4	10.8
Reactor Coolant System Leakage	4/13	5/13	6/13	7/13	8/13	9/13	10/13	11/13	12/13	1/14	2/14	3/14
Maximum leakage	2.660	2.597	2.610	2.667	2.653	2.757	2.783	2.677	2.633	2.636	2.660	2.637
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	10.6	10.4	10.4	10.7	10.6	11.0	11.1	10.7	10.5	10.5	10.6	10.5

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
Successful opportunities	3.0	79.0	60.0	25.0	44.0	34.0	53.0	34.0
Total opportunities	3.0	85.0	61.0	25.0	48.0	37.0	54.0	36.0
Indicator value	98.8%	97.1%	97.2%	97.1%	96.3%	95.5%	95.4%	95.1%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
Participating Key personnel	83.0	86.0	84.0	87.0	85.0	82.0	77.0	79.0
Total Key personnel	83.0	86.0	84.0	87.0	85.0	82.0	77.0	79.0
Indicator value	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
Successful siren-tests	296	222	333	222	293	221	333	221
Total sirens-tests	296	222	333	222	296	222	333	222
Indicator value	99.8%	99.9%	100.0%	100.0%	99.7%	99.6%	99.6%	99.5%

Licensee Comments: none

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.

 [Action Matrix Summary](#) | [Inspection Findings Summary](#) | [PI Summary](#) | [Reactor Oversight Process](#)

Last Modified: April 23, 2014