


## Summer

### 1Q/2014 Performance Indicators

The solid trend line represents the current reporting period.

Licensee's General Comments: none

#### Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

#### Notes

Unplanned Scrams per 7000 Critical Hrs	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
Unplanned scrams	0	0	0	0	0	0	0	0
Critical hours	2184.0	2208.0	915.7	1944.9	2157.1	2208.0	2209.0	2159.0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

### Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

#### Notes

Unplanned Power Changes per 7000 Critical Hrs	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
Unplanned power changes	0	0	0	0	0	0	0	0
Critical hours	2184.0	2208.0	915.7	1944.9	2157.1	2208.0	2209.0	2159.0
<b>Indicator value</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

Licensee Comments: none

### Unplanned Scrams with Complications




Thresholds: White > 1.0

#### Notes

Unplanned Scrams with Complications	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
Scrams with complications	0	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>

Licensee Comments: none

### Safety System Functional Failures (PWR)




Thresholds: White > 5.0

#### Notes

Safety System Functional Failures (PWR)	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
Safety System Functional Failures	0	0	0	0	0	1	0	0
<b>Indicator value</b>	<b>2</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>1</b>	<b>1</b>	<b>1</b>

Licensee Comments: none

### Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

#### Notes

Mitigating Systems Performance Index, Emergency AC Power System	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
UAI (ΔCDF)	-9.69E-08	1.67E-07	2.75E-08	1.94E-08	1.94E-08	3.39E-08	3.39E-08	3.38E-08
URI (ΔCDF)	-6.60E-07	4.54E-07	4.91E-07	-7.19E-09	-7.19E-09	-7.19E-09	-7.19E-09	-7.19E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-7.60E-07	6.20E-07	5.20E-07	1.20E-08	1.20E-08	2.70E-08	2.70E-08	2.70E-08

#### Licensee Comments:


1Q/14: 3/5/2014 "A" DG was taken out of service for 36 hours 26 minutes for maintenance & repairs. 3/16/2014 - "B" DG taken out of service 140 hours 39 minutes for overhaul. 3/23/2014 - "B" DG taken out of service for 2 hours 2 minutes for Rocker Arm LO Filter replacement

4Q/12: Risk Cap Invoked.

3Q/12: Risk Cap Invoked. 8/24/2012 - "A" DG Start/Demand Failure due to "A" DG exciter failed to flash. 63.1 hours of unplanned unavailability were accrued. CR-12-03599 9/19/2012 - "A" DG Start/Demand Failure due to "A" DG exciter failed to flash. 111.3 hours of unplanned unavailability were accrued. CR-12-03998 Revised PRA parameters, to take affect 10/1/2012, to credit Alternate Reactor Coolant Pump Seal Injection system plant modification to mitigate an Reactor Coolant Pump seal LOCA brought on by loss of offsite power.

2Q/12: Risk Cap Invoked.

### Mitigating Systems Performance Index, High Pressure Injection System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


#### Notes

Mitigating Systems Performance Index, High Pressure Injection System	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
UAI ( $\Delta$ CDF)	-7.06E-09	-7.06E-09	-2.14E-09	-2.33E-09	-2.33E-09	-2.33E-09	-2.33E-09	-2.33E-09
URI ( $\Delta$ CDF)	9.43E-08	9.43E-08	2.04E-09	2.17E-09	2.17E-09	2.17E-09	2.17E-09	2.17E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	8.70E-08	8.70E-08	-9.80E-11	-1.50E-10	-1.50E-10	-1.50E-10	-1.50E-10	-1.60E-10

Licensee Comments:

3Q/12: Revised PRA parameters, to take affect 10/1/2012, to credit Alternate Reactor Coolant Pump Seal Injection system plant modification to mitigate an Reactor Coolant Pump seal LOCA brought on by loss of offsite power.

### Mitigating Systems Performance Index, Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


#### Notes

Mitigating Systems Performance Index, Heat Removal System	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
UAI ( $\Delta$ CDF)	-2.11E-08	-1.97E-08	-2.03E-08	-1.38E-08	-1.39E-08	-1.41E-08	-1.45E-08	-1.23E-08
URI ( $\Delta$ CDF)	-1.17E-07	-1.17E-07	-1.23E-07	-1.55E-07	-1.55E-07	-1.55E-07	-1.55E-07	-1.55E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.40E-07	-1.40E-07	-1.40E-07	-1.70E-07	-1.70E-07	-1.70E-07	-1.70E-07	-1.70E-07

Licensee Comments:

3Q/12: Revised PRA parameters, to take affect 10/1/2012, to credit Alternate Reactor Coolant Pump Seal Injection system plant modification to mitigate an Reactor Coolant Pump seal LOCA brought on by loss of offsite power.

### Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

#### Notes


Mitigating Systems Performance Index, Residual Heat Removal System	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
UAI ( $\Delta$ CDF)	-4.49E-09	-4.49E-09	-3.00E-09	-3.21E-09	-3.21E-09	-3.22E-09	-8.66E-09	-8.66E-09
URI ( $\Delta$ CDF)	1.01E-07	1.01E-07	7.68E-08	8.08E-08	8.08E-08	8.08E-08	-6.66E-08	-6.66E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	9.70E-08	9.70E-08	7.40E-08	7.80E-08	7.80E-08	7.80E-08	-7.50E-08	-7.50E-08

#### Licensee Comments:

3Q/12: Revised PRA parameters, to take affect 10/1/2012, to credit Alternate Reactor Coolant Pump Seal Injection system plant modification to mitigate an Reactor Coolant Pump seal LOCA brought on by loss of offsite power.



### Mitigating Systems Performance Index, Cooling Water Systems



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


#### Notes

Mitigating Systems Performance Index, Cooling Water Systems	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
UAI ( $\Delta$ CDF)	-2.78E-08	-2.78E-08	-8.34E-09	-6.98E-09	-6.98E-09	-6.98E-09	-6.98E-09	-6.98E-09
URI ( $\Delta$ CDF)	-2.58E-07	-2.58E-07	-5.85E-08	-4.66E-08	-4.66E-08	-4.66E-08	-4.66E-08	-4.66E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-2.90E-07	-2.90E-07	-6.70E-08	-5.40E-08	-5.40E-08	-5.40E-08	-5.40E-08	-5.40E-08

#### Licensee Comments:

3Q/12: Revised PRA parameters, to take affect 10/1/2012, to credit Alternate Reactor Coolant Pump Seal Injection system plant modification to mitigate an Reactor Coolant Pump seal LOCA brought on by loss of offsite power.

### Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0

#### Notes

Reactor Coolant System Activity	4/12	5/12	6/12	7/12	8/12	9/12	10/12	11/12	12/12	1/13	2/13	3/13
Maximum activity	0.000171	0.000173	0.000179	0.000183	0.000185	0.000190	0.000199	N/A	0.000096	0.000095	0.000094	0.000095
Technical specification limit	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
Indicator value	0.3	0.3	0.3	0.3	0.3	0.3	0.3	N/A	0.2	0.2	0.2	0.2


  

Reactor Coolant System Activity	4/13	5/13	6/13	7/13	8/13	9/13	10/13	11/13	12/13	1/14	2/14	3/14
Maximum activity	0.000102	0.000098	0.000111	0.000116	0.000206	0.000121	0.000124	0.000122	0.000125	0.000136	0.000141	0.000147
Technical specification limit	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
Indicator value	0.2	0.2	0.2	0.2	0.3	0.2	0.2	0.2	0.2	0.2	0.2	0.2

Licensee Comments:

12/12: The plant was shutdown for a scheduled refueling outage for the entire month of November 2012.

### Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0


#### Notes

Reactor Coolant System Leakage	4/12	5/12	6/12	7/12	8/12	9/12	10/12	11/12	12/12	1/13	2/13	3/13
Maximum leakage	0.090	0.100	0.090	0.070	0.050	0.060	0.090	N/A	0.070	0.310	0.460	0.690
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	<b>0.9</b>	<b>1.0</b>	<b>0.9</b>	<b>0.7</b>	<b>0.5</b>	<b>0.6</b>	<b>0.9</b>	<b>N/A</b>	<b>0.7</b>	<b>3.1</b>	<b>4.6</b>	<b>6.9</b>
Reactor Coolant System Leakage	4/13	5/13	6/13	7/13	8/13	9/13	10/13	11/13	12/13	1/14	2/14	3/14
Maximum leakage	0.050	0.040	0.050	0.040	0.020	0.040	0.030	0.020	0.020	0.040	0.030	0.040
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	<b>0.5</b>	<b>0.4</b>	<b>0.5</b>	<b>0.4</b>	<b>0.2</b>	<b>0.4</b>	<b>0.3</b>	<b>0.2</b>	<b>0.2</b>	<b>0.4</b>	<b>0.3</b>	<b>0.4</b>

Licensee Comments:

12/12: The plant was shutdown for a scheduled refueling outage for the entire month of November 2012.

### Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

#### Notes

Drill/Exercise Performance	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
Successful opportunities	56.0	43.0	16.0	30.0	88.0	62.0	45.0	34.0
Total opportunities	56.0	44.0	16.0	32.0	90.0	63.0	45.0	34.0
Indicator value	96.7%	96.9%	97.1%	96.7%	97.1%	97.5%	97.5%	98.4%

Licensee Comments: none

### ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

#### Notes

ERO Drill Participation	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
Participating Key personnel	75.0	74.0	75.0	75.0	75.0	78.0	82.0	85.0
Total Key personnel	75.0	74.0	75.0	75.0	76.0	80.0	82.0	85.0
Indicator value	100.0%	100.0%	100.0%	100.0%	98.7%	97.5%	100.0%	100.0%

Licensee Comments: none

### Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

#### Notes

Alert & Notification System	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
Successful siren-tests	742	847	848	741	742	847	842	741
Total sirens-tests	742	848	848	742	742	848	848	742
Indicator value	99.8%	99.9%	99.9%	99.9%	99.9%	99.9%	99.7%	99.7%

Licensee Comments: none

### Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

#### Notes

Occupational Exposure Control Effectiveness	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

Licensee Comments: none

### RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

#### Notes

RETS/ODCM Radiological Effluent	2Q/12	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.



 [Action Matrix Summary](#) | [Inspection Findings Summary](#) | [PI Summary](#) | [Reactor Oversight Process](#)

*Last Modified: April 23, 2014*