


Oyster Creek

2Q/2014 Performance Indicators

The solid trend line represents the current reporting period.

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
Unplanned scrams	1.0	0	0	0	0	3.0	0	0
Critical hours	2127.8	1278.7	2159.0	2184.0	2202.0	1900.2	2159.0	2184.0
Indicator value	0.8	0.9	0.9	0.9	0	2.5	2.5	2.5

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
Unplanned power changes	0	0	0	2.0	0	0	0	0
Critical hours	2127.8	1278.7	2159.0	2184.0	2202.0	1900.2	2159.0	2184.0
Indicator value	0	0	0	1.8	1.8	1.7	1.7	0

Licensee Comments: none

Unplanned Scrams with Complications



Thresholds: White > 1.0


Notes

Unplanned Scrams with Complications	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
Scrams with complications	1.0	0	0	0	0	1.0	0	0
Indicator value	1.0	1.0	1.0	1.0	0.0	1.0	1.0	1.0

Licensee Comments:

3Q/12: After a peer review during the FAQ process, it was determined that this event should be counted as a Scram with complications.

Safety System Functional Failures (BWR)




Thresholds: White > 6.0

Notes

Safety System Functional Failures (BWR)	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
Safety System Functional Failures	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
UAI (Δ CDF)	-7.40E-10	-3.17E-08	-4.12E-08	-5.09E-08	-5.44E-08	4.87E-09	7.06E-10	5.41E-08
URI (Δ CDF)	-5.32E-07	-5.38E-07	-5.32E-07	-5.22E-07	-5.18E-07	-5.10E-07	-5.04E-07	-4.97E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-5.30E-07	-5.70E-07	-5.70E-07	-5.70E-07	-5.70E-07	-5.00E-07	-5.00E-07	-4.40E-07

Licensee Comments: none

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
UAI (Δ CDF)	-1.50E-08	-1.65E-08	-2.07E-08	-1.46E-08	-1.76E-08	-1.69E-08	-2.01E-08	-2.01E-08
URI (Δ CDF)	-1.19E-09	-1.19E-09	-1.19E-09	-1.19E-09	-1.19E-09	-1.19E-09	-1.19E-09	-1.19E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.60E-08	-1.80E-08	-2.20E-08	-1.60E-08	-1.90E-08	-1.80E-08	-2.10E-08	-2.10E-08

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > $1.00E-6$ Yellow > $1.00E-5$ Red > $1.00E-4$

Notes

Mitigating Systems Performance Index, Heat Removal System	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
UAI (Δ CDF)	$4.93E-11$	$-6.48E-11$	$9.05E-10$	$1.08E-09$	$1.04E-09$	$1.53E-09$	$1.73E-09$	$1.49E-09$
URI (Δ CDF)	$-9.81E-11$	$-9.89E-11$	$-9.97E-11$	$-9.81E-11$	$-9.89E-11$	$-9.81E-11$	$-9.89E-11$	$-9.89E-11$
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	$-4.90E-11$	$-1.60E-10$	$8.00E-10$	$9.80E-10$	$9.40E-10$	$1.40E-09$	$1.60E-09$	$1.40E-09$

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
UAI (ΔCDF)	7.88E-09	1.34E-08	1.03E-08	7.19E-09	7.37E-09	7.82E-09	9.19E-09	1.34E-08
URI (ΔCDF)	-1.29E-11	-1.29E-11	-1.29E-11	-1.27E-11	-1.36E-11	-1.36E-11	-1.37E-11	-1.38E-11
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	7.90E-09	1.30E-08	1.00E-08	7.20E-09	7.40E-09	7.80E-09	9.20E-09	1.30E-08

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
UAI (Δ CDF)	8.05E-09	6.43E-09	9.62E-09	9.49E-09	8.92E-09	8.42E-09	5.62E-09	1.08E-08
URI (Δ CDF)	-4.97E-11	-5.02E-11	-5.05E-11	3.16E-11	2.71E-11	2.59E-11	1.04E-10	1.05E-10
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	8.00E-09	6.40E-09	9.60E-09	9.50E-09	8.90E-09	8.40E-09	5.70E-09	1.10E-08

Licensee Comments: none

Reactor Coolant System Activity




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Activity	7/12	8/12	9/12	10/12	11/12	12/12	1/13	2/13	3/13	4/13	5/13	6/13
Maximum activity	0.000308	0.000031	0.000020	0.000535	0.000007	0.000014	0.000011	0.000006	0.000012	0.000010	0.000013	0.000013
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0.2	0	0	0.3	0	0	0	0	0	0	0	0
Reactor Coolant System Activity	7/13	8/13	9/13	10/13	11/13	12/13	1/14	2/14	3/14	4/14	5/14	6/14
Maximum activity	0.000010	0.000007	0.000151	0.000158	0.000546	0.000048	0.000016	0.000009	0.000008	0.000021	0.000016	0.000017
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0.1	0.1	0.3	0	0	0	0	0	0	0

Licensee Comments: none

Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	7/12	8/12	9/12	10/12	11/12	12/12	1/13	2/13	3/13	4/13	5/13	6/13
Maximum leakage	7.080	7.150	7.770	7.920	0	6.520	6.590	6.600	7.290	7.320	7.460	7.330
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	28.3	28.6	31.1	31.7	0	26.1	26.4	26.4	29.2	29.3	29.8	29.3
Reactor Coolant System Leakage	7/13	8/13	9/13	10/13	11/13	12/13	1/14	2/14	3/14	4/14	5/14	6/14
Maximum leakage	7.710	8.160	7.970	8.340	8.500	8.770	9.360	9.220	9.150	9.180	9.170	9.040
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	30.8	32.6	31.9	33.4	34.0	35.1	37.4	36.9	36.6	36.7	36.7	36.2

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
Successful opportunities	44.0	3.0	12.0	68.0	63.0	42.0	66.0	46.0
Total opportunities	45.0	4.0	12.0	68.0	64.0	42.0	66.0	46.0
Indicator value	98.3%	98.1%	98.0%	98.5%	98.2%	98.6%	98.8%	99.1%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
Participating Key personnel	57.0	56.0	59.0	60.0	58.0	52.0	52.0	60.0
Total Key personnel	57.0	56.0	59.0	60.0	58.0	52.0	52.0	60.0
Indicator value	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

Alert & Notification System



Thresholds: White < 94.0% Yellow < 90.0%


Notes

Alert & Notification System	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
Successful siren-tests	543	484	537	545	544	587	504	544
Total sirens-tests	546	496	546	546	546	588	504	546
Indicator value	99.4%	99.1%	98.7%	98.8%	98.9%	99.4%	99.8%	99.8%

Licensee Comments:

4Q/12: Total siren-tests for November 2012 were corrected after an error was found on the Monthly Testing Report.

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.

 [Action Matrix Summary](#) | [Inspection Findings Summary](#) | [PI Summary](#) | [Reactor Oversight Process](#)

Last Modified: July 31, 2014