


Seabrook 1

2Q/2014 Performance Indicators

The solid trend line represents the current reporting period.

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
Unplanned scrams	1.0	0	0	0	0	0	0	1.0
Critical hours	1820.4	1523.9	2159.0	2184.0	2208.0	2209.0	2159.0	1641.0
Indicator value	1.8	0.9	0.9	0.9	0	0	0	0.9

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
Unplanned power changes	0	0	0	0	0	0	0	0
Critical hours	1820.4	1523.9	2159.0	2184.0	2208.0	2209.0	2159.0	1641.0
Indicator value	0.9	0	0	0	0	0	0	0

Licensee Comments: none

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

Safety System Functional Failures (PWR)




Thresholds: White > 5.0

Notes

Safety System Functional Failures (PWR)	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
Safety System Functional Failures	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > $1.00E-6$ Yellow > $1.00E-5$ Red > $1.00E-4$

Notes

Mitigating Systems Performance Index, Emergency AC Power System	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
UAI (Δ CDF)	-3.32E-08	-3.32E-08	-3.32E-08	-3.32E-08	-3.32E-08	-3.32E-08	-3.32E-08	-3.32E-08
URI (Δ CDF)	-9.83E-08	-9.72E-08	-9.53E-08	-9.85E-08	-9.81E-08	-9.66E-08	-9.74E-08	-9.94E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.30E-07	-1.30E-07	-1.30E-07	-1.30E-07	-1.30E-07	-1.30E-07	-1.30E-07	-1.30E-07

Licensee Comments: none

Mitigating Systems Performance Index, High Pressure Injection System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
UAI (Δ CDF)	-3.13E-09	-3.13E-09	-3.13E-09	-3.13E-09	-3.13E-09	-3.13E-09	-3.13E-09	-3.13E-09
URI (Δ CDF)	-2.81E-09	-2.79E-09	-2.80E-09	-2.78E-09	-2.78E-09	-2.79E-09	-2.78E-09	-2.50E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-5.90E-09	-5.90E-09	-5.90E-09	-5.90E-09	-5.90E-09	-5.90E-09	-5.90E-09	-5.60E-09

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


Notes

Mitigating Systems Performance Index, Heat Removal System	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
UAI (Δ CDF)	-1.98E-08	-2.02E-08	-2.02E-08	-2.02E-08	-1.89E-08	-2.02E-08	-2.02E-08	-2.02E-08
URI (Δ CDF)	-4.01E-08	-3.99E-08	-3.99E-08	-3.98E-08	-3.98E-08	-3.98E-08	7.26E-08	7.74E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-6.00E-08	-6.00E-08	-6.00E-08	-6.00E-08	-5.90E-08	-6.00E-08	5.20E-08	5.70E-08

Licensee Comments:

1Q/14: An evaluation of an oil leak on 1-FW-P-37-A determined that an MSPI failure occurred in March 2014.

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
UAI (Δ CDF)	-1.80E-09	-3.09E-09	-2.11E-09	-1.78E-09	5.71E-09	6.20E-09	3.53E-09	2.01E-09
URI (Δ CDF)	-2.93E-08	-2.85E-08	-2.85E-08	-2.84E-08	-2.83E-08	-2.82E-08	-2.82E-08	-2.48E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-3.10E-08	-3.20E-08	-3.10E-08	-3.00E-08	-2.30E-08	-2.20E-08	-2.50E-08	-2.30E-08

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
UAI (Δ CDF)	3.60E-10	3.52E-10	-1.93E-14	-1.93E-14	-1.93E-14	-1.93E-14	-1.93E-14	-1.93E-14
URI (Δ CDF)	-4.04E-08	-3.97E-08	-3.97E-08	-3.95E-08	-3.94E-08	-3.94E-08	-3.31E-08	-3.06E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-4.00E-08	-3.90E-08	-4.00E-08	-3.90E-08	-3.90E-08	-3.90E-08	-3.30E-08	-3.10E-08

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Activity	7/12	8/12	9/12	10/12	11/12	12/12	1/13	2/13	3/13	4/13	5/13	6/13
Maximum activity	0.000062	0.000080	0.000059	N/A	0.000039	0.000062	0.000045	0.000045	0.000052	0.000062	0.000047	0.000064
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0	N/A	0	0	0	0	0	0	0	0


Reactor Coolant System Activity	7/13	8/13	9/13	10/13	11/13	12/13	1/14	2/14	3/14	4/14	5/14	6/14
Maximum activity	0.000055	0.000067	0.000056	0.000060	0.000063	0.000064	0.000065	0.000068	0.000094	N/A	0.000028	0.000033
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0	0	0	0	0	0	0	N/A	0	0

Licensee Comments:

6/14: During April 2014, RCS activity was not required to be calculated during the planned refueling outage and start-up activities as the plant was not at steady state power.

12/12: Reactor Coolant System Activity data was unavailable for the month of October as the unit was shutdown for refueling and RCS activity was not required to be calculated.

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Leakage	7/12	8/12	9/12	10/12	11/12	12/12	1/13	2/13	3/13	4/13	5/13	6/13
Maximum leakage	0.028	0.047	0.021	N/A	0.056	0.029	0.027	0.029	0.039	0.040	0.045	0.035
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.3	0.5	0.2	N/A	0.6	0.3	0.3	0.3	0.4	0.4	0.5	0.4
Reactor Coolant System Leakage	7/13	8/13	9/13	10/13	11/13	12/13	1/14	2/14	3/14	4/14	5/14	6/14
Maximum leakage	0.024	0.043	0.034	0.024	0.033	0.032	0.026	0.026	0.040	0.020	0.026	0.018
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.2	0.4	0.3	0.2	0.3	0.3	0.3	0.3	0.4	0.2	0.3	0.2

Licensee Comments:

12/12: Reactor Coolant Identified Leak Rate data was unavailable for the month of October as the unit was shutdown for refueling and RCS leakage was not required to be calculated.

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
Successful opportunities	22.0	36.0	29.0	27.0	16.0	44.0	17.0	20.0
Total opportunities	22.0	36.0	29.0	27.0	17.0	44.0	17.0	20.0
Indicator value	97.1%	97.3%	98.1%	98.2%	98.1%	98.4%	98.7%	99.5%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
Participating Key personnel	94.0	89.0	91.0	94.0	95.0	94.0	92.0	91.0
Total Key personnel	94.0	90.0	91.0	94.0	95.0	94.0	92.0	91.0
Indicator value	100.0%	98.9%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
Successful siren-tests	726	846	724	847	726	847	726	847
Total sirens-tests	726	847	726	847	726	847	726	847
Indicator value	100.0%	100.0%	99.9%	99.9%	99.9%	99.9%	100.0%	100.0%

Licensee Comments: none

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.

 [Action Matrix Summary](#) | [Inspection Findings Summary](#) | [PI Summary](#) | [Reactor Oversight Process](#)

Last Modified: July 31, 2014