


# Vogtle 1

## 2Q/2014 Performance Indicators

The solid trend line represents the current reporting period.

Licensee's General Comments: This change report corrects the Drill / Exercise data previously reported for February 2014. A Shift Manager was given credit for a notification opportunity during a simulator session in error due to the crew size.

### Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

### Notes

Unplanned Scrams per 7000 Critical Hrs	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
Unplanned scrams	0	0	0	0	0	0	0	1.0
Critical hours	1853.4	1833.2	2159.0	2184.0	2208.0	2209.0	1780.3	1923.3
<b>Indicator value</b>	<b>0.8</b>	<b>0.9</b>	<b>0.9</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0.9</b>

Licensee Comments: none

### Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

#### Notes

Unplanned Power Changes per 7000 Critical Hrs	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
Unplanned power changes	0	0	0	0	0	0	0	1.0
Critical hours	1853.4	1833.2	2159.0	2184.0	2208.0	2209.0	1780.3	1923.3
<b>Indicator value</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0.9</b>

Licensee Comments: none

### Unplanned Scrams with Complications




Thresholds: White > 1.0

#### Notes

Unplanned Scrams with Complications	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
Scrams with complications	0	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>

Licensee Comments: none

### Safety System Functional Failures (PWR)




Thresholds: White > 5.0

#### Notes

Safety System Functional Failures (PWR)	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
Safety System Functional Failures	0	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

Licensee Comments: none

### Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

#### Notes

Mitigating Systems Performance Index, Emergency AC Power System	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
UAI ( $\Delta$ CDF)	-5.88E-08	-5.93E-08	-5.99E-08	-3.07E-08	-2.57E-08	2.20E-08	1.59E-08	1.52E-08
URI ( $\Delta$ CDF)	1.95E-07	-4.23E-08	-3.50E-08	-3.14E-08	-2.48E-08	-3.88E-08	-1.90E-08	-1.48E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	1.40E-07	-1.00E-07	-9.50E-08	-6.20E-08	-5.00E-08	-1.70E-08	-3.20E-09	4.20E-10

Licensee Comments: none

### Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

#### Notes

Mitigating Systems Performance Index, High Pressure Injection System	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
UAI ( $\Delta$ CDF)	-6.15E-09	-6.15E-09	-6.15E-09	-6.15E-09	-6.15E-09	-6.15E-09	-2.31E-09	-2.10E-09
URI ( $\Delta$ CDF)	-1.23E-08	-1.18E-08	-1.19E-08	-1.22E-08	-1.22E-08	-1.27E-08	-1.15E-08	-1.25E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.80E-08	-1.80E-08	-1.80E-08	-1.80E-08	-1.80E-08	-1.90E-08	-1.40E-08	-1.50E-08

Licensee Comments: none

### Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

#### Notes

Mitigating Systems Performance Index, Heat Removal System	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
UAI ( $\Delta$ CDF)	-7.62E-08	-9.02E-08	-9.08E-08	-9.09E-08	-8.94E-08	-8.29E-08	-5.91E-08	-5.37E-08
URI ( $\Delta$ CDF)	-3.40E-07	-3.38E-07	-3.38E-07	-3.38E-07	-3.38E-07	-3.38E-07	-3.29E-07	-3.29E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-4.20E-07	-4.30E-07	-4.30E-07	-4.30E-07	-4.30E-07	-4.20E-07	-3.90E-07	-3.80E-07

Licensee Comments: none

### Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


#### Notes

Mitigating Systems Performance Index, Residual Heat Removal System	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
UAI ( $\Delta$ CDF)	3.65E-09	3.07E-09	2.79E-09	3.19E-09	3.69E-09	4.55E-09	-1.15E-08	-1.15E-08
URI ( $\Delta$ CDF)	-4.10E-08	-4.00E-08	-4.01E-08	-4.02E-08	-4.03E-08	-4.04E-08	-4.03E-08	-4.44E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-3.70E-08	-3.70E-08	-3.70E-08	-3.70E-08	-3.70E-08	-3.60E-08	-5.20E-08	-5.60E-08

Licensee Comments: none



### Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

#### Notes

Mitigating Systems Performance Index, Cooling Water Systems	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
UAI ( $\Delta$ CDF)	3.55E-08	3.52E-08	3.52E-08	3.45E-08	2.02E-08	9.15E-10	1.26E-10	5.25E-10
URI ( $\Delta$ CDF)	-2.89E-08	-2.66E-08	-2.50E-08	-2.53E-08	-2.56E-08	-2.15E-08	4.09E-08	3.87E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	6.60E-09	8.60E-09	1.00E-08	9.20E-09	-5.40E-09	-2.10E-08	4.10E-08	3.90E-08

Licensee Comments: none

### Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


#### Notes

Reactor Coolant System Activity	7/12	8/12	9/12	10/12	11/12	12/12	1/13	2/13	3/13	4/13	5/13	6/13
Maximum activity	0.000115	0.000109	0.000168	0.000030	0.000068	0.000028	0.000030	0.000021	0.000021	0.000031	0.000033	0.000031
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0
Reactor Coolant System Activity	7/13	8/13	9/13	10/13	11/13	12/13	1/14	2/14	3/14	4/14	5/14	6/14
Maximum activity	0.000024	0.000046	0.000034	0.000035	0.000046	0.000045	0.000027	0.000033	0.000040	0.000073	0.000157	0.000136
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Licensee Comments:

12/12: The October 2012 value for Maximum I-131 was corrected to only include steady state power level sampling.

### Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

#### Notes

Reactor Coolant System Leakage	7/12	8/12	9/12	10/12	11/12	12/12	1/13	2/13	3/13	4/13	5/13	6/13
Maximum leakage	0.069	0.069	0.055	0.054	0.076	0.040	0.056	0.061	0.056	0.066	0.068	0.080
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
<b>Indicator value</b>	<b>0.7</b>	<b>0.7</b>	<b>0.6</b>	<b>0.5</b>	<b>0.8</b>	<b>0.4</b>	<b>0.6</b>	<b>0.6</b>	<b>0.6</b>	<b>0.7</b>	<b>0.7</b>	<b>0.8</b>
Reactor Coolant System Leakage	7/13	8/13	9/13	10/13	11/13	12/13	1/14	2/14	3/14	4/14	5/14	6/14
Maximum leakage	0.078	0.079	0.102	0.108	0.072	0.058	0.097	0.077	0.070	0.144	0.137	0.147
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
<b>Indicator value</b>	<b>0.8</b>	<b>0.8</b>	<b>1.0</b>	<b>1.1</b>	<b>0.7</b>	<b>0.6</b>	<b>1.0</b>	<b>0.8</b>	<b>0.7</b>	<b>1.4</b>	<b>1.4</b>	<b>1.5</b>

Licensee Comments: none

### Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

#### Notes

Drill/Exercise Performance	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
Successful opportunities	62.0	27.0	40.0	67.0	71.0	53.0	37.0	46.0
Total opportunities	66.0	29.0	40.0	67.0	72.0	53.0	37.0	47.0
Indicator value	95.0%	94.9%	95.3%	96.3%	97.1%	97.5%	97.6%	98.1%

Licensee Comments: none

### ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

#### Notes

ERO Drill Participation	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
Participating Key personnel	121.0	116.0	116.0	92.0	94.0	95.0	96.0	94.0
Total Key personnel	121.0	118.0	116.0	92.0	95.0	95.0	96.0	94.0
Indicator value	100.0%	98.3%	100.0%	100.0%	98.9%	100.0%	100.0%	100.0%

Licensee Comments: none

### Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

#### Notes

Alert & Notification System	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
Successful siren-tests	610	658	564	611	658	611	610	610
Total sirens-tests	611	658	564	611	658	611	611	611
Indicator value	99.9%	99.9%	100.0%	100.0%	100.0%	100.0%	100.0%	99.9%

Licensee Comments: none

### Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

#### Notes

Occupational Exposure Control Effectiveness	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

Licensee Comments: none

### RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

#### Notes

RETS/ODCM Radiological Effluent	3Q/12	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.



 [Action Matrix Summary](#) | [Inspection Findings Summary](#) | [PI Summary](#) | [Reactor Oversight Process](#)

*Last Modified: August 29, 2014*