


Vogtle 1

3Q/2014 Performance Indicators

The solid trend line represents the current reporting period.

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14
Unplanned scrams	0	0	0	0	0	0	1.0	1.0
Critical hours	1833.2	2159.0	2184.0	2208.0	2209.0	1780.3	1923.3	2107.6
Indicator value	0.9	0.9	0	0	0	0	0.9	1.7

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs



Thresholds: White > 6.0


Notes

Unplanned Power Changes per 7000 Critical Hrs	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14
Unplanned power changes	0	0	0	0	0	0	1.0	1.0
Critical hours	1833.2	2159.0	2184.0	2208.0	2209.0	1780.3	1923.3	2107.6
Indicator value	0	0	0	0	0	0	0.9	1.7

Licensee Comments:

3Q/14: Notice of Enforcement Discretion (NOED No. 14-2-03) dated August 27, 2014, was received by Plant Vogtle which allowed Unit 2 to continue operation beyond the Technical Specification limit for Unit shutdown to complete repairs on 2B Containment Spray Pump. An unplanned power change of greater than 20% would have been reported without this NOED from the NRC.

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

Safety System Functional Failures (PWR)




Thresholds: White > 5.0

Notes

Safety System Functional Failures (PWR)	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14
Safety System Functional Failures	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14
UAI (Δ CDF)	-5.93E-08	-5.99E-08	-3.07E-08	-2.57E-08	2.20E-08	1.59E-08	1.52E-08	1.66E-08
URI (Δ CDF)	-4.23E-08	-3.50E-08	-3.14E-08	-2.48E-08	-3.88E-08	-1.90E-08	-1.48E-08	-8.43E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.00E-07	-9.50E-08	-6.20E-08	-5.00E-08	-1.70E-08	-3.20E-09	4.20E-10	8.20E-09

Licensee Comments: none

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14
UAI (Δ CDF)	-6.15E-09	-6.15E-09	-6.15E-09	-6.15E-09	-6.15E-09	-2.31E-09	-2.10E-09	-1.87E-09
URI (Δ CDF)	-1.18E-08	-1.19E-08	-1.22E-08	-1.22E-08	-1.27E-08	-1.15E-08	-1.25E-08	-1.25E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.80E-08	-1.80E-08	-1.80E-08	-1.80E-08	-1.90E-08	-1.40E-08	-1.50E-08	-1.40E-08

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14
UAI (Δ CDF)	-9.02E-08	-9.08E-08	-9.09E-08	-8.94E-08	-8.29E-08	-5.91E-08	-5.37E-08	-5.35E-08
URI (Δ CDF)	-3.38E-07	-3.38E-07	-3.38E-07	-3.38E-07	-3.38E-07	-3.29E-07	-3.29E-07	-3.34E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-4.30E-07	-4.30E-07	-4.30E-07	-4.30E-07	-4.20E-07	-3.90E-07	-3.80E-07	-3.90E-07

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14
UAI (Δ CDF)	3.07E-09	2.79E-09	3.19E-09	3.69E-09	4.55E-09	-1.15E-08	-1.15E-08	-4.79E-09
URI (Δ CDF)	-4.00E-08	-4.01E-08	-4.02E-08	-4.03E-08	-4.04E-08	-4.03E-08	-4.44E-08	-4.44E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-3.70E-08	-3.70E-08	-3.70E-08	-3.70E-08	-3.60E-08	-5.20E-08	-5.60E-08	-4.90E-08

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14
UAI (Δ CDF)	3.52E-08	3.52E-08	3.45E-08	2.02E-08	9.15E-10	1.26E-10	5.25E-10	1.08E-09
URI (Δ CDF)	-2.66E-08	-2.50E-08	-2.53E-08	-2.56E-08	-2.15E-08	4.09E-08	3.87E-08	3.97E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	8.60E-09	1.00E-08	9.20E-09	-5.40E-09	-2.10E-08	4.10E-08	3.90E-08	4.10E-08

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	10/12	11/12	12/12	1/13	2/13	3/13	4/13	5/13	6/13	7/13	8/13	9/13
Maximum activity	0.000030	0.000068	0.000028	0.000030	0.000021	0.000021	0.000031	0.000033	0.000031	0.000024	0.000046	0.000034
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0
Reactor Coolant System Activity	10/13	11/13	12/13	1/14	2/14	3/14	4/14	5/14	6/14	7/14	8/14	9/14
Maximum activity	0.000035	0.000046	0.000045	0.000027	0.000033	0.000040	0.000073	0.000157	0.000136	0.000132	0.000129	0.000128
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Licensee Comments:

12/12: The October 2012 value for Maximum I-131 was corrected to only include steady state power level sampling.

Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	10/12	11/12	12/12	1/13	2/13	3/13	4/13	5/13	6/13	7/13	8/13	9/13
Maximum leakage	0.054	0.076	0.040	0.056	0.061	0.056	0.066	0.068	0.080	0.078	0.079	0.102
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.5	0.8	0.4	0.6	0.6	0.6	0.7	0.7	0.8	0.8	0.8	1.0
Reactor Coolant System Leakage	10/13	11/13	12/13	1/14	2/14	3/14	4/14	5/14	6/14	7/14	8/14	9/14
Maximum leakage	0.108	0.072	0.058	0.097	0.077	0.070	0.144	0.137	0.147	0.154	0.169	0.161
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	1.1	0.7	0.6	1.0	0.8	0.7	1.4	1.4	1.5	1.5	1.7	1.6

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14
Successful opportunities	27.0	40.0	67.0	71.0	53.0	37.0	46.0	31.0
Total opportunities	29.0	40.0	67.0	72.0	53.0	37.0	47.0	31.0
Indicator value	94.9%	95.3%	96.3%	97.1%	97.5%	97.6%	98.1%	98.9%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14
Participating Key personnel	116.0	116.0	92.0	94.0	95.0	96.0	94.0	93.0
Total Key personnel	118.0	116.0	92.0	95.0	95.0	96.0	94.0	93.0
Indicator value	98.3%	100.0%	100.0%	98.9%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14
Successful siren-tests	658	564	611	658	611	610	610	611
Total sirens-tests	658	564	611	658	611	611	611	611
Indicator value	99.9%	100.0%	100.0%	100.0%	100.0%	100.0%	99.9%	99.9%

Licensee Comments: none

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.

 [Action Matrix Summary](#) | [Inspection Findings Summary](#) | [PI Summary](#) | [Reactor Oversight Process](#)

Last Modified: November 3, 2014