


# Surry 1

## 4Q/2014 Performance Indicators

The solid trend line represents the current reporting period.

Licensee's General Comments: none

### Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

### Notes

Unplanned Scrams per 7000 Critical Hrs	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14
Unplanned scrams	0	0	0	0	0	0	0	0
Critical hours	2159.0	2184.0	2208.0	1450.9	2159.0	2184.0	2208.0	2209.0
<b>Indicator value</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

Licensee Comments: none

### Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

#### Notes

Unplanned Power Changes per 7000 Critical Hrs	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14
Unplanned power changes	0	0	0	0	0	0	0	0
Critical hours	2159.0	2184.0	2208.0	1450.9	2159.0	2184.0	2208.0	2209.0
<b>Indicator value</b>	<b>0.9</b>	<b>0.8</b>	<b>0.8</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

Licensee Comments: none

### Unplanned Scrams with Complications




Thresholds: White > 1.0

#### Notes

Unplanned Scrams with Complications	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14
Scrams with complications	0	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>

Licensee Comments: none

### Safety System Functional Failures (PWR)



Thresholds: White > 5.0


#### Notes

Safety System Functional Failures (PWR)	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14
Safety System Functional Failures	1	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

Licensee Comments:

1Q/13: See Surry LER S1-2013-001-00 dated January 30, 2013.

### Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

#### Notes

Mitigating Systems Performance Index, Emergency AC Power System	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14
UAI ( $\Delta$ CDF)	-1.39E-08	-1.39E-08	-1.39E-08	-1.39E-08	-1.39E-08	-1.39E-08	-1.39E-08	-2.75E-09
URI ( $\Delta$ CDF)	-8.29E-08	-7.22E-08	-6.70E-08	-5.84E-08	-5.33E-08	-2.55E-08	-1.96E-08	-1.61E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-9.70E-08	-8.60E-08	-8.10E-08	-7.20E-08	-6.70E-08	-3.90E-08	-3.30E-08	-1.90E-08

Licensee Comments: none

### Mitigating Systems Performance Index, High Pressure Injection System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

#### Notes

Mitigating Systems Performance Index, High Pressure Injection System	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14
UAI ( $\Delta$ CDF)	-8.22E-10	-8.24E-10	-7.80E-10	-7.85E-10	-8.09E-10	-8.72E-10	-8.26E-10	-7.99E-10
URI ( $\Delta$ CDF)	-1.43E-08	-1.43E-08	-1.41E-08	-1.39E-08	-1.39E-08	-1.36E-08	-1.38E-08	-1.36E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.50E-08	-1.50E-08	-1.50E-08	-1.50E-08	-1.50E-08	-1.40E-08	-1.50E-08	-1.40E-08

#### Licensee Comments:

4Q/14: Changed PRA Parameter(s). An MSPI review identified several probabilistic risk analysis coefficients that were incorrect. The MSPI Basis Document and coefficients were corrected with no change in color.

3Q/14: Changed PRA Parameter(s).

2Q/14: Changed PRA Parameter(s).

1Q/14: Changed PRA Parameter(s).


4Q/13: Changed PRA Parameter(s).

3Q/13: Changed PRA Parameter(s).

2Q/13: Changed PRA Parameter(s).

1Q/13: Changed PRA Parameter(s).

### Mitigating Systems Performance Index, Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

### Notes

Mitigating Systems Performance Index, Heat Removal System	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14
UAI ( $\Delta$ CDF)	4.93E-09	4.35E-09	1.69E-09	2.32E-09	1.66E-09	1.25E-09	1.48E-09	-2.13E-09
URI ( $\Delta$ CDF)	7.13E-08	7.51E-08	7.32E-08	6.96E-08	-1.63E-08	-1.63E-08	-1.69E-08	-1.74E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	<b>7.60E-08</b>	<b>7.90E-08</b>	<b>7.50E-08</b>	<b>7.20E-08</b>	<b>-1.50E-08</b>	<b>-1.50E-08</b>	<b>-1.50E-08</b>	<b>-2.00E-08</b>

Licensee Comments:

4Q/14: Changed PRA Parameter(s). An MSPI review identified several probabilistic risk analysis coefficients that were incorrect. The MSPI Basis Document and coefficients were corrected with no change in color.

3Q/14: Changed PRA Parameter(s).

2Q/14: Changed PRA Parameter(s).

1Q/14: Changed PRA Parameter(s).


4Q/13: Changed PRA Parameter(s).

3Q/13: Changed PRA Parameter(s).

2Q/13: Changed PRA Parameter(s).

1Q/13: Changed PRA Parameter(s).

### Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

#### Notes

Mitigating Systems Performance Index, Residual Heat Removal System	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14
UAI (ΔCDF)	1.85E-10	-2.01E-10	-2.28E-10	-2.29E-10	-2.43E-10	-2.43E-10	-2.55E-10	-2.55E-10
URI (ΔCDF)	-9.45E-10	-9.16E-10	-8.96E-10	-9.03E-10	-9.03E-10	-9.03E-10	-9.03E-10	-9.03E-10
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-7.60E-10	-1.10E-09	-1.10E-09	-1.10E-09	-1.10E-09	-1.10E-09	-1.20E-09	-1.20E-09

Licensee Comments:



4Q/14: Changed PRA Parameter(s). An MSPI review identified several probabilistic risk analysis coefficients that were incorrect. The MSPI Basis Document and coefficients were corrected with no change in color.

3Q/14: Changed PRA Parameter(s).

2Q/14: Changed PRA Parameter(s).

1Q/14: Changed PRA Parameter(s).


4Q/13: Changed PRA Parameter(s).

3Q/13: Changed PRA Parameter(s).

2Q/13: Changed PRA Parameter(s).

1Q/13: Changed PRA Parameter(s).

### Mitigating Systems Performance Index, Cooling Water Systems



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

### Notes

Mitigating Systems Performance Index, Cooling Water Systems	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14
UAI (ΔCDF)	2.13E-09	2.26E-09	1.59E-09	1.58E-09	1.27E-09	3.30E-09	3.04E-09	3.25E-09
	-2.01E-	-2.01E-	-2.01E-	-1.99E-	-1.53E-	-1.49E-	-1.05E-	-1.07E-

4Q/2014 Performance Indicators - Surry 1

URI ( $\Delta$ CDF)	08	08	08	08	08	08	08	08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
<b>Indicator value</b>	<b>-1.80E-08</b>	<b>-1.80E-08</b>	<b>-1.80E-08</b>	<b>-1.80E-08</b>	<b>-1.40E-08</b>	<b>-1.20E-08</b>	<b>-7.50E-09</b>	<b>-7.40E-09</b>

Licensee Comments:

4Q/14: Changed PRA Parameter(s). An MSPI review identified several probabilistic risk analysis coefficients that were incorrect. The MSPI Basis Document and coefficients were corrected with no change in color.

3Q/14: Changed PRA Parameter(s).

2Q/14: Failure No. 311011 on March 29 was added which changed the first quarter indicator with no change in color. See LER report No. 50-280/2014-001-00.

2Q/14: Changed PRA Parameter(s).

1Q/14: Changed PRA Parameter(s).


4Q/13: Changed PRA Parameter(s).

3Q/13: Changed PRA Parameter(s).

2Q/13: Changed PRA Parameter(s).

1Q/13: Changed PRA Parameter(s).

### Reactor Coolant System Activity




Thresholds: White > 50.0 Yellow > 100.0

#### Notes

Reactor Coolant System Activity	1/13	2/13	3/13	4/13	5/13	6/13	7/13	8/13	9/13	10/13	11/13	12/13
Maximum activity	0.000979	0.001220	0.001160	0.001090	0.001310	0.001280	0.001120	0.001320	0.001490	0.001580	0.000475	0.000601
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0	0.1
Reactor Coolant System Activity	1/14	2/14	3/14	4/14	5/14	6/14	7/14	8/14	9/14	10/14	11/14	12/14
Maximum activity	0.000632	0.000631	0.000729	0.000749	0.000817	0.000839	0.000828	0.000910	0.000928	0.000929	0.001020	0.001030
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1

Licensee Comments: none

### Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0


#### Notes

Reactor Coolant System Leakage	1/13	2/13	3/13	4/13	5/13	6/13	7/13	8/13	9/13	10/13	11/13	12/13
Maximum leakage	0.130	0.140	0.120	0.120	0.130	0.120	0.130	0.140	0.180	0.350	0.420	0.420
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	1.3	1.4	1.2	1.2	1.3	1.2	1.3	1.4	1.8	3.5	4.2	4.2
Reactor Coolant System Leakage	1/14	2/14	3/14	4/14	5/14	6/14	7/14	8/14	9/14	10/14	11/14	12/14
Maximum leakage	0.330	0.380	0.450	0.330	0.630	0.990	1.350	1.220	1.290	1.430	1.570	0.340
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	3.3	3.8	4.5	3.3	6.3	9.9	13.5	12.2	12.9	14.3	15.7	3.4

#### Licensee Comments:

6/13: Maximum RCS Identified Leakage for Unit 1 was reported incorrectly in September and November of 2012. The data has been corrected. This correction does not change the color of any performance indicators.

### Drill/Exercise Performance



Thresholds: White < 90.0% Yellow < 70.0%


#### Notes

Drill/Exercise Performance	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14
Successful opportunities	48.0	22.0	28.0	14.0	36.0	28.0	33.0	19.0
Total opportunities	49.0	22.0	31.0	14.0	38.0	28.0	33.0	19.0
Indicator value	98.4%	98.8%	97.6%	97.5%	96.6%	97.5%	97.5%	97.4%

Licensee Comments:

3Q/14: Further review of a March 2014 ERO drill determined an initial successful DEP opportunity was not successful. Historical data was corrected with no change in color.

### ERO Drill Participation



Thresholds: White < 80.0% Yellow < 60.0%


#### Notes

ERO Drill Participation	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14
Participating Key personnel	165.0	161.0	160.0	159.0	156.0	152.0	154.0	151.0
Total Key personnel	165.0	161.0	160.0	159.0	156.0	152.0	154.0	151.0
Indicator value	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments:

3Q/14: An assessment determined the total number of personnel in key ERO positions was inaccurate. Historical data was corrected with no change in color.

### Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

#### Notes

Alert & Notification System	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14
Successful siren-tests	497	567	497	566	496	568	567	497
Total sirens-tests	497	568	497	568	497	568	568	497
Indicator value	100.0%	100.0%	100.0%	99.9%	99.8%	99.9%	99.8%	99.9%

Licensee Comments: none

### Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0


#### Notes

Occupational Exposure Control Effectiveness	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

Licensee Comments: none



### RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

#### Notes

RETS/ODCM Radiological Effluent	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
<b>Indicator value</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.

 [Action Matrix Summary](#) | [Inspection Findings Summary](#) | [PI Summary](#) | [Reactor Oversight Process](#)

*Last Modified: February 3, 2015*