


FitzPatrick

1Q/2015 Performance Indicators

The solid trend line represents the current reporting period.

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
Unplanned scrams	0	0	0	0	0	0	0	0
Critical hours	2184.0	2208.0	2209.0	2159.0	2155.7	1318.0	2060.1	2159.0
Indicator value	1.9	1.8	0	0	0	0	0	0

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs



Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
Unplanned power changes	4.0	2.0	6.0	11.0	10.0	4.0	4.0	0
Critical hours	2184.0	2208.0	2209.0	2159.0	2155.7	1318.0	2060.1	2159.0
Indicator value	10.2	9.8	12.1	18.4	23.2	27.7	26.4	16.4

Licensee Comments:

1Q/15: Multiple downpowers were due to Main Condenser tube leakage. Retubing project completed during Refuel Outage 21. Main Condenser degrading performance has been corrected and this PI is improving. There is no effect on public or nuclear safety.

4Q/14: Multiple downpowers are due to Main Condenser tube leakage. Retubing project completed during Refuel Outage 21. Main Condenser degrading performance has been corrected and this PI is expected to improve. There is no effect on public or nuclear safety.

3Q/14: Multiple downpowers are due to Main Condenser tube leakage. Retubing project completed during Refuel Outage 21. Main Condenser degrading performance has been corrected and this PI is expected to improve. There is no effect on public or nuclear safety.

2Q/14: Multiple downpowers are due to repairs on the Main Condenser tube inleakage. This deficiency is a known issue but individual tube failures are not predictable. Compensatory measures, such as tube plugging and tube sleeving, have been performed to mitigate Main Condenser performance. Full Tube replacement is scheduled for next refueling outage. There is no effect on public or nuclear safety.

1Q/14: Multiple downpowers are due to repairs on the Main Condenser tube inleakage. This deficiency is a


known issue but individual tube failures are not predictable. Compensatory measures, such as tube plugging and tube sleeving, have been performed to mitigate Main Condenser performance. Full Tube replacement is scheduled for next refueling outage. There is no effect on public or nuclear safety.

4Q/13: Multiple downpowers are due to repairs on the Main Condenser tube inleakage. This deficiency is a known issue but individual tube failures are not predictable. Compensatory measures, such as tube plugging and tube sleeving, have been performed to mitigate Main Condenser performance. There is no affect on public or nuclear safety.

3Q/13: Multiple downpowers are due to repairs on the Main Condenser tube inleakage. This deficiency is a known issue but individual tube failures are not predictable. Compensatory measures, such as tube plugging and tube sleeving, have been performed to mitigate Main Condenser performance. There is no affect on public or nuclear safety.

2Q/13: Multiple downpowers are due to repairs on the Main Condenser tube inleakage. This deficiency is a known issue but individual tube failures are not predictable. Compensatory measures, such as tube plugging and tube sleeving, have been performed to mitigate Main Condenser performance. There is no affect on public or nuclear safety.

Unplanned Scrams with Complications



Thresholds: White > 1.0


Notes

Unplanned Scrams with Complications	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
Scrams with complications	0	0	0	0	0	0	0	0

Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
-----------------	-----	-----	-----	-----	-----	-----	-----	-----

Licensee Comments: none

Safety System Functional Failures (BWR)



Thresholds: White > 6.0

Notes


Safety System Functional Failures (BWR)	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
Safety System Functional Failures	0	1	0	0	1	0	0	0
Indicator value	4	5	1	1	2	1	1	1

Licensee Comments:

2Q/14: LER-14-001

3Q/13: LER-12-010

Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
UAI (Δ CDF)	6.30E-09	7.40E-09	9.66E-09	9.53E-09	7.89E-09	8.30E-09	5.04E-09	2.79E-09
URI (Δ CDF)	-1.13E-06	-1.04E-06	-1.01E-06	-9.94E-07	-8.13E-07	-7.03E-07	-6.64E-07	-5.99E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.10E-06	-1.00E-06	-1.00E-06	-9.80E-07	-8.00E-07	-6.90E-07	-6.60E-07	-6.00E-07


Licensee Comments:

4Q/13: Change report submitted to make minor changes in the 3rd quarter 2013 to 4th quarter 2012. The Indicator color significance remains Green with the change.

3Q/13: A change report submitted with 4th quarter 2013 data made a minor change in the 4th quarter 2012 EDG MSPI PI. This had an effect through 2013. The Indicator color significance remains Green with the change.

2Q/13: A change report submitted with 4th quarter 2013 data made a minor change in the 4th quarter 2012 EDG MSPI PI. This had an effect through 2013. The Indicator color significance remains Green with the change.

Mitigating Systems Performance Index, High Pressure Injection System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


Notes

Mitigating Systems Performance Index, High Pressure Injection System	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
UAI (ΔCDF)	1.38E-08	1.21E-08	7.02E-09	7.02E-09	6.56E-08	7.50E-08	1.03E-07	1.03E-07
URI (ΔCDF)	2.93E-07	2.87E-07	-8.08E-08	-7.62E-08	-7.86E-08	-7.63E-08	-8.30E-08	-8.32E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	3.10E-07	3.00E-07	-7.40E-08	-6.90E-08	-1.30E-08	-1.20E-09	2.00E-08	2.00E-08

Licensee Comments:

2Q/14: MSPI Basis Document Rev 4: Revise HPCI and RCIC to remove the Pressure Control Mode. Remove 10SOV-101A through D

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
UAI (Δ CDF)	5.47E-08	5.23E-08	1.78E-08	5.09E-08	4.32E-08	4.16E-08	3.90E-08	-1.27E-08
URI (Δ CDF)	2.50E-08	3.06E-08	-1.10E-08	-5.48E-08	-5.48E-08	-5.26E-08	-5.71E-08	-5.70E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	8.00E-08	8.30E-08	6.80E-09	-3.90E-09	-1.20E-08	-1.10E-08	-1.80E-08	-7.00E-08

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
UAI (Δ CDF)	-1.34E-08	-2.37E-08	5.90E-08	1.00E-07	9.04E-08	1.17E-07	1.20E-07	8.97E-08
URI (Δ CDF)	-2.69E-07	-2.53E-07	-2.41E-07	-2.44E-07	-2.47E-07	-2.60E-07	-2.65E-07	-2.63E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-2.80E-07	-2.80E-07	-1.80E-07	-1.40E-07	-1.60E-07	-1.40E-07	-1.50E-07	-1.70E-07

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > $1.00E-6$ Yellow > $1.00E-5$ Red > $1.00E-4$

Notes

Mitigating Systems Performance Index, Cooling Water Systems	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
UAI (Δ CDF)	-1.79E-08	-1.79E-08	1.06E-07	1.07E-07	1.25E-07	1.38E-07	1.40E-07	1.39E-07
URI (Δ CDF)	-1.18E-08	-1.12E-08	-1.13E-08	-1.13E-08	-1.15E-08	-1.22E-08	-1.23E-08	-1.23E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-3.00E-08	-2.90E-08	9.40E-08	9.60E-08	1.10E-07	1.30E-07	1.30E-07	1.30E-07

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	4/13	5/13	6/13	7/13	8/13	9/13	10/13	11/13	12/13	1/14	2/14	3/14
Maximum activity	0.000018	0.000014	0.000013	0.000025	0.000013	0.000028	0.000010	0.000010	0.000014	0.000015	0.000015	0.000013
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Reactor Coolant System Activity	4/14	5/14	6/14	7/14	8/14	9/14	10/14	11/14	12/14	1/15	2/15	3/15
Maximum activity	0.000009	0.000012	0.000006	0.000018	0.000017	N/A	0.000008	0.000008	0.000010	0.000012	0.000009	0.000011
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	0	0	N/A	0	0	0	0	0	0

Licensee Comments: none

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	4/13	5/13	6/13	7/13	8/13	9/13	10/13	11/13	12/13	1/14	2/14	3/14
Maximum leakage	1.440	1.400	1.460	1.360	1.350	1.300	1.280	1.270	1.260	1.250	1.230	1.220
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	5.8	5.6	5.8	5.4	5.4	5.2	5.1	5.1	5.0	5.0	4.9	4.9


Reactor Coolant System Leakage	4/14	5/14	6/14	7/14	8/14	9/14	10/14	11/14	12/14	1/15	2/15	3/15
Maximum leakage	1.160	1.140	1.150	1.060	1.530	0	1.720	1.740	1.760	1.730	1.730	1.730
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	4.6	4.6	4.6	4.2	6.1	0	6.9	7.0	7.0	6.9	6.9	6.9

Licensee Comments:

9/13: 2nd Quarter 2013 data has been updated to correct data submitted in error. This change has no affect on indicator color.

6/13: Maximum RCS identified leakage and Maximum RCS unidentified leakage were inadvertently switched. Corrected by change report in 3rd Quarter 2013.

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
Successful opportunities	67.0	74.0	76.0	51.0	50.0	0	0	24.0
Total opportunities	68.0	75.0	77.0	52.0	55.0	0	0	24.0
Indicator value	94.8%	95.7%	96.5%	96.7%	97.2%	97.0%	96.9%	97.4%

Licensee Comments: none

ERO Drill Participation



Thresholds: White < 80.0% Yellow < 60.0%

Notes


ERO Drill Participation	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
Participating Key personnel	78.0	74.0	78.0	69.0	62.0	60.0	57.0	58.0
Total Key personnel	78.0	74.0	78.0	69.0	67.0	66.0	67.0	62.0
Indicator value	100.0%	100.0%	100.0%	100.0%	92.5%	90.9%	85.1%	93.5%

Licensee Comments:

1Q/14: 4th quarter 2013 data was revised to reflect updated qualification status of one key individual. This change does not affect the indicator color.

4Q/13: December and November 2013 data was revised to reflect updated qualification status of one key individual. This change does not affect the indicator color.

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
Successful siren-tests	293	221	333	221	296	259	296	259
Total sirens-tests	296	222	333	222	296	259	296	259
Indicator value	99.7%	99.6%	99.6%	99.5%	99.8%	99.9%	99.9%	100.0%

Licensee Comments: none

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.

 [Action Matrix Summary](#) | [Inspection Findings Summary](#) | [PI Summary](#) | [Reactor Oversight Process](#)

Last Modified: April 23, 2015