


Nine Mile Point 1

1Q/2015 Performance Indicators

The solid trend line represents the current reporting period.

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
Unplanned scrams	0	0	0	0	0	0	0	0
Critical hours	1479.4	2155.9	2209.0	2159.0	2184.0	2208.0	2209.0	1777.4
Indicator value	3.7	1.8	0	0	0	0	0	0

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
Unplanned power changes	0	0	1.0	0	0	0	0	0
Critical hours	1479.4	2155.9	2209.0	2159.0	2184.0	2208.0	2209.0	1777.4
Indicator value	0.9	0.9	0.9	0.9	0.8	0.8	0	0

Licensee Comments: none

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

Safety System Functional Failures (BWR)



Thresholds: White > 6.0


Notes

Safety System Functional Failures (BWR)	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
Safety System Functional Failures	0	1	0	0	0	0	0	0
Indicator value	2	3	2	1	1	0	0	0

Licensee Comments:

3Q/13: LER 2012-003 Rev 1, LER 2013-001

Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
UAI (Δ CDF)	-5.10E-10	2.60E-11	-6.80E-10	-1.20E-09	-4.97E-09	-5.87E-09	-5.87E-09	-5.87E-09
URI (Δ CDF)	-2.78E-08	-2.78E-08	-2.77E-08	-2.70E-08	-2.67E-08	-2.61E-08	-2.52E-08	-2.55E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-2.80E-08	-2.80E-08	-2.80E-08	-2.80E-08	-3.20E-08	-3.20E-08	-3.10E-08	-3.10E-08

Licensee Comments: none

Mitigating Systems Performance Index, High Pressure Injection System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
UAI (Δ CDF)	-9.29E-09	-1.09E-08	-1.09E-08	-1.09E-08	-1.13E-08	-1.13E-08	-1.13E-08	-1.13E-08
URI (Δ CDF)	8.82E-09	8.62E-09	8.54E-09	8.64E-09	-2.50E-09	-2.49E-09	-2.49E-09	-2.47E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-4.80E-10	-2.20E-09	-2.30E-09	-2.20E-09	-1.40E-08	-1.40E-08	-1.40E-08	-1.40E-08

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
UAI (Δ CDF)	-1.24E-09	-1.24E-09	-1.24E-09	-1.24E-09	-1.24E-09	-1.24E-09	-1.24E-09	-1.24E-09
URI (Δ CDF)	-4.95E-10	-4.95E-10	-5.00E-10	-4.83E-10	-4.66E-10	-4.69E-10	-4.66E-10	-4.69E-10
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.70E-09	-1.70E-09	-1.70E-09	-1.70E-09	-1.70E-09	-1.70E-09	-1.70E-09	-1.70E-09

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
UAI (Δ CDF)	-1.49E-10	-1.49E-10	-1.49E-10	-1.49E-10	-1.49E-10	-1.49E-10	7.19E-11	7.45E-11
URI (Δ CDF)	-1.53E-09	-1.55E-09	-1.52E-09	-1.50E-09	-1.41E-09	-1.41E-09	-1.41E-09	-1.38E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.70E-09	-1.70E-09	-1.70E-09	-1.70E-09	-1.60E-09	-1.60E-09	-1.30E-09	-1.30E-09

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
UAI (Δ CDF)	-1.45E-08	-1.46E-08	-1.46E-08	-1.45E-08	-1.45E-08	-1.45E-08	-1.43E-08	-1.41E-08
URI (Δ CDF)	2.05E-08	6.87E-09	6.87E-09	1.43E-08	1.44E-08	1.44E-08	1.52E-08	1.60E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	6.00E-09	-7.70E-09	-7.70E-09	-1.50E-10	-1.60E-10	-1.70E-10	8.80E-10	1.90E-09

Licensee Comments: none

Reactor Coolant System Activity




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Activity	4/13	5/13	6/13	7/13	8/13	9/13	10/13	11/13	12/13	1/14	2/14	3/14
Maximum activity	0.000019	0.000004	0.000006	0.000007	0.000006	0.000011	0.000005	0.000006	0.000004	0.000005	0.000004	0.000004
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0
Reactor Coolant System Activity	4/14	5/14	6/14	7/14	8/14	9/14	10/14	11/14	12/14	1/15	2/15	3/15
Maximum activity	0.000003	0.000004	0.000004	0.000004	0.000004	0.000005	0.000004	0.000004	0.000004	0.000004	0.000004	0.000004
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Licensee Comments: none

Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	4/13	5/13	6/13	7/13	8/13	9/13	10/13	11/13	12/13	1/14	2/14	3/14
Maximum leakage	3.891	3.719	4.322	4.354	3.847	3.871	3.879	3.831	3.838	3.834	3.952	3.954
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	15.6	14.9	17.3	17.4	15.4	15.5	15.5	15.3	15.4	15.3	15.8	15.8
Reactor Coolant System Leakage	4/14	5/14	6/14	7/14	8/14	9/14	10/14	11/14	12/14	1/15	2/15	3/15
Maximum leakage	3.950	4.006	3.870	3.887	3.927	3.933	3.799	3.874	3.800	3.792	3.966	3.717
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	15.8	16.0	15.5	15.5	15.7	15.7	15.2	15.5	15.2	15.2	15.9	14.9

Licensee Comments: none

Drill/Exercise Performance



Thresholds: White < 90.0% Yellow < 70.0%


Notes

Drill/Exercise Performance	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
Successful opportunities	44.0	34.0	53.0	34.0	8.0	67.0	50.0	90.0
Total opportunities	48.0	37.0	54.0	36.0	8.0	67.0	54.0	94.0
Indicator value	96.3%	95.5%	95.4%	95.1%	95.2%	96.7%	95.7%	95.5%

Licensee Comments:

4Q/14: Change reflects a correction to the Drill and Exercise Performance. The number of drill, exercise and actual event opportunities during December was changed from 12 to 14. The number performed successfully was changed from 10 to 12. The changes have no impact on the color of the indicator.

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
Participating Key personnel	85.0	82.0	77.0	79.0	84.0	80.0	79.0	80.0
Total Key personnel	85.0	82.0	77.0	79.0	84.0	80.0	79.0	80.0
Indicator value	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
Successful siren-tests	293	221	333	221	296	259	296	259
Total sirens-tests	296	222	333	222	296	259	296	259
Indicator value	99.7%	99.6%	99.6%	99.5%	99.8%	99.9%	99.9%	100.0%

Licensee Comments: none

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.

 [Action Matrix Summary](#) | [Inspection Findings Summary](#) | [PI Summary](#) | [Reactor Oversight Process](#)

Last Modified: April 23, 2015