


Quad Cities 2

1Q/2015 Performance Indicators

The solid trend line represents the current reporting period.

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
Unplanned scrams	0	0	0	0	1.0	0	0	0
Critical hours	2184.0	2208.0	2209.0	2156.4	1346.8	2208.0	2209.0	2159.0
Indicator value	0	0	0	0	0.9	0.9	0.9	0.9

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs



Thresholds: White > 6.0


Notes

Unplanned Power Changes per 7000 Critical Hrs	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
Unplanned power changes	0	1.0	0	1.0	1.0	0	0	0
Critical hours	2184.0	2208.0	2209.0	2156.4	1346.8	2208.0	2209.0	2159.0
Indicator value	0.8	0.8	0.8	1.6	2.7	1.8	1.8	0.9

Licensee Comments:

3Q/13: An FAQ was submitted for a 6/5/13 event involving a power change on Unit 2 due to an animal intrusion event in the Quad Cities Switchyard.

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
Scrams with complications	0	0	0	0	1.0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	1.0	1.0	1.0	1.0

Licensee Comments: none

Safety System Functional Failures (BWR)



Thresholds: White > 6.0


Notes

Safety System Functional Failures (BWR)	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
Safety System Functional Failures	0	0	0	0	0	0	0	1
Indicator value	2	2	0	0	0	0	0	1

Licensee Comments:

1Q/15: LER 254/2104-005-00, Main Control Room Door Unable to Close Causes Loss of Control Room Envelope Boundary (affects BOTH units)

Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


Notes

Mitigating Systems Performance Index, Emergency AC Power System	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
UAI (Δ CDF)	9.10E-09	9.82E-09	2.83E-08	2.61E-08	1.75E-08	2.02E-08	-5.80E-10	5.40E-08
URI (Δ CDF)	1.08E-08	-1.49E-08	-1.63E-08	-1.21E-08	-1.41E-08	-1.20E-08	-1.26E-08	-1.11E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	2.00E-08	-5.10E-09	1.20E-08	1.40E-08	3.40E-09	8.20E-09	-1.30E-08	4.30E-08

Licensee Comments:

4Q/14: Includes endurance run and short work window.

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
UAI (Δ CDF)	1.32E-08	1.43E-08	1.38E-08	1.44E-08	1.20E-08	1.47E-08	1.80E-08	1.24E-08
URI (Δ CDF)	-1.43E-08	-1.43E-08	-1.43E-08	-1.37E-08	-1.49E-08	-1.49E-08	-1.49E-08	-1.43E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.10E-09	-3.40E-11	-5.40E-10	7.10E-10	-2.90E-09	-2.30E-10	3.00E-09	-1.90E-09

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
UAI (Δ CDF)	1.53E-08	1.62E-08	1.49E-08	1.51E-08	1.59E-08	1.53E-08	1.74E-08	1.23E-09
URI (Δ CDF)	-1.36E-08	-1.36E-08	-1.36E-08	-1.36E-08	-1.53E-08	-1.53E-08	-1.45E-08	-1.45E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	1.80E-09	2.70E-09	1.40E-09	1.50E-09	6.20E-10	3.60E-11	3.00E-09	-1.30E-08

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
UAI (ΔCDF)	-2.38E-08	-1.85E-08	-1.85E-08	-1.85E-08	-1.83E-08	-1.83E-08	-1.83E-08	-1.84E-08
URI (ΔCDF)	-3.99E-08	2.29E-08	2.29E-08	2.29E-08	2.29E-08	2.29E-08	2.29E-08	2.29E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-6.40E-08	4.40E-09	4.40E-09	4.40E-09	4.60E-09	4.60E-09	4.60E-09	4.50E-09

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
UAI (Δ CDF)	1.07E-08	-3.05E-09	-3.05E-09	-1.54E-08	-1.26E-08	-1.57E-08	-8.13E-09	-9.28E-09
URI (Δ CDF)	1.06E-10	1.06E-10	-5.47E-10	-5.47E-10	-5.47E-10	-5.47E-10	-5.47E-10	-5.47E-10
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	1.10E-08	-2.90E-09	-3.60E-09	-1.60E-08	-1.30E-08	-1.60E-08	-8.70E-09	-9.80E-09

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	4/13	5/13	6/13	7/13	8/13	9/13	10/13	11/13	12/13	1/14	2/14	3/14
Maximum activity	0.000004	0.000004	0.000005	0.000004	0.000008	0.000009	0.000009	0.000006	0.000010	0.000006	0.000007	0.000006
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Reactor Coolant System Activity	4/14	5/14	6/14	7/14	8/14	9/14	10/14	11/14	12/14	1/15	2/15	3/15
Maximum activity	N/A	0.000004	0.000006	0.000005	0.000012	0.000006	0.000012	0.000014	0.000012	0.000014	0.000011	0.000011
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	N/A	0	0	0	0	0	0	0	0	0	0	0

Licensee Comments: none

Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	4/13	5/13	6/13	7/13	8/13	9/13	10/13	11/13	12/13	1/14	2/14	3/14
Maximum leakage	1.495	1.503	1.496	1.615	1.480	1.488	1.488	1.510	1.456	1.458	1.458	1.467
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	6.0	6.0	6.0	6.5	5.9	6.0	6.0	6.0	5.8	5.8	5.8	5.9
Reactor Coolant System Leakage	4/14	5/14	6/14	7/14	8/14	9/14	10/14	11/14	12/14	1/15	2/15	3/15
Maximum leakage	1.381	2.421	2.330	2.172	2.122	2.253	2.235	2.250	2.190	2.178	2.188	2.211
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	5.5	9.7	9.3	8.7	8.5	9.0	8.9	9.0	8.8	8.7	8.8	8.8

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
Successful opportunities	47.0	31.0	26.0	15.0	51.0	40.0	22.0	28.0
Total opportunities	47.0	33.0	26.0	15.0	52.0	45.0	22.0	28.0
Indicator value	98.6%	97.8%	97.6%	97.3%	97.7%	96.3%	96.9%	97.0%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
Participating Key personnel	70.0	71.0	73.0	73.0	73.0	72.0	75.0	76.0
Total Key personnel	70.0	71.0	73.0	73.0	73.0	72.0	75.0	76.0
Indicator value	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
Successful siren-tests	2684	2686	2687	2641	2687	2686	2686	2641
Total sirens-tests	2688	2688	2688	2646	2688	2688	2688	2646
Indicator value	99.9%	99.9%	99.9%	99.9%	99.9%	99.9%	99.9%	99.9%

Licensee Comments: none

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.

 [Action Matrix Summary](#) | [Inspection Findings Summary](#) | [PI Summary](#) | [Reactor Oversight Process](#)

Last Modified: April 23, 2015