


Susquehanna 2

3Q/2015 Performance Indicators

The solid trend line represents the current reporting period.

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15
Unplanned scrams	0	0	0	0	0	0	1.0	0
Critical hours	2209.0	1714.3	2051.6	1949.8	2209.0	2159.0	1153.9	2208.0
Indicator value	0.9	1.0	0.9	0	0	0	0.9	0.9

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs



Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15
Unplanned power changes	0	1.0	0	0	0	0	0	0
Critical hours	2209.0	1714.3	2051.6	1949.8	2209.0	2159.0	1153.9	2208.0
Indicator value	0.9	1.0	0.9	0.9	0.9	0	0	0

Licensee Comments: none

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

Safety System Functional Failures (BWR)



Thresholds: White > 6.0

Notes


Safety System Functional Failures (BWR)	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15
Safety System Functional Failures	0	2	2	0	0	0	0	1
Indicator value	1	2	4	4	4	2	0	1

Licensee Comments:

2Q/14: LER 387(388) 2014-002-00: Secondary Containment Door Found Ajar; Submitted on April 9, 2014
 LER387(388) 2014-003-00: Loss of Secondary Containment During TS SR 3.6.4.1.5 Drawdown Testing; Submitted on May 1, 2014

1Q/14: LER 387/2013-007-00: Loss of Secondary Containment due to drawdown test failure, submitted on January 21, 2014

Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15
UAI (Δ CDF)	2.14E-07	2.07E-07	4.80E-08	4.13E-08	-6.10E-09	-6.04E-09	-5.95E-09	-6.72E-09
URI (Δ CDF)	-5.78E-06	-5.69E-06	-2.17E-06	-2.09E-06	-2.09E-06	-2.04E-06	-2.09E-06	-2.10E-06
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-5.60E-06	-5.50E-06	-2.10E-06	-2.10E-06	-2.10E-06	-2.00E-06	-2.10E-06	-2.10E-06

Licensee Comments:


3Q/14: Risk Cap Invoked.

2Q/14: Risk Cap Invoked.

1Q/14: Risk Cap Invoked.

4Q/13: Risk Cap Invoked.

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15
UAI (Δ CDF)	5.54E-09	5.74E-09	7.02E-09	7.11E-09	7.57E-11	8.16E-11	2.54E-10	2.54E-10
URI (Δ CDF)	1.83E-08	1.84E-08	3.03E-08	3.03E-08	-9.30E-09	-9.30E-09	-9.36E-09	-9.36E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	2.40E-08	2.40E-08	3.70E-08	3.70E-08	-9.20E-09	-9.20E-09	-9.10E-09	-9.10E-09

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15
UAI (Δ CDF)	3.64E-09	3.79E-09	-1.82E-09	-3.38E-09	-3.49E-09	-3.49E-09	-3.49E-09	-3.49E-09
URI (Δ CDF)	3.24E-08	3.24E-08	1.68E-08	1.75E-08	-1.25E-08	-1.27E-08	-1.29E-08	-1.29E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	3.60E-08	3.60E-08	1.50E-08	1.40E-08	-1.60E-08	-1.60E-08	-1.60E-08	-1.60E-08

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15
UAI (Δ CDF)	1.38E-09	1.02E-09	5.05E-09	6.10E-09	1.25E-08	8.79E-09	9.38E-09	7.21E-09
URI (Δ CDF)	-1.69E-08	-1.72E-08	-6.40E-08	-6.38E-08	-6.38E-08	1.88E-08	1.75E-08	2.40E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.60E-08	-1.60E-08	-5.90E-08	-5.80E-08	-5.10E-08	2.80E-08	2.70E-08	3.10E-08

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15
UAI (Δ CDF)	6.79E-08	7.31E-08	5.31E-08	6.52E-08	6.39E-08	6.18E-08	6.72E-08	7.46E-08
URI (Δ CDF)	-3.11E-08	-3.12E-08	-3.72E-08	-3.80E-08	-3.89E-08	-3.94E-08	-4.00E-08	-4.08E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	3.70E-08	4.20E-08	1.60E-08	2.70E-08	2.50E-08	2.20E-08	2.70E-08	3.40E-08

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	10/13	11/13	12/13	1/14	2/14	3/14	4/14	5/14	6/14	7/14	8/14	9/14
Maximum activity	0.000005	0.000006	0.000007	0.000006	0.000007	N/A	0.000005	0.000006	0.000006	0.000006	0.000006	0.000006
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	0	0	N/A	0	0	0	0	0	0

Reactor Coolant System Activity	10/14	11/14	12/14	1/15	2/15	3/15	4/15	5/15	6/15	7/15	8/15	9/15
Maximum activity	0.000008	0.000007	0.000006	0.000006	0.000006	0.000007	0.000006	N/A	0.000003	0.000004	0.000004	0.000004
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	0	0	0	0	N/A	0	0	0	0

Licensee Comments: none

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Leakage	10/13	11/13	12/13	1/14	2/14	3/14	4/14	5/14	6/14	7/14	8/14	9/14
Maximum leakage	1.790	1.800	1.740	1.740	1.720	1.710	1.760	1.710	1.710	1.730	1.740	1.750
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	7.2	7.2	7.0	7.0	6.9	6.8	7.0	6.8	6.8	6.9	7.0	7.0

Reactor Coolant System Leakage	10/14	11/14	12/14	1/15	2/15	3/15	4/15	5/15	6/15	7/15	8/15	9/15
Maximum leakage	1.790	1.760	1.750	1.770	1.760	1.790	1.780	1.730	1.800	1.840	1.840	1.800
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	7.2	7.0	7.0	7.1	7.0	7.2	7.1	6.9	7.2	7.4	7.4	7.2

Licensee Comments: none

Drill/Exercise Performance



Thresholds: White < 90.0% Yellow < 70.0%


Notes

Drill/Exercise Performance	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15
Successful opportunities	24.0	56.0	25.0	36.0	20.0	29.0	40.0	49.0
Total opportunities	25.0	59.0	26.0	38.0	22.0	30.0	40.0	53.0
Indicator value	96.2%	96.4%	96.1%	95.3%	95.1%	95.0%	95.8%	95.2%

Licensee Comments:

3Q/14: Data for Drill / Exercise Performance was revised based on reevaluation of the data over the past two years. Specifically, data was revised for the following time periods: July 2012; April, Nov & Dec 2013; Feb, March & June 2014. The PI color was Green before the revisions and remains Green after the revisions for each of the time periods. There is no safety significance associated with these revisions.

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15
Participating Key personnel	91.0	94.0	90.0	86.0	82.0	78.0	80.0	80.0
Total Key personnel	91.0	94.0	90.0	86.0	82.0	78.0	80.0	80.0
Indicator value	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15
Successful siren-tests	532	608	530	684	532	532	532	608
Total sirens-tests	532	608	532	684	532	532	532	608
Indicator value	100.0%	100.0%	99.9%	99.9%	99.9%	99.9%	100.0%	100.0%

Licensee Comments: none

Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	4Q/13	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.

 [Action Matrix Summary](#) | [Inspection Findings Summary](#) | [PI Summary](#) | [Reactor Oversight Process](#)

Last Modified: December 15, 2015