


Byron 2

4Q/2015 Performance Indicators

The solid trend line represents the current reporting period.

Licensee's General Comments: Byron Unit 2 4Q2015

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
Unplanned scrams	0	0	0	0	0	0	0	0
Critical hours	2159.0	2184.0	2160.0	1664.2	2159.0	2184.0	2208.0	2209.0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs



Thresholds: White > 6.0


Notes

Unplanned Power Changes per 7000 Critical Hrs	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
Unplanned power changes	1.0	1.0	0	0	0	0	0	0
Critical hours	2159.0	2184.0	2160.0	1664.2	2159.0	2184.0	2208.0	2209.0
Indicator value	0.9	1.6	1.6	1.7	0.9	0	0	0

Licensee Comments:

1Q/14: Power was lowered from 100% to 49% within 4 hours from when the shutdown rods mis-positioned. To recover the two shutdown rods. power was lowered from 49% to 38.4%. ICES # 302697, IR 1607715.

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

Safety System Functional Failures (PWR)




Thresholds: White > 5.0

Notes

Safety System Functional Failures (PWR)	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
Safety System Functional Failures	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
UAI (Δ CDF)	-7.87E-09	3.98E-09	6.35E-09	3.04E-08	3.77E-09	-1.44E-08	-1.44E-08	-1.44E-08
URI (Δ CDF)	-8.96E-08	-7.56E-08	-6.07E-08	-4.47E-08	-2.75E-09	-2.75E-09	-2.75E-09	-2.75E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-9.70E-08	-7.20E-08	-5.40E-08	-1.40E-08	1.00E-09	-1.70E-08	-1.70E-08	-1.70E-08

Licensee Comments: none

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
UAI (Δ CDF)	-2.89E-08	-2.89E-08	-2.89E-08	-2.89E-08	-2.89E-08	-2.89E-08	-2.44E-08	-2.89E-08
URI (Δ CDF)	-8.70E-09	-8.70E-09	-8.70E-09	-8.70E-09	-8.61E-09	-8.61E-09	-8.61E-09	-8.61E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-3.80E-08	-3.80E-08	-3.80E-08	-3.80E-08	-3.80E-08	-3.80E-08	-3.30E-08	-3.80E-08

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
UAI (Δ CDF)	9.26E-09	6.48E-09	4.63E-09	-6.01E-08	-5.79E-08	-1.06E-08	5.42E-09	4.62E-09
URI (Δ CDF)	-3.85E-07	-3.85E-07	-3.87E-07	-3.73E-07	-3.60E-07	-3.55E-07	-3.57E-07	-3.57E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-3.80E-07	-3.80E-07	-3.80E-07	-4.30E-07	-4.20E-07	-3.70E-07	-3.50E-07	-3.50E-07

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
UAI (Δ CDF)	-3.33E-08	-3.33E-08	-3.33E-08	-3.33E-08	-3.33E-08	-2.47E-08	-3.33E-08	-3.33E-08
URI (Δ CDF)	-9.77E-08	-9.77E-08	-9.77E-08	-9.77E-08	-9.77E-08	-9.77E-08	-9.77E-08	-9.77E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.30E-07	-1.30E-07	-1.30E-07	-1.30E-07	-1.30E-07	-1.20E-07	-1.30E-07	-1.30E-07

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
UAI (Δ CDF)	1.79E-08	5.32E-08	4.59E-08	4.73E-08	1.38E-07	1.01E-07	1.74E-07	1.78E-07
URI (Δ CDF)	-1.12E-07	-1.07E-07	-1.03E-07	-9.81E-08	-9.23E-08	-9.23E-08	-9.23E-08	-9.23E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-9.40E-08	-5.40E-08	-5.70E-08	-5.10E-08	4.60E-08	8.40E-09	8.20E-08	8.50E-08

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	1/14	2/14	3/14	4/14	5/14	6/14	7/14	8/14	9/14	10/14	11/14	12/14
Maximum activity	0.000069	0.000072	0.000073	0.000076	0.000087	0.000078	0.000082	0.000085	0.000084	0.000045	0.000050	0.000054
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Reactor Coolant System Activity	1/15	2/15	3/15	4/15	5/15	6/15	7/15	8/15	9/15	10/15	11/15	12/15
Maximum activity	0.000056	0.000056	0.000063	0.000067	0.000065	0.000069	0.000076	0.000070	0.000071	0.000073	0.000070	0.000078
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Licensee Comments: none

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Leakage	1/14	2/14	3/14	4/14	5/14	6/14	7/14	8/14	9/14	10/14	11/14	12/14
Maximum leakage	0.090	0.080	0.070	0.060	0.070	0.060	0.050	0.050	0.050	0.080	0.050	0.050
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.9	0.8	0.7	0.6	0.7	0.6	0.5	0.5	0.5	0.8	0.5	0.5

Reactor Coolant System Leakage	1/15	2/15	3/15	4/15	5/15	6/15	7/15	8/15	9/15	10/15	11/15	12/15
Maximum leakage	0.060	0.050	0.050	0.050	0.050	0.060	0.050	0.050	0.050	0.050	0.070	0.060
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.6	0.5	0.5	0.5	0.5	0.6	0.5	0.5	0.5	0.5	0.7	0.6

Licensee Comments: none

Drill/Exercise Performance



Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
Successful opportunities	62.0	70.0	90.0	14.0	74.0	41.0	27.0	32.0
Total opportunities	64.0	71.0	92.0	14.0	74.0	43.0	27.0	32.0
Indicator value	99.5%	99.2%	98.8%	98.9%	98.8%	98.4%	98.3%	98.3%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
Participating Key personnel	77.0	79.0	78.0	77.0	74.0	74.0	72.0	75.0
Total Key personnel	77.0	79.0	78.0	77.0	74.0	74.0	72.0	75.0
Indicator value	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

Alert & Notification System



Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
Successful siren-tests	3841	3898	3896	3901	3834	3902	3962	3903
Total sirens-tests	3843	3904	3904	3904	3840	3904	3965	3904
Indicator value	99.9%	99.9%	99.9%	99.9%	99.9%	99.9%	99.9%	99.9%

Licensee Comments: none

Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.

▲ [Action Matrix Summary](#) | [Inspection Findings Summary](#) | [PI Summary](#) | [Reactor Oversight Process](#)

Last Modified: March 1, 2016