


Davis-Besse

4Q/2015 Performance Indicators

The solid trend line represents the current reporting period.

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
Unplanned scrams	0	0	0	0	0	1.0	0	0
Critical hours	746.4	1330.2	2208.0	2209.0	2159.0	2136.9	2208.0	2209.0
Indicator value	1.0	0	0	0	0	0.8	0.8	0.8

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
Unplanned power changes	0	0	0	0	0	0	0	0
Critical hours	746.4	1330.2	2208.0	2209.0	2159.0	2136.9	2208.0	2209.0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
Scrams with complications	0	0	0	0	0	1.0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	1.0	1.0	1.0

Licensee Comments: none

Safety System Functional Failures (PWR)



Thresholds: White > 5.0

Notes

Safety System Functional Failures (PWR)	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
Safety System Functional Failures	0	0	0	2	0	0	1	1
Indicator value	0	0	0	2	2	2	3	2


Licensee Comments:

4Q/15: LER 2015-001 Revision 01, "Borated Water Storage Tank (BWST) Rendered Inoperable due to Use of Non-Seismic Purification System," dated 11/2/15

3Q/15: LER 2015-003-00, Inadvertent Breaker Operation Renders Control Room Emergency Air Temperature Control System Inoperable

4Q/14: Two failures documented in LER 2014-003, "Door Latch Failure Results in Loss of Emergency Ventilation System Function."

Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
UAI (Δ CDF)	-2.41E-09	2.00E-08	7.22E-08	5.80E-08	4.15E-08	3.60E-08	3.73E-08	-1.49E-08
URI (Δ CDF)	-1.32E-07	-1.32E-07	-1.30E-07	-1.21E-07	-1.21E-07	-1.21E-07	-1.21E-07	-1.22E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.30E-07	-1.10E-07	-5.80E-08	-6.30E-08	-7.90E-08	-8.50E-08	-8.40E-08	-1.40E-07

Licensee Comments: none

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
UAI (Δ CDF)	8.11E-09	1.48E-08	1.07E-08	9.35E-09	8.07E-09	6.85E-09	5.14E-09	3.26E-09
URI (Δ CDF)	-3.50E-09	-3.62E-09	-3.57E-09	-3.27E-09	-3.20E-09	-2.73E-09	-2.68E-09	-2.78E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	4.60E-09	1.10E-08	7.10E-09	6.10E-09	4.90E-09	4.10E-09	2.50E-09	4.80E-10

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
UAI (Δ CDF)	4.86E-11	-6.43E-09	-5.20E-09	-1.10E-08	-1.05E-08	-1.04E-08	-6.60E-09	-1.87E-08
URI (Δ CDF)	-6.59E-07	-6.57E-07	-6.54E-07	-6.56E-07	-6.55E-07	-6.55E-07	-6.59E-07	-6.53E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-6.60E-07	-6.60E-07	-6.60E-07	-6.70E-07	-6.70E-07	-6.70E-07	-6.70E-07	-6.70E-07

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
UAI (Δ CDF)	3.37E-08	3.10E-08	3.61E-08	3.35E-08	2.94E-08	2.88E-08	2.87E-08	1.71E-08
URI (Δ CDF)	6.34E-09	4.79E-09	4.79E-09	9.04E-09	8.41E-09	1.31E-08	1.33E-08	1.36E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	4.00E-08	3.60E-08	4.10E-08	4.30E-08	3.80E-08	4.20E-08	4.20E-08	3.10E-08

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
UAI (Δ CDF)	-3.58E-11	-3.58E-11	-3.58E-11	-3.58E-11	-3.58E-11	-3.55E-11	-3.55E-11	-3.55E-11
URI (Δ CDF)	-7.24E-09	-7.08E-09	-7.06E-09	-6.71E-09	-6.74E-09	-2.25E-09	-2.15E-09	-2.06E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-7.30E-09	-7.10E-09	-7.10E-09	-6.70E-09	-6.80E-09	-2.30E-09	-2.20E-09	-2.10E-09

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	1/14	2/14	3/14	4/14	5/14	6/14	7/14	8/14	9/14	10/14	11/14	12/14
Maximum activity	0.001500	N/A	N/A	N/A	0.000440	0.000440	0.000480	0.000490	0.000470	0.000500	0.000480	0.000480
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0.2	N/A	N/A	N/A	0	0	0	0	0	0.1	0	0

Reactor Coolant System Activity	1/15	2/15	3/15	4/15	5/15	6/15	7/15	8/15	9/15	10/15	11/15	12/15
Maximum activity	0.000530	0.000500	0.000490	0.000590	0.000540	0.000580	0.000620	0.000530	0.000540	0.000540	0.000560	0.000610
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0.1	0.1	0	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1

Licensee Comments: none

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Leakage	1/14	2/14	3/14	4/14	5/14	6/14	7/14	8/14	9/14	10/14	11/14	12/14
Maximum leakage	0.548	N/A	N/A	N/A	0.075	0.083	0.083	0.080	0.079	0.083	0.086	0.093
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	5.5	N/A	N/A	N/A	0.8	0.8	0.8	0.8	0.8	0.8	0.9	0.9

Reactor Coolant System Leakage	1/15	2/15	3/15	4/15	5/15	6/15	7/15	8/15	9/15	10/15	11/15	12/15
Maximum leakage	0.093	0.090	0.093	0.094	0.092	0.089	0.089	0.108	0.110	0.144	0.167	0.218
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.9	0.9	0.9	0.9	0.9	0.9	0.9	1.1	1.1	1.4	1.7	2.2

Licensee Comments: none

Drill/Exercise Performance



Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
Successful opportunities	8.0	14.0	16.0	80.0	32.0	16.0	16.0	41.0
Total opportunities	8.0	14.0	16.0	80.0	32.0	18.0	17.0	41.0
Indicator value	95.2%	95.3%	96.3%	97.1%	98.4%	99.3%	98.9%	98.7%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
Participating Key personnel	95.0	91.0	89.0	88.0	87.0	87.0	86.0	91.0
Total Key personnel	95.0	91.0	89.0	88.0	87.0	87.0	86.0	91.0
Indicator value	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
Successful siren-tests	701	700	701	699	702	701	702	701
Total sirens-tests	702	702	702	702	702	702	702	702
Indicator value	99.9%	99.8%	99.9%	99.8%	99.8%	99.8%	99.9%	99.9%

Licensee Comments: none

Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.

▲ [Action Matrix Summary](#) | [Inspection Findings Summary](#) | [PI Summary](#) | [Reactor Oversight Process](#)

Last Modified: March 1, 2016