


Harris 1

4Q/2015 Performance Indicators

The solid trend line represents the current reporting period.

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
Unplanned scrams	1.0	0	0	0	0	0	0	0
Critical hours	2072.6	2050.3	2208.0	2209.0	2159.0	1166.2	2208.0	2209.0
Indicator value	0.9	0.9	0.9	0.8	0	0	0	0

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
Unplanned power changes	0	0	0	0	0	0	0	0
Critical hours	2072.6	2050.3	2208.0	2209.0	2159.0	1166.2	2208.0	2209.0
Indicator value	0.9	0	0	0	0	0	0	0

Licensee Comments: none

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

Safety System Functional Failures (PWR)



Thresholds: White > 5.0

Notes


Safety System Functional Failures (PWR)	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
Safety System Functional Failures	0	0	0	1	0	1	2	0
Indicator value	0	0	0	1	1	2	4	3

Licensee Comments:

3Q/15: Licensee Event Reports were submitted in both July 2015 and August 2015 that involved safety system functional failures. They were LER 2015-004-01 and LER 2015-005-00, respectively.

2Q/15: There was one Licensee Event Report submitted in June 2015 which involved a safety system functional failure. LER No. 2015-002-00

Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
UAI (Δ CDF)	1.08E-08	1.22E-08	1.17E-08	1.48E-08	1.44E-08	1.44E-08	1.44E-08	1.72E-08
URI (Δ CDF)	-9.73E-09	-9.34E-09	-8.93E-09	-8.51E-09	-8.51E-09	-4.96E-08	-4.96E-08	-4.96E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	1.00E-09	2.90E-09	2.70E-09	6.30E-09	5.80E-09	-3.50E-08	-3.50E-08	-3.20E-08

Licensee Comments: none

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
UAI (Δ CDF)	9.06E-09	9.67E-09	1.03E-08	1.04E-08	8.11E-09	7.32E-09	1.01E-08	1.09E-08
URI (Δ CDF)	-9.44E-09	-9.33E-09	-9.22E-09	-9.11E-09	-9.11E-09	-9.11E-09	-9.11E-09	-9.11E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-3.80E-10	3.40E-10	1.10E-09	1.30E-09	-1.00E-09	-1.80E-09	9.90E-10	1.80E-09

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
UAI (Δ CDF)	9.14E-09	9.49E-09	1.25E-08	1.25E-08	1.51E-08	1.52E-08	1.52E-08	9.31E-09
URI (Δ CDF)	-6.75E-08	-6.75E-08	-6.56E-08	-6.33E-08	-6.33E-08	-6.33E-08	-6.33E-08	-6.33E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-5.80E-08	-5.80E-08	-5.30E-08	-5.10E-08	-4.80E-08	-4.80E-08	-4.80E-08	-5.40E-08

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
UAI (Δ CDF)	1.98E-08	1.55E-08	1.92E-08	2.42E-08	2.02E-08	1.82E-08	2.49E-08	1.51E-08
URI (Δ CDF)	2.81E-08	-2.93E-08	-2.88E-08	-2.82E-08	-2.82E-08	-2.82E-08	-2.82E-08	-2.82E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	4.80E-08	-1.40E-08	-9.50E-09	-4.00E-09	-8.00E-09	-1.00E-08	-3.20E-09	-1.30E-08

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
UAI (Δ CDF)	2.31E-08	4.04E-08	4.46E-08	3.64E-08	1.73E-08	1.85E-08	2.28E-08	2.11E-08
URI (Δ CDF)	-1.03E-07	-1.03E-07	-1.03E-07	-1.02E-07	-1.02E-07	-1.01E-08	-1.01E-08	-1.01E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-8.00E-08	-6.30E-08	-5.80E-08	-6.60E-08	-8.50E-08	8.40E-09	1.30E-08	1.10E-08

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	1/14	2/14	3/14	4/14	5/14	6/14	7/14	8/14	9/14	10/14	11/14	12/14
Maximum activity	0.000131	0.000105	0.000113	0.000330	0.000130	0.000139	0.000147	0.000131	0.000138	0.000138	0.000147	0.000155
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Reactor Coolant System Activity	1/15	2/15	3/15	4/15	5/15	6/15	7/15	8/15	9/15	10/15	11/15	12/15
Maximum activity	0.000153	0.000160	0.000162	0.000159	0.000090	0.000092	0.000404	0.000089	0.000094	0.000147	0.000104	0.000163
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Licensee Comments: none

Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	1/14	2/14	3/14	4/14	5/14	6/14	7/14	8/14	9/14	10/14	11/14	12/14
Maximum leakage	0.027	0.028	0.037	0.029	0.029	0.030	0.035	0.036	0.042	0.051	0.054	0.055
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.3	0.3	0.4	0.3	0.3	0.3	0.4	0.4	0.4	0.5	0.5	0.6
Reactor Coolant System Leakage	1/15	2/15	3/15	4/15	5/15	6/15	7/15	8/15	9/15	10/15	11/15	12/15
Maximum leakage	0.058	0.056	0.055	0.050	0.019	0.018	0.016	0.015	0.014	0.015	0.015	0.015
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.6	0.6	0.6	0.5	0.2	0.2	0.2	0.2	0.1	0.2	0.2	0.2

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
Successful opportunities	40.0	44.0	31.0	28.0	24.0	11.0	38.0	33.0
Total opportunities	41.0	44.0	32.0	28.0	26.0	11.0	39.0	35.0
Indicator value	96.4%	97.1%	97.8%	97.9%	97.2%	97.7%	97.9%	97.3%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
Participating Key personnel	44.0	49.0	50.0	54.0	55.0	54.0	49.0	51.0
Total Key personnel	44.0	49.0	50.0	54.0	55.0	54.0	49.0	51.0
Indicator value	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
Successful siren-tests	581	580	746	664	581	581	746	664
Total sirens-tests	581	581	747	664	581	581	747	664
Indicator value	99.8%	99.9%	99.9%	99.9%	99.9%	100.0%	100.0%	100.0%

Licensee Comments: none

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	1Q/14	2Q/14	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.

▲ [Action Matrix Summary](#) | [Inspection Findings Summary](#) | [PI Summary](#) | [Reactor Oversight Process](#)

Last Modified: March 1, 2016