


Arkansas Nuclear 1

2Q/2016 Performance Indicators

The solid trend line represents the current reporting period.

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16
Unplanned scrams	0	0	0	0	0	1.0	0	0
Critical hours	2208.0	2209.0	1339.4	2184.0	2208.0	2141.3	2183.0	2184.0
Indicator value	0	0	0	0	0	0.9	0.8	0.8

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16
Unplanned power changes	0	0	0	0	0	0	0	0
Critical hours	2208.0	2209.0	1339.4	2184.0	2208.0	2141.3	2183.0	2184.0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Licensee Comments: none

Safety System Functional Failures (PWR)



Thresholds: White > 5.0


Notes

Safety System Functional Failures (PWR)	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16
Safety System Functional Failures	0	0	0	0	0	0	0	1
Indicator value	1	1	1	0	0	0	0	1

Licensee Comments:

2Q/16: LER 50-313/2016-001-00

Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16
UAI (Δ CDF)	-2.20E-09	-2.21E-09	-2.20E-09	-9.63E-10	-7.00E-10	5.40E-10	5.36E-10	-4.95E-10
URI (Δ CDF)	-2.11E-08	-2.03E-08	-2.04E-08	-2.05E-08	-2.04E-08	-2.05E-08	-2.02E-08	-1.46E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-2.30E-08	-2.20E-08	-2.30E-08	-2.10E-08	-2.10E-08	-2.00E-08	-2.00E-08	-1.50E-08

Licensee Comments: none

Mitigating Systems Performance Index, High Pressure Injection System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


Notes

Mitigating Systems Performance Index, High Pressure Injection System	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16
UAI (Δ CDF)	-8.24E-12	-8.34E-12	-8.24E-12	-8.24E-12	-8.24E-12	-8.23E-12	-8.26E-12	-8.49E-12
URI (Δ CDF)	-4.66E-09	-4.67E-09	-4.67E-09	-4.67E-09	-4.65E-09	-4.66E-09	-4.69E-09	-4.76E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-4.70E-09	-4.70E-09	-4.70E-09	-4.70E-09	-4.70E-09	-4.70E-09	-4.70E-09	-4.80E-09

Licensee Comments:

3Q/14: ANO-1 HPI Reliability for P36A in August was revised. Oper Non-Test demands and Run Hours were originally reported under Test. This change does not affect the color of this indicator.

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16
UAI (Δ CDF)	-4.02E-09	-4.59E-09	5.76E-10	-1.14E-09	-1.14E-09	-3.57E-09	-6.33E-09	-3.95E-09
URI (Δ CDF)	-2.06E-08	-2.01E-08	-2.22E-08	-2.22E-08	-2.14E-08	-2.19E-08	-2.22E-08	-2.29E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-2.50E-08	-2.50E-08	-2.20E-08	-2.30E-08	-2.30E-08	-2.50E-08	-2.90E-08	-2.70E-08

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16
UAI (Δ CDF)	4.73E-08	5.58E-08	5.09E-08	5.09E-08	5.06E-08	4.80E-08	5.48E-08	4.88E-08
URI (Δ CDF)	3.73E-08	5.08E-08	3.66E-08	3.66E-08	3.86E-08	4.25E-08	-4.54E-08	-3.77E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	8.50E-08	1.10E-07	8.80E-08	8.80E-08	8.90E-08	9.00E-08	9.40E-09	1.10E-08

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16
UAI (Δ CDF)	-3.39E-09	-3.39E-09	-3.39E-09	-3.39E-09	-3.39E-09	-3.39E-09	-3.39E-09	-3.40E-09
URI (Δ CDF)	-1.67E-09	-4.48E-09	-4.48E-09	6.47E-08	6.47E-08	6.47E-08	6.47E-08	6.48E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-5.10E-09	-7.90E-09	-7.90E-09	6.10E-08	6.10E-08	6.10E-08	6.10E-08	6.10E-08

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	7/14	8/14	9/14	10/14	11/14	12/14	1/15	2/15	3/15	4/15	5/15	6/15
Maximum activity	0.000142	0.000103	0.000157	0.000160	0.000185	0.000144	0.000149	N/A	0.000049	0.000053	0.000058	0.000216
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0	0	0	0	0	N/A	0	0	0	0

Reactor Coolant System Activity	7/15	8/15	9/15	10/15	11/15	12/15	1/16	2/16	3/16	4/16	5/16	6/16
Maximum activity	0.000220	0.000208	0.000143	0.000140	0.000194	0.034700	0.000122	0.000153	0.000173	0.000166	0.000214	0.000207
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0	0	0	3.5	0	0	0	0	0	0

Licensee Comments: none

Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	7/14	8/14	9/14	10/14	11/14	12/14	1/15	2/15	3/15	4/15	5/15	6/15
Maximum leakage	0.135	0.165	0.164	0.159	0.160	0.159	0.148	0.135	0.127	0.100	0.125	0.137
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	1.4	1.7	1.6	1.6	1.6	1.6	1.5	1.4	1.3	1.0	1.3	1.4
Reactor Coolant System Leakage	7/15	8/15	9/15	10/15	11/15	12/15	1/16	2/16	3/16	4/16	5/16	6/16
Maximum leakage	0.163	0.168	0.177	0.175	0.182	0.198	0.132	0.128	0.116	0.125	0.121	0.125
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	1.6	1.7	1.8	1.8	1.8	2.0	1.3	1.3	1.2	1.3	1.2	1.3

Licensee Comments: none

Drill/Exercise Performance



Thresholds: White < 90.0% Yellow < 70.0%

Notes


Drill/Exercise Performance	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16
Successful opportunities	108.0	61.0	16.0	93.0	65.0	19.0	31.0	93.0
Total opportunities	111.0	61.0	16.0	98.0	67.0	19.0	32.0	94.0
Indicator value	96.7%	97.6%	97.7%	97.1%	97.2%	97.2%	97.6%	97.6%

Licensee Comments:

2Q/15: The June Drill/Exercise Performance is being revised to include two Shift Manager requalification exams. This change does not affect the color of the Drill/Exercise Performance indicator.

3Q/14: The September Drill / Exercise Performance was revised to included three notification communicator drills. This change dose not affect the color of this indicator.

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16
Participating Key personnel	119.0	116.0	113.0	109.0	106.0	103.0	103.0	108.0
Total Key personnel	119.0	116.0	113.0	109.0	106.0	103.0	103.0	108.0
Indicator value	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16
Successful siren-tests	147	146	147	147	147	146	147	147
Total sirens-tests	147	147	147	147	147	147	147	147
Indicator value	99.8%	99.7%	99.8%	99.8%	99.8%	99.8%	99.8%	99.8%

Licensee Comments: none

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.

▲ [Action Matrix Summary](#) | [Inspection Findings Summary](#) | [PI Summary](#) | [Reactor Oversight Process](#)

Last Modified: July 25, 2016