


Davis-Besse

2Q/2016 Performance Indicators

The solid trend line represents the current reporting period.

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16
Unplanned scrams	0	0	0	1.0	0	0	1.0	0
Critical hours	2208.0	2209.0	2159.0	2136.9	2208.0	2209.0	1993.2	1277.4
Indicator value	0	0	0	0.8	0.8	0.8	1.6	0.9

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16
Unplanned power changes	0	0	0	0	0	0	0	0
Critical hours	2208.0	2209.0	2159.0	2136.9	2208.0	2209.0	1993.2	1277.4
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16
Scrams with complications	0	0	0	1.0	0	0	1.0	0
Indicator value	0.0	0.0	0.0	1.0	1.0	1.0	2.0	1.0

Licensee Comments: none

Safety System Functional Failures (PWR)



Thresholds: White > 5.0

Notes

Safety System Functional Failures (PWR)	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16
Safety System Functional Failures	0	2	0	0	1	1	0	1
Indicator value	0	2	2	2	3	2	2	3


Licensee Comments:

4Q/15: LER 2015-001 Revision 01, "Borated Water Storage Tank (BWST) Rendered Inoperable due to Use of Non-Seismic Purification System," dated 11/2/15

3Q/15: LER 2015-003-00, Inadvertent Breaker Operation Renders Control Room Emergency Air Temperature Control System Inoperable

4Q/14: Two failures documented in LER 2014-003, "Door Latch Failure Results in Loss of Emergency Ventilation System Function."

Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16
UAI (Δ CDF)	7.22E-08	5.80E-08	4.15E-08	3.60E-08	3.73E-08	-1.49E-08	-2.84E-08	-2.35E-08
URI (Δ CDF)	-1.30E-07	-1.21E-07	-1.21E-07	-1.21E-07	-1.21E-07	-1.22E-07	-1.21E-07	-1.29E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-5.80E-08	-6.30E-08	-7.90E-08	-8.50E-08	-8.40E-08	-1.40E-07	-1.50E-07	-1.50E-07

Licensee Comments: none

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16
UAI (Δ CDF)	1.07E-08	9.35E-09	8.07E-09	6.85E-09	5.14E-09	3.26E-09	9.83E-09	5.42E-09
URI (Δ CDF)	-3.57E-09	-3.27E-09	-3.20E-09	-2.73E-09	-2.68E-09	-2.78E-09	-2.71E-09	-3.20E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	7.10E-09	6.10E-09	4.90E-09	4.10E-09	2.50E-09	4.80E-10	7.10E-09	2.20E-09

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16
UAI (Δ CDF)	-5.20E-09	-1.10E-08	-1.05E-08	-1.04E-08	-6.60E-09	-1.87E-08	-1.81E-08	-1.71E-08
URI (Δ CDF)	-6.54E-07	-6.56E-07	-6.55E-07	-6.55E-07	-6.59E-07	-6.53E-07	-6.55E-07	-6.53E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-6.60E-07	-6.70E-07	-6.70E-07	-6.70E-07	-6.70E-07	-6.70E-07	-6.70E-07	-6.70E-07

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16
UAI (Δ CDF)	3.61E-08	3.35E-08	2.94E-08	2.88E-08	2.87E-08	1.71E-08	3.81E-09	8.76E-09
URI (Δ CDF)	4.79E-09	9.04E-09	8.41E-09	1.31E-08	1.33E-08	1.36E-08	1.35E-08	8.12E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	4.10E-08	4.30E-08	3.80E-08	4.20E-08	4.20E-08	3.10E-08	1.70E-08	1.70E-08

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16
UAI (Δ CDF)	-3.58E-11	-3.58E-11	-3.58E-11	-3.55E-11	-3.55E-11	-3.55E-11	-3.55E-11	-3.55E-11
URI (Δ CDF)	-7.06E-09	-6.71E-09	-6.74E-09	-2.25E-09	-2.15E-09	-2.06E-09	-1.96E-09	-3.99E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-7.10E-09	-6.70E-09	-6.80E-09	-2.30E-09	-2.20E-09	-2.10E-09	-2.00E-09	-4.00E-09

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0

Notes


Reactor Coolant System Activity	7/14	8/14	9/14	10/14	11/14	12/14	1/15	2/15	3/15	4/15	5/15	6/15
Maximum activity	0.000480	0.000490	0.000470	0.000500	0.000480	0.000480	0.000530	0.000500	0.000490	0.000590	0.000540	0.000580
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0	0.1	0	0	0.1	0.1	0	0.1	0.1	0.1

Reactor Coolant System Activity	7/15	8/15	9/15	10/15	11/15	12/15	1/16	2/16	3/16	4/16	5/16	6/16
Maximum activity	0.000620	0.000530	0.000540	0.000540	0.000560	0.000610	0.000560	0.000590	0.000510	N/A	0.000150	0.000160
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	N/A	0	0

Licensee Comments:

3/16: Minor data discrepancy corrected for February 2016, change did not affect indicator color.

Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	7/14	8/14	9/14	10/14	11/14	12/14	1/15	2/15	3/15	4/15	5/15	6/15
Maximum leakage	0.083	0.080	0.079	0.083	0.086	0.093	0.093	0.090	0.093	0.094	0.092	0.089
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.8	0.8	0.8	0.8	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9
Reactor Coolant System Leakage	7/15	8/15	9/15	10/15	11/15	12/15	1/16	2/16	3/16	4/16	5/16	6/16
Maximum leakage	0.089	0.108	0.110	0.144	0.167	0.218	0.226	0.213	0.204	N/A	0.161	0.152
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.9	1.1	1.1	1.4	1.7	2.2	2.3	2.1	2.0	N/A	1.6	1.5

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16
Successful opportunities	16.0	80.0	32.0	16.0	16.0	41.0	0	2.0
Total opportunities	16.0	80.0	32.0	18.0	17.0	41.0	0	2.0
Indicator value	96.3%	97.1%	98.4%	99.3%	98.9%	98.7%	98.6%	98.5%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16
Participating Key personnel	89.0	88.0	87.0	87.0	86.0	91.0	90.0	88.0
Total Key personnel	89.0	88.0	87.0	87.0	86.0	91.0	90.0	88.0
Indicator value	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16
Successful siren-tests	701	699	702	701	702	701	702	702
Total sirens-tests	702	702	702	702	702	702	702	702
Indicator value	99.9%	99.8%	99.8%	99.8%	99.9%	99.9%	99.9%	100.0%

Licensee Comments: none

Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	3Q/14	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.

▲ [Action Matrix Summary](#) | [Inspection Findings Summary](#) | [PI Summary](#) | [Reactor Oversight Process](#)

Last Modified: July 25, 2016