


Palo Verde 1

3Q/2016 Performance Indicators

The solid trend line represents the current reporting period.

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16
Unplanned scrams	0	0	0	0	0	0	0	1.0
Critical hours	1475.5	2160.0	2184.0	2208.0	2208.0	2184.0	1346.9	2099.8
Indicator value	0	0	0	0	0	0	0	0.9

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16
Unplanned power changes	0	0	0	0	0	0	1.0	0
Critical hours	1475.5	2160.0	2184.0	2208.0	2208.0	2184.0	1346.9	2099.8
Indicator value	0	0	0	0	0	0	0.9	0.9

Licensee Comments: none

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16
Scrams with complications	0	0	0	0	0	0	0	1.0
Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0

Licensee Comments: none

Safety System Functional Failures (PWR)




Thresholds: White > 5.0

Notes

Safety System Functional Failures (PWR)	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16
Safety System Functional Failures	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16
UAI (Δ CDF)	1.13E-08	3.58E-09	3.58E-09	3.35E-09	4.40E-09	5.38E-09	-7.47E-10	8.26E-09
URI (Δ CDF)	1.52E-08	1.52E-08	1.52E-08	1.52E-08	1.52E-08	1.52E-08	1.52E-08	1.52E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	2.60E-08	1.90E-08	1.90E-08	1.90E-08	2.00E-08	2.10E-08	1.40E-08	2.30E-08

Licensee Comments:

3Q/15: In 3rd Quarter 2015, updated unavailability for EDG 1A for interval March 2013 - October 2014, net change was (-) 12.43 hours and EDG 1B for May 2013, net change was (-) 10.62 hours , no color change as a result.

2Q/15: In May 2015, planned unavailability hours from March 2013 were adjusted resulting in a net decrease of 9.59 planned unavailability hours for the 3 year period ending in June 2015. The adjustments were made to account for hours unavailable vs. hours inoperable, previously recorded and not have resulted in a color change.


2Q/15: In May 2015, planned unavailability hours from March 2013 were adjusted resulting in a net decrease of 9.59 planned unavailability hours for the 3 year period ending in June 2015. The adjustments were made to account for hours unavailable vs. hours inoperable, previously recorded and not have resulted in a color change.

4Q/14: In May 2015, planned unavailability hours from March 2013 were adjusted resulting in a net decrease of 9.59 planned unavailability hours for the 3 year period ending in June 2015. The adjustments were made to account for hours unavailable vs. hours inoperable, previously recorded and not have resulted in a color change.

Additionally, In 3rd Quarter 2015, updated October 2014 unavailability for EDG 1A, net change was (-) 11.32 hours, no color change as a result.

4Q/14: In May 2015, planned unavailability hours from March 2013 were adjusted resulting in a net decrease of 9.59 planned unavailability hours for the 3 year period ending in June 2015. The adjustments were made to account for hours unavailable vs. hours inoperable, previously recorded and not have resulted in a color change.

Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16
UAI (ΔCDF)	-1.52E-09	-1.52E-09	-1.52E-09	-1.52E-09	-1.52E-09	-1.52E-09	-1.52E-09	-1.52E-09
URI (ΔCDF)	-1.03E-08	-1.03E-08	-1.03E-08	-1.03E-08	-1.03E-08	-1.03E-08	-1.03E-08	-1.03E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.20E-08	-1.20E-08	-1.20E-08	-1.20E-08	-1.20E-08	-1.20E-08	-1.20E-08	-1.20E-08

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16
UAI (Δ CDF)	-4.84E-08	-4.84E-08	-4.84E-08	-4.84E-08	-4.84E-08	-4.84E-08	-4.84E-08	-4.84E-08
URI (Δ CDF)	-5.15E-08	-5.15E-08	-5.15E-08	-5.15E-08	-5.15E-08	-5.15E-08	-5.15E-08	-5.15E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.00E-07	-1.00E-07	-1.00E-07	-1.00E-07	-1.00E-07	-1.00E-07	-1.00E-07	-1.00E-07

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16
UAI (Δ CDF)	-1.67E-10	-4.19E-10	-7.93E-10	-1.16E-09	-1.19E-09	-4.58E-10	-2.81E-10	-1.28E-09
URI (Δ CDF)	-6.37E-09	-6.37E-09	-6.37E-09	-6.37E-09	-6.37E-09	-6.37E-09	-6.37E-09	-6.37E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-6.50E-09	-6.80E-09	-7.20E-09	-7.50E-09	-7.60E-09	-6.80E-09	-6.70E-09	-7.70E-09

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16
UAI (Δ CDF)	1.74E-08	1.16E-08	1.14E-08	1.12E-08	1.11E-08	1.06E-08	4.84E-09	8.65E-09
URI (Δ CDF)	-4.57E-08	-4.57E-08	-4.57E-08	-4.57E-08	-4.57E-08	-4.57E-08	-4.57E-08	-4.57E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-2.80E-08	-3.40E-08	-3.40E-08	-3.40E-08	-3.50E-08	-3.50E-08	-4.10E-08	-3.70E-08

Licensee Comments: none

Reactor Coolant System Activity




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Activity	10/14	11/14	12/14	1/15	2/15	3/15	4/15	5/15	6/15	7/15	8/15	9/15
Maximum activity	0.000313	0.000166	0.000179	0.000180	0.000187	0.000188	0.000190	0.000198	0.000212	0.000210	0.000230	0.000281
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0
Reactor Coolant System Activity	10/15	11/15	12/15	1/16	2/16	3/16	4/16	5/16	6/16	7/16	8/16	9/16
Maximum activity	0.000257	0.000254	0.000278	0.000307	0.000286	0.000292	0.000314	0.000178	0.000182	0.000193	0.000306	0.000207
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Licensee Comments: none

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Leakage	10/14	11/14	12/14	1/15	2/15	3/15	4/15	5/15	6/15	7/15	8/15	9/15
Maximum leakage	0.027	0.096	0.028	0.050	0.050	0.043	0.044	0.064	0.055	0.052	0.046	0.036
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.3	1.0	0.3	0.5	0.5	0.4	0.4	0.6	0.6	0.5	0.5	0.4

Reactor Coolant System Leakage	10/15	11/15	12/15	1/16	2/16	3/16	4/16	5/16	6/16	7/16	8/16	9/16
Maximum leakage	0.058	0.068	0.056	0.060	0.071	0.122	0.411	0.062	0.072	0.085	0.087	0.084
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0.6	0.7	0.6	0.6	0.7	1.2	4.1	0.6	0.7	0.9	0.9	0.8

Licensee Comments: none

Drill/Exercise Performance



Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16
Successful opportunities	137.0	42.0	38.0	50.0	163.0	203.0	3.0	46.0
Total opportunities	139.0	42.0	38.0	50.0	164.0	206.0	3.0	48.0
Indicator value	97.0%	97.7%	97.7%	97.7%	98.2%	98.4%	98.3%	98.8%


Licensee Comments:

1Q/16: On March 29, 2016, a new shift manager became qualified in two key ERO positions and completed two opportunities and successes which were not included in the previously submitted data. No color change.

4Q/15: The total number of drill / exercise opportunities and successes was revised from 87 to 86 each (no additional failures). No color change resulted.

1Q/15: Corrected March 2014 EP01 drill success and total opportunities that included one item that should not have been counted. Discovered in March 2015. No color change as a result.

ERO Drill Participation



Thresholds: White < 80.0% Yellow < 60.0%


Notes

ERO Drill Participation	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16
Participating Key personnel	85.0	91.0	91.0	95.0	91.0	91.0	95.0	93.0
Total Key personnel	85.0	93.0	91.0	95.0	91.0	91.0	95.0	93.0
Indicator value	100.0%	97.8%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments:

1Q/16: On March 29, 2016, a new shift manager became qualified in two key ERO positions which were not included in the previously submitted data. No color change.

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16
Successful siren-tests	960	908	912	909	1008	1102	1044	1102
Total sirens-tests	960	912	912	912	1008	1102	1044	1102
Indicator value	99.8%	99.7%	99.7%	99.8%	99.8%	99.9%	99.9%	100.0%

Licensee Comments: none

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16
High radiation area occurrences	0	0	0	0	0	0	1	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	1	1

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	4Q/14	1Q/15	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.

▲ [Action Matrix Summary](#) | [Inspection Findings Summary](#) | [PI Summary](#) | [Reactor Oversight Process](#)

Last Modified: October 23, 2016