



Home > Nuclear Reactors > Operating Reactors > Reactor Oversight Process > Plant Summaries> Calvert Cliffs 1 > Quarterly Performance Indicators

Calvert Cliffs 1 – Quarterly Performance Indicators

1Q/2017 Performance Indicators


The solid trend line represents the current reporting period.

Licensee's General Comments: none

On this page:

- Unplanned Scrams (IE01)
- Unplanned Power Changes per 7000 Critical Hours (IE03)
- Unplanned Scrams with Complications (IE04)
- Safety System Functional Failures (MS05)
- Emergency AC Power Systems (MS06)
- High Pressure Injection Systems (MS07)
- Heat Removal Systems (MS08)
- Residual Heat Removal Systems (MS09)
- Cooling Water Systems (MS10)
- Reactor Coolant System Activity (BI01)
- Reactor Coolant System Leakage (BI02)
- Drill/Exercise Performance (EP01)
- Emergency Response Organization Drill Participation (EP02)
- Alert and Notification System Reliability (EP03)
- Occupational Exposure Control Effectiveness (OR01)
- RETS/OCDM Radiological Effluent Occurrence (PR01)
- Protected Area Equipment (PP01)

Unplanned Scrams per 7000 Critical Hrs



Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes


Unplanned Scrams per 7000 Critical Hrs	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17
Unplanned scrams	1.0	0	0	1.0	1.0	0	0	0
Critical hours	2146.5	2208.0	2209.0	1592.5	2157.6	2208.0	2209.0	2159.0

Indicator value	0.8	0.8	0.8	1.7	1.7	1.7	1.7	0.8
-----------------	-----	-----	-----	-----	-----	-----	-----	-----

▲ TOP

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs



Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17
Unplanned power changes	0	0	0	2.0	0	0	0	0
Critical hours	2146.5	2208.0	2209.0	1592.5	2157.6	2208.0	2209.0	2159.0

Indicator value	1.6	0	0	1.7	1.7	1.7	1.7	0
------------------------	------------	----------	----------	------------	------------	------------	------------	----------


▲ TOP

Licensee Comments:

1Q/16: 1/10/17: This is a correction: This should have been counted in March as an unplanned power change per NEI 99-02 but was not counted in error. IR 3953568 documents this issue.

1Q/16: 3/12/2016 MSIV hydraulic leak downpower initially recorded as Unplanned Power Change. Corrected record in June for March, Unit SDs impacting this time period 16-003. IR 2671497/2639325

Unplanned Scrams with Complications



Thresholds: White > 1.0

Notes


Unplanned Scrams with Complications	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17
Scrams with complications	0	0	0	0	0	0	0	0

Indicator value	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
------------------------	------------	------------	------------	------------	------------	------------	------------	------------

▲ TOP

Licensee Comments: none

Safety System Functional Failures (PWR)



Thresholds: White > 5.0

Notes

Safety System Functional Failures (PWR) 2Q/15 3Q/15 4Q/15 1Q/16 2Q/16 3Q/16 4Q/16 1Q/17

Safety System Functional Failures 0 0 1 1 0 0 0 0

Indicator value 1 1 2 2 2 2 1 0


[TOP](#)

Licensee Comments:

2Q/16: 8/2016: Changed CDE June 2016 value 1 to 0 for LER-2016-004. LER was submitted in June 2016 after the 60 report requirement (March) and counted in CDE in June. In August it was determined the SSFF should have been counted in March as that is the original 60 day LER report date.

1Q/16: 8/2016: Changed CDE March 2016 value 0 to 1 for LER-2016-004. LER was submitted in June 2016 after the 60 report requirement (March) and counted in CDE in June. In August it was determined the SSFF should have been counted in March as that is the original 60 day LER report date.

Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes


Mitigating Systems Performance Index, Emergency AC Power System

	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17
UAI (ΔCDF)	3.16E-08	3.04E-08	-1.88E-09	1.55E-08	1.56E-08	3.93E-08	2.27E-08	1.66E-08
URI (ΔCDF)	2.15E-07	2.11E-07	2.10E-07	1.68E-07	1.60E-07	1.58E-07	1.56E-07	1.52E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	2.50E-07	2.40E-07	2.10E-07	1.80E-07	1.80E-07	2.00E-07	1.80E-07	1.70E-07

▲ TOP

Licensee Comments: none

Mitigating Systems Performance Index, High Pressure Injection System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes


Mitigating Systems Performance Index, High Pressure Injection System

	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17
UAI (ΔCDF)	-2.11E-08	-2.24E-08	-2.27E-08	-2.52E-08	-2.01E-08	-2.03E-08	-2.03E-08	-2.52E-08
URI (ΔCDF)	-2.73E-08	-2.59E-08	-2.54E-08	-2.46E-08	-2.65E-08	-3.03E-08	-3.17E-08	-3.00E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-4.80E-08	-4.80E-08	-4.80E-08	-5.00E-08	-4.70E-08	-5.10E-08	-5.20E-08	-5.50E-08

▲ TOP

Licensee Comments: none

Mitigating Systems Performance Index, Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes


Mitigating Systems Performance Index, Heat Removal System

	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17
UAI (ΔCDF)	-1.30E-09	-1.36E-09	2.10E-10	-1.06E-08	-1.01E-08	-4.17E-09	-6.06E-09	-1.67E-09
URI (ΔCDF)	-3.12E-08	-3.12E-08	-3.23E-08	-4.27E-08	-4.34E-08	-4.39E-08	-4.31E-08	-3.93E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-3.20E-08	-3.30E-08	-3.20E-08	-5.30E-08	-5.30E-08	-4.80E-08	-4.90E-08	-4.10E-08

▲ TOP

Licensee Comments: none

Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes


Mitigating Systems Performance Index, Residual Heat Removal System

	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17
UAI (Δ CDF)	-5.56E-08	-5.56E-08	-5.09E-08	-4.54E-08	-4.54E-08	-4.54E-08	-4.54E-08	-4.54E-08
URI (Δ CDF)	-4.15E-09	-4.15E-09	-4.15E-09	-5.76E-09	-5.84E-09	-5.82E-09	-5.79E-09	-4.99E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-6.00E-08	-6.00E-08	-5.50E-08	-5.10E-08	-5.10E-08	-5.10E-08	-5.10E-08	-5.00E-08

▲ TOP

Licensee Comments: none

Mitigating Systems Performance Index, Cooling Water Systems



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes


Mitigating Systems Performance Index, Cooling Water Systems

	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17
UAI (ΔCDF)	3.66E-08	3.90E-08	8.12E-08	1.36E-07	1.11E-07	1.11E-07	1.24E-08	-1.01E-07
URI (ΔCDF)	-2.06E-07	-2.06E-07	-2.06E-07	-2.13E-07	-2.13E-07	-2.12E-07	-2.12E-07	-2.12E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.70E-07	-1.70E-07	-1.20E-07	-7.70E-08	-1.00E-07	-1.00E-07	-2.00E-07	-3.10E-07

▲ TOP

Licensee Comments: none

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	4/15	5/15	6/15	7/15	8/15	9/15	10/15	11/15	12/15	1/16	2/16	3/16
Maximum activity	0.002880	0.002460	0.002590	0.002850	0.002650	0.004480	0.003010	0.002870	0.003150	0.003050	0.002970	0.001070
Technical specification limit	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
Indicator value	0.6	0.5	0.5	0.6	0.5	0.9	0.6	0.6	0.6	0.6	0.6	0.2
Reactor Coolant System Activity	4/16	5/16	6/16	7/16	8/16	9/16	10/16	11/16	12/16	1/17	2/17	3/17
Maximum activity	0.000828	0.001430	0.001450	0.001530	0.001650	0.001700	0.001820	0.001850	0.001920	0.001920	0.001960	0.001960
Technical specification limit	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
Indicator value	0.2	0.3	0.3	0.3	0.3	0.3	0.4	0.4	0.4	0.4	0.4	0.4

▲ TOP

Licensee Comments: none

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	4/15	5/15	6/15	7/15	8/15	9/15	10/15	11/15	12/15	1/16	2/16	3/16
Maximum leakage	0	0	0	0	0	0	0	0	0	0	0	0
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0


Reactor Coolant System Leakage	4/16	5/16	6/16	7/16	8/16	9/16	10/16	11/16	12/16	1/17	2/17	3/17
Maximum leakage	0	0	0	0	0	0	0	0	0	0	0	0
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0

Indicator value	0	0	0	0	0	0	0	0	0	0	0	0
------------------------	----------	----------	----------	----------	----------	----------	----------	----------	----------	----------	----------	----------

TOP

Licensee Comments: none

Drill/Exercise Performance



Thresholds: White < 90.0% Yellow < 70.0%

Notes


Drill/Exercise Performance	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17
Successful opportunities	75.0	44.0	60.0	42.0	30.0	74.0	71.0	8.0
Total opportunities	76.0	45.0	60.0	42.0	30.0	74.0	72.0	8.0

Indicator value 97.5% 97.4% 98.3% 98.4% 98.9% 99.2% 99.3% 99.3%

▲ TOP

Licensee Comments: none

ERO Drill Participation



Thresholds: White < 80.0% Yellow < 60.0%

Notes


ERO Drill Participation	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17
Participating Key personnel	46.0	46.0	46.0	52.0	55.0	51.0	52.0	48.0
Total Key personnel	46.0	46.0	46.0	52.0	55.0	51.0	52.0	48.0

Indicator value **100.0% 100.0% 100.0% 100.0% 100.0% 100.0% 100.0% 100.0%**

▲ TOP

Licensee Comments: none

Alert & Notification System



Thresholds: White < 94.0% Yellow < 90.0%

Notes


Alert & Notification System	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17
Successful siren-tests	948	949	948	949	948	946	945	943
Total sirens-tests	949	949	949	949	949	949	949	949

Indicator value 99.8% 99.9% 99.9% 99.9% 99.9% 99.9% 99.8% 99.6%

▲ TOP

Licensee Comments: none

Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0

Notes


Occupational Exposure Control Effectiveness 2Q/15 3Q/15 4Q/15 1Q/16 2Q/16 3Q/16 4Q/16 1Q/17

High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

TOP

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent 2Q/15 3Q/15 4Q/15 1Q/16 2Q/16 3Q/16 4Q/16 1Q/17

RETS/ODCM occurrences 0 0 0 0 0 0 0 0

Indicator value 0 0 0 0 0 0 0 0

[TOP](#)

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.

Current data as of: May 5, 2017

Page Last Reviewed/Updated Wednesday, June 07, 2017