



Home > Nuclear Reactors > Operating Reactors > Reactor Oversight Process > Plant Summaries > Nine Mile Point 2 > Quarterly Performance Indicators

Nine Mile Point 2 – Quarterly Performance Indicators

1Q/2017 Performance Indicators


The solid trend line represents the current reporting period.

Licensee's General Comments: Change to RCS Identified Leakage to correct a typo, in the month of Oct 2016, NRC indicator for RCS leakage remains GREEN.

On this page:

- Unplanned Scrams (IE01)
- Unplanned Power Changes per 7000 Critical Hours (IE03)
- Unplanned Scrams with Complications (IE04)
- Safety System Functional Failures (MS05)
- Emergency AC Power Systems (MS06)
- High Pressure Injection Systems (MS07)
- Heat Removal Systems (MS08)
- Residual Heat Removal Systems (MS09)
- Cooling Water Systems (MS10)
- Reactor Coolant System Activity (BI01)
- Reactor Coolant System Leakage (BI02)
- Drill/Exercise Performance (EP01)
- Emergency Response Organization Drill Participation (EP02)
- Alert and Notification System Reliability (EP03)
- Occupational Exposure Control Effectiveness (OR01)
- RETS/OCDM Radiological Effluent Occurrence (PR01)
- Protected Area Equipment (PP01)

Unplanned Scrams per 7000 Critical Hrs



Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0


Notes

Unplanned Scrams per 7000 Critical Hrs	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17
Unplanned scrams	0	0	0	0	0	0	0	0
Critical hours	2184.0	2208.0	2209.0	2183.0	1618.0	2208.0	1970.9	2159.0
Indicator value	0.8	0.8	0.8	0	0	0	0	0

TOP

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs



Thresholds: White > 6.0

Notes


Unplanned Power Changes per 7000 Critical Hrs	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17
Unplanned power changes	0	0	0	0	0	0	2.0	0
Critical hours	2184.0	2208.0	2209.0	2183.0	1618.0	2208.0	1970.9	2159.0

Indicator value 0 0 0 0 0 0 1.8 1.8

▲ TOP

Licensee Comments: none

Unplanned Scrams with Complications



Thresholds: White > 1.0

Notes


Unplanned Scrams with Complications	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17
Scrams with complications	0	0	0	0	0	0	0	0

Indicator value 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0

▲ TOP

Licensee Comments: none

Safety System Functional Failures (BWR)



Thresholds: White > 6.0

Notes


Safety System Functional Failures (BWR) 2Q/15 3Q/15 4Q/15 1Q/16 2Q/16 3Q/16 4Q/16 1Q/17
 Safety System Functional Failures 0 0 0 1 0 0 0 0

Indicator value 0 0 0 1 1 1 1 0

▲ TOP

Licensee Comments: none

Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Emergency AC Power System


	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17
UAI (ΔCDF)	-1.45E-08	-1.45E-08	-1.45E-08	-2.31E-08	-2.31E-08	-1.90E-08	-1.89E-08	-5.18E-09
URI (ΔCDF)	-1.15E-07	-1.14E-07	-1.09E-07	-2.11E-07	-2.13E-07	-1.23E-07	-1.39E-07	-1.31E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-1.30E-07	-1.30E-07	-1.20E-07	-2.30E-07	-2.40E-07	-1.40E-07	-1.60E-07	-1.40E-07

▲ TOP

Licensee Comments:

1Q/16: Changed PRA Parameter(s).

Mitigating Systems Performance Index, High Pressure Injection System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, High Pressure Injection System


	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17
UAI (ΔCDF)	-8.11E-09	-1.53E-08	-1.38E-08	-2.17E-08	-2.17E-08	-2.17E-08	-2.17E-08	-2.17E-08
URI (ΔCDF)	-2.76E-08	-2.74E-08	-2.72E-08	-3.49E-08	-3.52E-08	-3.47E-08	-3.85E-08	-3.88E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-3.60E-08	-4.30E-08	-4.10E-08	-5.70E-08	-5.70E-08	-5.60E-08	-6.00E-08	-6.00E-08

TOP

Licensee Comments:

1Q/16: Changed PRA Parameter(s).

Mitigating Systems Performance Index, Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System


	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17
UAI (Δ CDF)	-4.77E-09	-4.79E-09	-6.96E-09	-1.08E-08	-1.12E-08	-1.12E-08	-1.12E-08	-1.13E-08
URI (Δ CDF)	-2.32E-08	-2.18E-08	-2.11E-08	-2.51E-08	-2.70E-08	-2.70E-08	-2.70E-08	-2.61E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-2.80E-08	-2.70E-08	-2.80E-08	-3.60E-08	-3.80E-08	-3.80E-08	-3.80E-08	-3.70E-08

TOP

Licensee Comments:

1Q/16: Changed PRA Parameter(s).

Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Residual Heat Removal System


	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17
UAI (Δ CDF)	-6.00E-09	-6.01E-09	-6.03E-09	-1.31E-08	-1.31E-08	-1.31E-08	-1.31E-08	-1.31E-08
URI (Δ CDF)	-1.90E-08	-1.86E-08	-1.79E-08	-2.00E-08	-2.27E-08	-2.29E-08	-2.30E-08	-2.17E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-2.50E-08	-2.50E-08	-2.40E-08	-3.30E-08	-3.60E-08	-3.60E-08	-3.60E-08	-3.50E-08

▲ TOP

Licensee Comments:

1Q/16: Changed PRA Parameter(s).

Mitigating Systems Performance Index, Cooling Water Systems



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Cooling Water Systems


	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17
UAI (Δ CDF)	-6.33E-10	-6.34E-10	-5.50E-10	-7.26E-10	-9.19E-10	-9.19E-10	-9.90E-10	-9.92E-10
URI (Δ CDF)	2.14E-08	2.18E-08	2.24E-08	1.48E-09	-3.39E-10	-3.33E-10	-3.40E-10	-3.31E-10
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	2.10E-08	2.10E-08	2.20E-08	1.50E-09	-3.50E-10	-3.40E-10	-3.50E-10	-3.40E-10

▲ TOP

Licensee Comments:

1Q/16: Changed PRA Parameter(s).

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	4/15	5/15	6/15	7/15	8/15	9/15	10/15	11/15	12/15	1/16	2/16	3/16
Maximum activity	0.000010	0.000009	0.000011	0.000013	0.000013	0.000014	0.000014	0.000014	0.000014	0.000013	0.000011	0.000057
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0
Reactor Coolant System Activity	4/16	5/16	6/16	7/16	8/16	9/16	10/16	11/16	12/16	1/17	2/17	3/17
Maximum activity	0.000009	0.000007	0.000008	0.000009	0.000007	0.000009	0.000008	0.000010	0.000010	0.000010	0.000008	0.000009
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

▲ TOP

Licensee Comments: none

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	4/15	5/15	6/15	7/15	8/15	9/15	10/15	11/15	12/15	1/16	2/16	3/16
Maximum leakage	2.549	2.590	2.607	2.569	2.568	2.581	2.572	2.626	2.582	2.568	2.600	2.582
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0


Indicator value	10.2	10.4	10.4	10.3	10.3	10.3	10.3	10.5	10.3	10.3	10.4	10.3
Reactor Coolant System Leakage	4/16	5/16	6/16	7/16	8/16	9/16	10/16	11/16	12/16	1/17	2/17	3/17
Maximum leakage	2.700	2.620	2.685	2.616	2.605	2.630	2.596	2.660	2.628	2.596	2.600	2.598
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0

Indicator value	10.8	10.5	10.7	10.5	10.4	10.5	10.4	10.6	10.5	10.4	10.4	10.4
------------------------	-------------	-------------	-------------	-------------	-------------	-------------	-------------	-------------	-------------	-------------	-------------	-------------

▲ TOP

Licensee Comments: none

Drill/Exercise Performance



Thresholds: White < 90.0% Yellow < 70.0%

Notes


Drill/Exercise Performance	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17
Successful opportunities	0	25.0	54.0	38.0	14.0	51.0	70.0	31.0
Total opportunities	0	25.0	55.0	38.0	14.0	52.0	71.0	31.0

Indicator value **95.7% 96.5% 96.5% 97.1% 97.1% 96.7% 97.7% 99.0%**

▲ TOP

Licensee Comments: none

ERO Drill Participation



Thresholds: White < 80.0% Yellow < 60.0%

Notes


ERO Drill Participation	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17
Participating Key personnel	78.0	82.0	83.0	82.0	85.0	92.0	93.0	85.0
Total Key personnel	78.0	82.0	83.0	82.0	85.0	92.0	93.0	85.0

Indicator value **100.0% 100.0% 100.0% 100.0% 100.0% 100.0% 100.0% 100.0%**

▲ TOP

Licensee Comments: none

Alert & Notification System



Thresholds: White < 94.0% Yellow < 90.0%

Notes


Alert & Notification System	2Q/15	3Q/15	4Q/15	1Q/16	2Q/16	3Q/16	4Q/16	1Q/17
Successful siren-tests	258	258	296	348	520	520	520	520
Total sirens-tests	259	259	296	348	520	520	520	520

Indicator value 99.9% 99.8% 99.8% 99.8% 99.9% 100.0% 100.0% 100.0%

▲ TOP

Licensee Comments: none

Occupational Exposure Control Effectiveness



Thresholds: White > 2.0 Yellow > 5.0

Notes


Occupational Exposure Control Effectiveness 2Q/15 3Q/15 4Q/15 1Q/16 2Q/16 3Q/16 4Q/16 1Q/17

High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

▲ TOP

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent 2Q/15 3Q/15 4Q/15 1Q/16 2Q/16 3Q/16 4Q/16 1Q/17

RETS/ODCM occurrences 0 0 0 0 0 0 0 0

Indicator value 0 0 0 0 0 0 0 0

[TOP](#)

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.

Current data as of: May 5, 2017

Page Last Reviewed/Updated Wednesday, June 07, 2017